



# NEILSON RESEARCH CORPORATION

*Environmental Testing Laboratory*

8/17/2016

Rick Rose  
Medford School District  
815 S Oakdale Ave  
Medford, OR 97501

TEL: (541) 842-1138

FAX: 541-842-1160

RE: 16-24 Jackson Lead Study

Order No.: 1608810

Dear Rick Rose:

Neilson Research Corporation received 4 sample(s) on 8/15/2016 for the analyses presented in the following report.

The results relate only to the parameters tested or to the sample as received by the laboratory. This report shall not be reproduced except in full, without the written approval of Neilson Research Corporation. If you have any questions regarding these test results, please feel free to call.

Sincerely,  
Neilson Research Corporation

Alec C Smith  
Project Manager

# Neilson Research Corporation

245 South Grape Street, Medford, Oregon 97501 541-770-5678 Fax 541-770-2901

## Analysis Report

ORELAP 100016  
EPA OR00028

**CLIENT:** Medford School District  
**Project:** 16-24 Jackson Lead Study  
**Lab Order:** 1608810

**Date:** 17-Aug-16

## CASE NARRATIVE

The analyses were performed according to the guidelines in the Neilson Research Corporation Quality Assurance Program. This report contains analytical results for the sample(s) as received by the laboratory.

Neilson Research Corporation certifies that this report is in compliance with the requirements of NELAP. No unusual difficulties were experienced during analysis of this batch except as noted below or qualified with data flags on the reports.

# Neilson Research Corporation

245 South Grape Street, Medford, Oregon 97501 541-770-5678 Fax 541-770-2901

## Analysis Report

ORELAP 100016  
EPA OR00028

Medford School District  
815 S Oakdale Ave  
Medford, OR 97501

Lab Order: **1608810**  
NRC Sample ID: **1608810-01A**  
Collection Date: **8/13/2016 8:23:00 AM**  
Received Date: **8/15/2016 8:10:00 AM**  
Reported Date: **8/17/2016 4:24:56 PM**

### Sample Information:

16-24 Jackson Lead Study

Client Sample ID: Bottle #23437  
Collectors Name: John Jessen  
Sample Location: Mech Rm Dwn frm PRV  
Source: City Water

## ANALYTICAL RESULTS

Analyses	Method	NELAP Accredited	Result	Qual	MRL	Units	EPA Limit	Date Analyzed	Analyst
Lead	EPA 200.8	A	0.00416		0.000103	mg/L	0.020 AL	8/16/2016	OML

Notes: ND - Not Detected at the MRL

N.L. - No Limit

MRL - Minimum Reporting Limit

# Neilson Research Corporation

245 South Grape Street, Medford, Oregon 97501 541-770-5678 Fax 541-770-2901

## Analysis Report

ORELAP 100016  
EPA OR00028

Medford School District  
815 S Oakdale Ave  
Medford, OR 97501

Lab Order: **1608810**  
NRC Sample ID: **1608810-02A**  
Collection Date: **8/13/2016 8:14:00 AM**  
Received Date: **8/15/2016 8:10:00 AM**  
Reported Date: **8/17/2016 4:24:56 PM**

### Sample Information:

16-24 Jackson Lead Study

Client Sample ID: Bottle #23436  
Collectors Name: John Jessen  
Sample Location: Pot. BF by Meter 1st Port A  
Source: City Water

## ANALYTICAL RESULTS

Analyses	Method	NELAP Accredited	Result	Qual	MRL	Units	EPA Limit	Date Analyzed	Analyst
Lead	EPA 200.8	A	0.00117		0.000103	mg/L	0.020 AL	8/16/2016	OML

Notes: ND - Not Detected at the MRL

N.L. - No Limit

MRL - Minimum Reporting Limit

# Neilson Research Corporation

245 South Grape Street, Medford, Oregon 97501 541-770-5678 Fax 541-770-2901

## Analysis Report

ORELAP 100016  
EPA OR00028

Medford School District  
815 S Oakdale Ave  
Medford, OR 97501

Lab Order: **1608810**  
NRC Sample ID: **1608810-03A**  
Collection Date: **8/13/2016 8:15:00 AM**  
Received Date: **8/15/2016 8:10:00 AM**  
Reported Date: **8/17/2016 4:24:57 PM**

### Sample Information:

16-24 Jackson Lead Study

Client Sample ID: Bottle #23439  
Collectors Name: John Jessen  
Sample Location: Pot. BF by Meter 1st Port B  
Source: City Water

## ANALYTICAL RESULTS

Analyses	Method	NELAP Accredited	Result	Qual	MRL	Units	EPA Limit	Date Analyzed	Analyst
Lead	EPA 200.8	A	0.000743		0.000103	mg/L	0.020 AL	8/16/2016	OML

Notes: ND - Not Detected at the MRL

N.L. - No Limit

MRL - Minimum Reporting Limit

# Neilson Research Corporation

245 South Grape Street, Medford, Oregon 97501 541-770-5678 Fax 541-770-2901

## Analysis Report

ORELAP 100016  
EPA OR00028

Medford School District  
815 S Oakdale Ave  
Medford, OR 97501

Lab Order: **1608810**  
NRC Sample ID: **1608810-04A**  
Collection Date: **8/13/2016 8:17:00 AM**  
Received Date: **8/15/2016 8:10:00 AM**  
Reported Date: **8/17/2016 4:24:57 PM**

### Sample Information:

16-24 Jackson Lead Study

Client Sample ID: Bottle #23441  
Collectors Name: John Jessen  
Sample Location: Pot. BF by Meter 1st Port C  
Source: City Water

## ANALYTICAL RESULTS

Analyses	Method	NELAP Accredited	Result	Qual	MRL	Units	EPA Limit	Date Analyzed	Analyst
Lead	EPA 200.8	A	0.000725		0.000103	mg/L	0.020 AL	8/16/2016	OML

Notes: ND - Not Detected at the MRL

N.L. - No Limit

MRL - Minimum Reporting Limit

CLIENT: Medford School District  
 Work Order: 1608810  
 Project: 16-24 Jackson Lead Study

**ANALYTICAL QC SUMMARY REPORT**

TestCode: ICPMS\_200.8\_SCHOOL

Sample ID: <b>MB-36263</b>	SampType: <b>MBLK</b>	TestCode: <b>ICPMS_200.8</b>	Units: <b>mg/L</b>	Prep Date: <b>8/16/2016</b>	RunNo: <b>89252</b>						
Client ID: <b>ZZZZZ</b>	Batch ID: <b>36263</b>	TestNo: <b>EPA 200.8</b>	<b>(EPA 200.8)</b>	Analysis Date: <b>8/16/2016</b>	SeqNo: <b>1346384</b>						
Analyte	Result	MRL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual

Lead ND 0.000103

Sample ID: <b>LCS-36263</b>	SampType: <b>LCS</b>	TestCode: <b>ICPMS_200.8</b>	Units: <b>mg/L</b>	Prep Date: <b>8/16/2016</b>	RunNo: <b>89252</b>						
Client ID: <b>ZZZZZ</b>	Batch ID: <b>36263</b>	TestNo: <b>EPA 200.8</b>	<b>(EPA 200.8)</b>	Analysis Date: <b>8/16/2016</b>	SeqNo: <b>1346385</b>						
Analyte	Result	MRL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual

Lead 0.1057 0.000104 0.1 0 106 85 115

Sample ID: <b>1608817-03AMS</b>	SampType: <b>MS</b>	TestCode: <b>ICPMS_200.8</b>	Units: <b>mg/L</b>	Prep Date: <b>8/16/2016</b>	RunNo: <b>89252</b>						
Client ID: <b>ZZZZZ</b>	Batch ID: <b>36263</b>	TestNo: <b>EPA 200.8</b>	<b>(EPA 200.8)</b>	Analysis Date: <b>8/16/2016</b>	SeqNo: <b>1346404</b>						
Analyte	Result	MRL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual

Lead 0.1050 0.000104 0.1 0.001084 104 70 130

Sample ID: <b>1608817-03AMSD</b>	SampType: <b>MSD</b>	TestCode: <b>ICPMS_200.8</b>	Units: <b>mg/L</b>	Prep Date: <b>8/16/2016</b>	RunNo: <b>89252</b>						
Client ID: <b>ZZZZZ</b>	Batch ID: <b>36263</b>	TestNo: <b>EPA 200.8</b>	<b>(EPA 200.8)</b>	Analysis Date: <b>8/16/2016</b>	SeqNo: <b>1346405</b>						
Analyte	Result	MRL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual

Lead 0.1066 0.000104 0.1 0.001084 106 70 130 0.105 1.47 20

**Qualifiers:** E Value above quantitation range H Holding times for preparation or analysis exceeded J Analyte detected below quantitation limits  
 ND Not Detected at the Minimum Reporting Limit R RPD outside accepted recovery limits S Spike Recovery outside accepted recovery limits



Environmental Testing Laboratory  
 245 South Grape Street • Medford, OR 97501  
 (541) 770-5678 Fax (541) 770-2901

# RUSH Chain of Custody Record

This Chain of Custody is a LEGAL DOCUMENT and must be filled out accurately.

*Jason*

**Section A**  
 Required Client Information

Company: Hell S.S. Dist. 549C  
 Address: 815 S. Oakdale  
Medford, OR 97501  
 Email: rick.rosengard@medford.k12.or.us  
 Phone: 541-744-5613 Fax: \_\_\_\_\_  
 Collected By (Print): John Sesson  
 Collected By (Sign): [Signature]  
 Email Report  Yes  No Mail Report  Yes  No  
 Fax Report  Yes  No

**Section B**  
 Required Project Information

Project Name: 2016 Lead Testing  
 Project Number: Jason  
 Report To: rick.rosengard@medford.k12.or.us  
 Copy To: ron.kovlitz@medford.k12.or.us

**Section C**  
 Invoice Information

Attention: \_\_\_\_\_  
 Company Name: \_\_\_\_\_  
 Address: \_\_\_\_\_  
 P.O. # \_\_\_\_\_

**Section D**  
 Rush Status (Subject to Scheduling)

Standard 10-14 Days  
 5 Business Days (50% surcharge)  
 3 Business Days (75% surcharge)  
 24 - 48 hours (100% surcharge)  
 Other: \_\_\_\_\_  
 Authorized  Yes  No

**Section E**  
 Sample Information

Sample ID	Temp/Grab	Matrix*	Date Collected	Time Collected	No. of Containers	Analysis Requested	NRC Workorder # <small>(Use this only)</small>	NRC Sample # <small>(Lab Use Only)</small>
<u>Med. Rin Main 2nd Drain Don'ton PQ</u>	<u>23437</u>		<u>8/13/16</u>	<u>9:23am</u>	<u>1</u>		<u>157 Draw</u>	<u>01</u>
<u>Stable Bottle for Clocetic Hts. Washroom</u>	<u>23436</u>			<u>8:14am</u>	<u>1</u>		<u>1st Draw</u>	<u>02</u>
	<u>23439</u>			<u>8:15am</u>	<u>1</u>		<u>2nd Draw</u>	<u>03</u>
	<u>23441</u>			<u>8:16am</u>	<u>1</u>		<u>3rd Draw (Washed Field)</u>	<u>04</u>

**Section F**  
 Relinquish/Receive

\*Matrix: DW - Drinking Water WW - Wastewater W - Water S - Soil/Solid SL - Sludge O - Oil WP - Wipe OT - Other

Relinquished By: [Signature] Sign  
 Received By: John Sesson Sign  
 Date: 8/15/16 Time: 8:10am

Relinquished By: \_\_\_\_\_  
 Received By: \_\_\_\_\_  
 Relinquished By: \_\_\_\_\_  
 Received By: \_\_\_\_\_

Received By Laboratory: 1211 N. 1st St. Medford, OR 97504

**Section G**  
 Lab Use Only

Temp: AW  
 4°C - 7.2°C: Yes  No   
 Refrigerated: Yes  No   
 Number of Bottles Received: 1  
 pH Checked: MS  
 GPC Seal/Intact: Yes  No   
 Field Blank Included: Yes  No   
 Received Via: UPS FedEx Other Hand  
 Payment:  Invoice  Cash  VISA  M/C  Check # \_\_\_\_\_ Amount: \_\_\_\_\_