



Neilson Research Corporation
245 S Grape St
Medford, OR 97501
TEL: (541) 770-5678 FAX: (541) 770-2901
Website: www.nrclabs.com

Andy Chasteen
Medford School District
815 S Oakdale Ave
Medford, OR 97501
TEL: 541-842-3646
FAX: 541-842-1160

RE: Ruch Elementary Routine Bacteria

Order No.: 19041022

Dear Andy Chasteen:

Neilson Research Corporation received 1 sample(s) on 4/24/2019 for the analyses presented in the following report.

The results relate only to the parameters tested or to the sample as received by the laboratory. This report shall not be reproduced except in full, without the written approval of Neilson Research Corporation. If you have any questions regarding these test results, please feel free to call.

Sincerely,
Neilson Research Corporation

Tamra Schmedemann
Senior Project Manager
245 S Grape St
Medford, OR 97501



Neilson Research Corporation
245 S Grape St
Medford, OR 97501
TEL: (541) 770-5678 FAX: (541) 770-2901
Website: www.nrclabs.com

Case Narrative

WO#: **19041022**

Date:

CLIENT: Medford School District

Project: Ruch Elementary Routine Bacteria

The analyses were performed according to the guidelines in the Neilson Research Corporation Quality Assurance Program. This report contains analytical results for the sample(s) as received by the laboratory.

Neilson Research Corporation certifies that this report is in compliance with the requirements of NELAP. No unusual difficulties were experienced during analysis of this batch except as noted below or qualified with data flags on the reports.

Original



Neilson Research Corporation
 245 S Grape St
 Medford, OR 97501
 TEL: (541) 770-5678 FAX: (541) 770-2901
 Website: www.nrclabs.com

Analytical Report

WO#: **19041022**
 Date Reported:

CLIENT: Medford School District
Lab ID: 19041022-01
Client Sample ID: Ruch Elementary
Project: Ruch Elementary Routine Bacteria
Sample Location: Staff Room Sink
Sample Address:

Collection Date: 4/24/2019 11:37:00 AM
Received Date: 4/24/2019 1:45:16 PM
Matrix: DRINKING WATER
PWS #: 41-91508 RUCH ELEM
Source ID: DIST-A
Sample Collector: PERRY YORKS
Residual Chlorine:

Analyses	Method	NELAP Status	Result	Qual	Units	Date Analyzed/Analyst
----------	--------	--------------	--------	------	-------	-----------------------

TOTAL COLIFORM BACTERIA BY COLILERT

Total Coliform Bacteria	A9223B	A	Absent		P/A	04/24/19 17:49 MES
E. Coli Bacteria	A9223B	A	Absent		P/A	04/24/19 17:49 MES

QUALIFIERS

C1	Sample container temperature is out of limit as specified at testcode	H	Holding times for preparation or analysis exceeded
MI	Recovery outside control limits due to Matrix Interference	ND	Not Detected at the Reporting Limit
PL	Permit Limit		

Original

NELAP

NELAP A Accredited. ORELAP 100016, OR-028