



Neilson Research Corporation  
245 S Grape St  
Medford, OR 97501  
TEL: (541) 770-5678 FAX: (541) 770-2901  
Website: [www.nrclabs.com](http://www.nrclabs.com)

March 24, 2020

Ron Havniar  
Medford School District  
815 S Oakdale Ave  
Medford, OR 97501  
TEL: 541-842-3646  
FAX: 541-842-1160

RE: 18-52 Ruch 2020 Lead Testing

Order No.: 20030804

Dear Ron Havniar:

Neilson Research Corporation received 4 sample(s) on 3/18/2020 for the analyses presented in the following report.

The results relate only to the parameters tested or to the sample as received by the laboratory. This report shall not be reproduced except in full, without the written approval of Neilson Research Corporation. If you have any questions regarding these test results, please feel free to call.

Sincerely,  
Neilson Research Corporation

Tamra Schmedemann  
Senior Project Manager  
245 S Grape St  
Medford, OR 97501



Neilson Research Corporation  
245 S Grape St  
Medford, OR 97501  
TEL: (541) 770-5678 FAX: (541) 770-2901  
Website: www.nrclabs.com

## Case Narrative

WO#: 20030804  
Date: 3/24/2020

---

**CLIENT:** Medford School District  
**Project:** 18-52 Ruch 2020 Lead Testing

---

The analyses were performed according to the guidelines in the Neilson Research Corporation Quality Assurance Program. This report contains analytical results for the sample(s) as received by the laboratory.

Neilson Research Corporation certifies that this report is in compliance with the requirements of NELAP. No unusual difficulties were experienced during analysis of this batch except as noted below or qualified with data flags on the reports.

---

Original



Neilson Research Corporation  
 245 S Grape St  
 Medford, OR 97501  
 TEL: (541) 770-5678 FAX: (541) 770-2901  
 Website: www.nrclabs.com

# Analytical Report

WO#: 20030804  
 Date Reported: 3/24/2020

Medford School District  
 815 S Oakdale Ave  
 Medford, OR 97501

**Lab Order:** 20030804  
**Received Date:** 3/18/2020 2:55:00 PM  
**Reported Date:** 3/24/2020 10:55:21 AM

Sample Information:

**Lab ID:** 20030804-01      Client Sample ID: Kitchen Unisex Restroom - Sink  
 Collection Date: 3/18/2020 10:50:00 AM      Collected By:  
 Matrix: Drinking Water      Sample Location: Kitchen Unisex Restroom - Sink

Trace Metals by EPA 200.8 ICP-MS								Analyst: SJS
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	0.00338		0.000103	mg/L	1	3/20/2020	0.0150	A

**Lab ID:** 20030804-02      Client Sample ID: Room 14 - Drinking Fountain (N Side)  
 Collection Date: 3/18/2020 10:52:00 AM      Collected By:  
 Matrix: Drinking Water      Sample Location: Room 14 - Drinking Fountain (N Side)

Trace Metals by EPA 200.8 ICP-MS								Analyst: SJS
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	0.00663		0.000103	mg/L	1	3/20/2020	0.0150	A

**Lab ID:** 20030804-03      Client Sample ID: Room 14 - Drinking Fountain (S Side)  
 Collection Date: 3/18/2020 10:53:00 AM      Collected By:  
 Matrix: Drinking Water      Sample Location: Room 14 - Drinking Fountain (S Side)

Trace Metals by EPA 200.8 ICP-MS								Analyst: SJS
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	0.00283		0.000103	mg/L	1	3/20/2020	0.0150	A

<b>QUALIFIERS</b>	* Value exceeds Maximum Contaminant Level.	C1 Sample container temperature is out of limit as specified at testcode
	E Value above quantitation range	H Holding times for preparation or analysis exceeded
	J Analyte detected below quantitation limits	MI Recovery outside control limits due to Matrix Interference
	ND Not Detected at the Reporting Limit	PL Permit Limit
	R RPD outside accepted recovery limits	

Original



Neilson Research Corporation  
 245 S Grape St  
 Medford, OR 97501  
 TEL: (541) 770-5678 FAX: (541) 770-2901  
 Website: www.nrclabs.com

# Analytical Report

WO#: 20030804  
 Date Reported: 3/24/2020

Medford School District  
 815 S Oakdale Ave  
 Medford , OR 97501

**Lab Order:** 20030804  
**Received Date:** 3/18/2020 2:55:00 PM  
**Reported Date:** 3/24/2020 10:55:21 AM

Sample Information:

**Lab ID:** 20030804-04      Client Sample ID: Room 14 - Sink (S Side)  
 Collection Date: 3/18/2020 10:54:00 AM      Collected By:  
 Matrix: Drinking Water      Sample Location: Room 14 - Sink (S Side)

Trace Metals by EPA 200.8 ICP-MS						Analyst: SJS		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	0.00377		0.000103	mg/L	1	3/20/2020	0.0150	A

<b>QUALIFIERS</b>	* Value exceeds Maximum Contaminant Level.	C1 Sample container temperature is out of limit as specified at testcode
	E Value above quantitation range	H Holding times for preparation or analysis exceeded
	J Analyte detected below quantitation limits	MI Recovery outside control limits due to Matrix Interference
	ND Not Detected at the Reporting Limit	PL Permit Limit
	R RPD outside accepted recovery limits	

Original



Neilson Research Corporation  
 245 S Grape St  
 Medford, OR 97501  
 TEL: (541) 770-5678 FAX: (541) 770-2901  
 Website: www.nrclabs.com

# QC SUMMARY REPORT

WO#: 20030804

24-Mar-20

**Client:** Medford School District  
**Project:** 18-52 Ruch 2020 Lead Testing

**TestCode:** LEAD\_DW

Sample ID: <b>MB-3379</b>	SampType: <b>MBLK</b>	TestCode: <b>LEAD_DW</b>	Units: <b>mg/L</b>	Prep Date: <b>3/19/2020</b>	RunNo: <b>8470</b>						
Client ID: <b>PBW</b>	Batch ID: <b>3379</b>	TestNo: <b>E200.8</b>	<b>E200.8</b>	Analysis Date: <b>3/20/2020</b>	SeqNo: <b>153524</b>						
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual
Lead	ND	0.000103									

Sample ID: <b>LCS-3379</b>	SampType: <b>LCS</b>	TestCode: <b>LEAD_DW</b>	Units: <b>mg/L</b>	Prep Date: <b>3/19/2020</b>	RunNo: <b>8470</b>						
Client ID: <b>LCSW</b>	Batch ID: <b>3379</b>	TestNo: <b>E200.8</b>	<b>E200.8</b>	Analysis Date: <b>3/20/2020</b>	SeqNo: <b>153525</b>						
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual
Lead	0.115	0.000104	0.1000	0	115	85	115				

Sample ID: <b>20030680-170AMS</b>	SampType: <b>MS</b>	TestCode: <b>LEAD_DW</b>	Units: <b>mg/L</b>	Prep Date: <b>3/19/2020</b>	RunNo: <b>8470</b>						
Client ID: <b>BatchQC</b>	Batch ID: <b>3379</b>	TestNo: <b>E200.8</b>	<b>E200.8</b>	Analysis Date: <b>3/20/2020</b>	SeqNo: <b>153532</b>						
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual
Lead	0.119	0.000104	0.1000	0.005966	113	70	130				

Sample ID: <b>20030680-170AMSD</b>	SampType: <b>MSD</b>	TestCode: <b>LEAD_DW</b>	Units: <b>mg/L</b>	Prep Date: <b>3/19/2020</b>	RunNo: <b>8470</b>						
Client ID: <b>BatchQC</b>	Batch ID: <b>3379</b>	TestNo: <b>E200.8</b>	<b>E200.8</b>	Analysis Date: <b>3/20/2020</b>	SeqNo: <b>153533</b>						
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual
Lead	0.114	0.000104	0.1000	0.005966	108	70	130	0.1190	3.94	20	

**Qualifiers:**

* Value exceeds Maximum Contaminant Level.	C1 Sample container temperature is out of limit as specified at testcode	E Value above quantitation range
H Holding times for preparation or analysis exceeded	MI Recovery outside control limits due to Matrix Interference	ND Not Detected at the Reporting Limit
PL Permit Limit	RL Reporting Detection Limit	

Original

# Sample Log-In Check List

Client Name: **MedfordSchoolDist**

Work Order Number: **20030804**

RcptNo: **1**

Logged by:	<b>Denise Neal</b>	<b>3/18/2020 2:55:00 PM</b>	<i>Denise Neal</i>
Completed By:	<b>Michelle Harsh</b>	<b>3/19/2020 8:49:00 AM</b>	<i>Michelle Harsh</i>
Reviewed By:	<b>Tamra Schmedemann</b>	<b>3/24/2020 10:49:37 AM</b>	<i>Tamra Schmedemann</i>

**Chain of Custody**

1. Is Chain of Custody complete? Yes  No  Not Present
2. How was the sample delivered? Client

**Log In**

3. Coolers are present? Yes  No  NA
4. Shipping container/cooler in good condition? Yes  No
- Custody seals intact on shipping container/cooler? Yes  No  Not Present
- No. Seal Date: Signed By:
5. Was an attempt made to cool the samples? Yes  No  NA
6. Were all samples received at a temperature of >0° C to 6.0°C Yes  No  NA
7. Sample(s) in proper container(s)? Yes  No
8. Sufficient sample volume for indicated test(s)? Yes  No
9. Are samples (except VOA and ONG) properly preserved? Yes  No
10. Was preservative added to bottles? Yes  No  NA
11. Is the headspace in the VOA vials less than 1/4 inch or 6 mm? Yes  No  HNO3 pH <2  
No VOA Vials
12. Were any sample containers received broken? Yes  No
13. Does paperwork match bottle labels? Yes  No   
(Note discrepancies on chain of custody)
14. Are matrices correctly identified on Chain of Custody? Yes  No
15. Is it clear what analyses were requested? Yes  No
16. Were all holding times able to be met? Yes  No   
(If no, notify customer for authorization.)

**Special Handling (if applicable)**

17. Was client notified of all discrepancies with this order? Yes  No  NA

Person Notified:	<input type="text"/>	Date:	<input type="text"/>
By Whom:	<input type="text"/>	Via:	<input type="checkbox"/> eMail <input type="checkbox"/> Phone <input type="checkbox"/> Fax <input type="checkbox"/> In Person
Regarding:	<input type="text"/>		
Client Instructions:	<input type="text"/>		

18. Additional remarks:

**Cooler Information**

Cooler No	Temp °C	Condition	Seal Intact	Seal No	Seal Date	Signed By
1	Ambient	Good				NKO



