

Site Radon Inspection Report

Date : 04/22/2019

Bryan Hogan/Ron Havniear
MEDFORD SCHOOL DISTRICT
815 South Oakdale Avenue
Medford, OR 97501-

Client: Kennedy E.S.
Test Location: 2860 North Keeneway Drive
Medford, OR 97504-

Individual Canister Results

Canister ID# : 2679242
Canister Type : Charcoal Canister 3 inch
Location : 1st FL = 33
Radon Level : 8.7 pCi/L
Error for Measurement is: ± 0.7 pCi/L

Test Start : 04/15/2019 @ 05:30
Test Stop : 04/17/2019 @ 05:30
Received: 04/22/2019 @ 10:28
Analyzed: 04/23/2019 @ 14:12

This is a quality control test known as a spike. This canister has never been on the school site.

Canister ID# : 2679244
Canister Type : Charcoal Canister 3 inch
Location : 1st FL = 15 BL
Radon Level : 0.1 pCi/L
Error for Measurement is: ± 0.1 pCi/L

Test Start : 04/15/2019 @ 05:37
Test Stop : 04/17/2019 @ 05:37
Received: 04/22/2019 @ 10:28
Analyzed: 04/23/2019 @ 14:14

Canister ID# : 2679279
Canister Type : Charcoal Canister 3 inch
Location : 1st FL = 15
Radon Level : 0.1 pCi/L
Error for Measurement is: ± 0.4 pCi/L

Test Start : 04/15/2019 @ 05:37
Test Stop : 04/17/2019 @ 05:54
Received: 04/22/2019 @ 10:28
Analyzed: 04/23/2019 @ 17:13

Canister ID# : 2679286
Canister Type : Charcoal Canister 3 inch
Location : 1st FL = 31
Radon Level : 8.9 pCi/L
Error for Measurement is: ± 0.8 pCi/L

Test Start : 04/15/2019 @ 05:30
Test Stop : 04/17/2019 @ 05:30
Received: 04/22/2019 @ 10:28
Analyzed: 04/23/2019 @ 17:13

This is a quality control test known as a spike. This canister has never been on the school site.

Canister ID# : 2680427
Canister Type : Charcoal Canister 3 inch
Location : 1st FL = 32
Radon Level : 9.7 pCi/L
Error for Measurement is: ± 0.8 pCi/L

Test Start : 04/15/2019 @ 05:30
Test Stop : 04/17/2019 @ 05:30
Received: 04/22/2019 @ 10:28
Analyzed: 04/23/2019 @ 14:12

This is a quality control test known as a spike. This canister has never been on the school site.

Canister ID# : 2680644
Canister Type : Charcoal Canister 3 inch
Location : 1st FL = 14
Radon Level : 0.1 pCi/L
Error for Measurement is: ± 0.2 pCi/L

Test Start : 04/15/2019 @ 05:40
Test Stop : 04/17/2019 @ 05:56
Received: 04/22/2019 @ 10:28
Analyzed: 04/23/2019 @ 17:18



Andreas C. George

Andreas C. George
Radon Measurement Specialist
NJ MES 11089

Dante Galan

Dante Galan
Laboratory Director

NRSB ARL0001
NYS ELAP ID: 10806
PADEP ID: 0346
NJDEP ID: NY933
NJ MEB 90036
FL DOH RB1609
IL RNL2000201

Site Radon Inspection Report

Date : 04/22/2019

Bryan Hogan/Ron Havniear
MEDFORD SCHOOL DISTRICT
815 South Oakdale Avenue
Medford, OR 97501-

Client: Kennedy E.S.
Test Location: 2860 North Keeneway Drive
Medford, OR 97504-

Individual Canister Results

Canister ID# : 2704184 Test Start : 04/15/2019 @ 05:32
Canister Type : Charcoal Canister 3 inch Test Stop : 04/17/2019 @ 05:56
Location : 1st FL = 5 DP Received: 04/22/2019 @ 10:28
Radon Level : 0.4 pCi/L Analyzed: 04/23/2019 @ 16:55
Error for Measurement is: ± 0.5 pCi/L

Canister ID# : 2704197 Test Start : 04/15/2019 @ 05:43
Canister Type : Charcoal Canister 3 inch Test Stop : 04/17/2019 @ 06:00
Location : 1st FL = 25 BL Received: 04/22/2019 @ 10:28
Radon Level : 0.1 pCi/L Analyzed: 04/23/2019 @ 17:13
Error for Measurement is: ± 0.6 pCi/L

Canister ID# : 2704198 Test Start : 04/15/2019 @ 05:45
Canister Type : Charcoal Canister 3 inch Test Stop : 04/17/2019 @ 05:57
Location : 1st FL = 13 DP Received: 04/22/2019 @ 10:28
Radon Level : 0.6 pCi/L Analyzed: 04/23/2019 @ 16:55
Error for Measurement is: ± 0.5 pCi/L

Canister ID# : 2704207 Test Start : 04/15/2019 @ 05:25
Canister Type : Charcoal Canister 3 inch Test Stop : 04/17/2019 @ 05:50
Location : 1st FL = 16 Received: 04/22/2019 @ 10:28
Radon Level : 0.1 pCi/L Analyzed: 04/23/2019 @ 13:59
Error for Measurement is: ± 0.2 pCi/L

Canister ID# : 2704208 Test Start : 04/15/2019 @ 05:29
Canister Type : Charcoal Canister 3 inch Test Stop : 04/17/2019 @ 05:52
Location : 1st FL = 19 BL Received: 04/22/2019 @ 10:28
Radon Level : 0.1 pCi/L Analyzed: 04/23/2019 @ 16:55
Error for Measurement is: ± 0.6 pCi/L

Canister ID# : 2704209 Test Start : 04/15/2019 @ 05:23
Canister Type : Charcoal Canister 3 inch Test Stop : 04/17/2019 @ 05:23
Location : 1st FL=Principal's Off. Received: 04/22/2019 @ 10:28
Radon Level : 0.1 pCi/L Analyzed: 04/23/2019 @ 16:39
Error for Measurement is: ± 0.4 pCi/L



Andreas C. George

Andreas C. George
Radon Measurement Specialist
NJ MES 11089

Dante Galan

Dante Galan
Laboratory Director

NRSB ARL0001
NYS ELAP ID: 10806
PADEP ID: 0346
NJDEP ID: NY933
NJ MEB 90036
FL DOH RB1609
IL RNL2000201

Site Radon Inspection Report

Date : 04/22/2019

Bryan Hogan/Ron Havniear
MEDFORD SCHOOL DISTRICT
815 South Oakdale Avenue
Medford, OR 97501-

Client: Kennedy E.S.
Test Location: 2860 North Keeneway Drive
Medford, OR 97504-

Individual Canister Results

Canister ID# : 2704236 Test Start : 04/15/2019 @ 05:50
Canister Type : Charcoal Canister 3 inch Test Stop : 04/17/2019 @ 06:04
Location : 1st FL = 27 Received: 04/22/2019 @ 10:28
Radon Level : 0.1 pCi/L Analyzed: 04/23/2019 @ 14:15
Error for Measurement is: ± 0.4 pCi/L

Canister ID# : 2704237 Test Start : 04/15/2019 @ 05:57
Canister Type : Charcoal Canister 3 inch Test Stop : 04/17/2019 @ 05:57
Location : 1st FL = 8 BL Received: 04/22/2019 @ 10:28
Radon Level : 0.2 pCi/L Analyzed: 04/23/2019 @ 16:38
Error for Measurement is: ± 0.6 pCi/L

Canister ID# : 2704240 Test Start : 04/15/2019 @ 05:24
Canister Type : Charcoal Canister 3 inch Test Stop : 04/17/2019 @ 05:50
Location : 1st FL = 3 Received: 04/22/2019 @ 10:28
Radon Level : 0.2 pCi/L Analyzed: 04/23/2019 @ 16:59
Error for Measurement is: ± 0.5 pCi/L

Canister ID# : 2704242 Test Start : 04/15/2019 @ 05:24
Canister Type : Charcoal Canister 3 inch Test Stop : 04/17/2019 @ 05:53
Location : 1st FL = Cafe DP Received: 04/22/2019 @ 10:28
Radon Level : 0.1 pCi/L Analyzed: 04/23/2019 @ 14:00
Error for Measurement is: ± 0.6 pCi/L

Canister ID# : 2704243 Test Start : 04/15/2019 @ 05:25
Canister Type : Charcoal Canister 3 inch Test Stop : 04/17/2019 @ 05:25
Location : 1st FL=Work Rm Received: 04/22/2019 @ 10:28
Radon Level : 0.1 pCi/L Analyzed: 04/23/2019 @ 14:29
Error for Measurement is: ± 0.5 pCi/L

Canister ID# : 2704244 Test Start : 04/15/2019 @ 05:25
Canister Type : Charcoal Canister 3 inch Test Stop : 04/17/2019 @ 05:25
Location : 1st FL=Work Rm BL Received: 04/22/2019 @ 10:28
Radon Level : 0.1 pCi/L Analyzed: 04/23/2019 @ 16:39
Error for Measurement is: ± 0.2 pCi/L



Andreas C. George

Andreas C. George
Radon Measurement Specialist
NJ MES 11089

Dante Galan

Dante Galan
Laboratory Director

NRSB ARL0001
NYS ELAP ID: 10806
PADEP ID: 0346
NJDEP ID: NY933
NJ MEB 90036
FL DOH RB1609
IL RNL2000201



Site Radon Inspection Report

Date : 04/22/2019

Bryan Hogan/Ron Havniear
MEDFORD SCHOOL DISTRICT
815 South Oakdale Avenue
Medford, OR 97501-

Client: Kennedy E.S.
Test Location: 2860 North Keeneway Drive
Medford, OR 97504-

Individual Canister Results

Canister ID# :	2704498	Test Start :	04/15/2019 @ 05:42
Canister Type :	Charcoal Canister 3 inch	Test Stop :	04/17/2019 @ 06:00
Location :	1st FL = 25	Received:	04/22/2019 @ 10:28
Radon Level :	0.1 pCi/L	Analyzed:	04/23/2019 @ 14:15
Error for Measurement is: ±	0.3 pCi/L		

Canister ID# :	2704500	Test Start :	04/15/2019 @ 05:27
Canister Type :	Charcoal Canister 3 inch	Test Stop :	04/17/2019 @ 05:55
Location :	1st FL = Gym 1	Received:	04/22/2019 @ 10:28
Radon Level :	0.1 pCi/L	Analyzed:	04/23/2019 @ 14:00
Error for Measurement is: ±	0.2 pCi/L		

Canister ID# :	2704502	Test Start :	04/15/2019 @ 05:59
Canister Type :	Charcoal Canister 3 inch	Test Stop :	04/17/2019 @ 06:10
Location :	1st FL=Cust. Off.	Received:	04/22/2019 @ 10:28
Radon Level :	0.1 pCi/L	Analyzed:	04/23/2019 @ 13:59
Error for Measurement is: ±	0.2 pCi/L		

Canister ID# :	2704503	Test Start :	04/15/2019 @ 05:24
Canister Type :	Charcoal Canister 3 inch	Test Stop :	04/17/2019 @ 05:53
Location :	1st FL = Cafe 2	Received:	04/22/2019 @ 10:28
Radon Level :	0.1 pCi/L	Analyzed:	04/23/2019 @ 16:55
Error for Measurement is: ±	0.7 pCi/L		

Canister ID# :	2704504	Test Start :	04/15/2019 @ 05:32
Canister Type :	Charcoal Canister 3 inch	Test Stop :	04/17/2019 @ 05:56
Location :	1st FL = 5	Received:	04/22/2019 @ 10:28
Radon Level :	0.4 pCi/L	Analyzed:	04/23/2019 @ 14:29
Error for Measurement is: ±	0.6 pCi/L		

Canister ID# :	2704506	Test Start :	04/15/2019 @ 05:38
Canister Type :	Charcoal Canister 3 inch	Test Stop :	04/17/2019 @ 05:59
Location :	1st FL = Stage	Received:	04/22/2019 @ 10:28
Radon Level :	0.2 pCi/L	Analyzed:	04/23/2019 @ 14:12
Error for Measurement is: ±	0.5 pCi/L		



Andreas C. George

Andreas C. George
Radon Measurement Specialist
NJ MES 11089

Dante Galan

Dante Galan
Laboratory Director

NRSB ARL0001
NYS ELAP ID: 10806
PADEP ID: 0346
NJDEP ID: NY933
NJ MEB 90036
FL DOH RB1609
IL RNL2000201

Site Radon Inspection Report

Date : 04/22/2019

Bryan Hogan/Ron Havniear
MEDFORD SCHOOL DISTRICT
815 South Oakdale Avenue
Medford, OR 97501-

Client: Kennedy E.S.
Test Location: 2860 North Keeneway Drive
Medford, OR 97504-

Individual Canister Results

Canister ID# : 2704509 Test Start : 04/15/2019 @ 05:47
Canister Type : Charcoal Canister 3 inch Test Stop : 04/17/2019 @ 06:02
Location : 1st FL = 26 Received: 04/22/2019 @ 10:28
Radon Level : 0.1 pCi/L Analyzed: 04/23/2019 @ 16:39
Error for Measurement is: ± 0.5 pCi/L

Canister ID# : 2704510 Test Start : 04/15/2019 @ 05:33
Canister Type : Charcoal Canister 3 inch Test Stop : 04/17/2019 @ 05:33
Location : 1st FL = 29 BL Received: 04/22/2019 @ 10:28
Radon Level : 0.4 pCi/L Analyzed: 04/23/2019 @ 17:22
Error for Measurement is: ± 0.5 pCi/L

Canister ID# : 2704515 Test Start : 04/15/2019 @ 05:49
Canister Type : Charcoal Canister 3 inch Test Stop : 04/17/2019 @ 05:55
Location : 1st FL = 10 Received: 04/22/2019 @ 10:28
Radon Level : 0.2 pCi/L Analyzed: 04/23/2019 @ 16:39
Error for Measurement is: ± 0.6 pCi/L

Canister ID# : 2704516 Test Start : 04/15/2019 @ 05:41
Canister Type : Charcoal Canister 3 inch Test Stop : 04/17/2019 @ 06:03
Location : 1st FL = 21 Received: 04/22/2019 @ 10:28
Radon Level : 0.1 pCi/L Analyzed: 04/23/2019 @ 13:56
Error for Measurement is: ± 0.9 pCi/L

Canister ID# : 2704521 Test Start : 04/15/2019 @ 05:32
Canister Type : Charcoal Canister 3 inch Test Stop : 04/17/2019 @ 05:49
Location : 1st FL = 29 Received: 04/22/2019 @ 10:28
Radon Level : 0.1 pCi/L Analyzed: 04/23/2019 @ 17:13
Error for Measurement is: ± 0.6 pCi/L

Canister ID# : 2704523 Test Start : 04/15/2019 @ 05:29
Canister Type : Charcoal Canister 3 inch Test Stop : 04/17/2019 @ 05:52
Location : 1st FL = 19 Received: 04/22/2019 @ 10:28
Radon Level : 0.1 pCi/L Analyzed: 04/23/2019 @ 14:15
Error for Measurement is: ± 0.8 pCi/L



Andreas C. George

Andreas C. George
Radon Measurement Specialist
NJ MES 11089

Dante Galan

Dante Galan
Laboratory Director

NRSB ARL0001
NYS ELAP ID: 10806
PADEP ID: 0346
NJDEP ID: NY933
NJ MEB 90036
FL DOH RB1609
IL RNL2000201



Site Radon Inspection Report

Date : 04/22/2019

Bryan Hogan/Ron Havniear
MEDFORD SCHOOL DISTRICT
815 South Oakdale Avenue
Medford, OR 97501-

Client: Kennedy E.S.
Test Location: 2860 North Keeneway Drive
Medford, OR 97504-

Individual Canister Results

Canister ID# : 2704525 Test Start : 04/15/2019 @ 05:55
Canister Type : Charcoal Canister 3 inch Test Stop : 04/17/2019 @ 06:02
Location : 1st FL = 9 Received: 04/22/2019 @ 10:28
Radon Level : 0.1 pCi/L Analyzed: 04/23/2019 @ 16:39
Error for Measurement is: ± 0.6 pCi/L

Canister ID# : 2704527 Test Start : 04/15/2019 @ 05:35
Canister Type : Charcoal Canister 3 inch Test Stop : 04/17/2019 @ 06:00
Location : 1st FL = 20 Received: 04/22/2019 @ 10:28
Radon Level : 0.2 pCi/L Analyzed: 04/23/2019 @ 14:15
Error for Measurement is: ± 0.4 pCi/L

Canister ID# : 2704531 Test Start : 04/15/2019 @ 05:38
Canister Type : Charcoal Canister 3 inch Test Stop : 04/17/2019 @ 06:07
Location : 1st FL = 23 DP Received: 04/22/2019 @ 10:28
Radon Level : 0.1 pCi/L Analyzed: 04/23/2019 @ 16:59
Error for Measurement is: ± 0.4 pCi/L

Canister ID# : 2707249 Test Start : 04/15/2019 @ 05:57
Canister Type : Charcoal Canister 3 inch Test Stop : 04/17/2019 @ 06:00
Location : 1st FL = 8 Received: 04/22/2019 @ 10:28
Radon Level : 0.1 pCi/L Analyzed: 04/23/2019 @ 17:18
Error for Measurement is: ± 0.9 pCi/L

Canister ID# : 2707250 Test Start : 04/15/2019 @ 05:35
Canister Type : Charcoal Canister 3 inch Test Stop : 04/17/2019 @ 06:00
Location : 1st FL = 6 Received: 04/22/2019 @ 10:28
Radon Level : 0.1 pCi/L Analyzed: 04/23/2019 @ 14:00
Error for Measurement is: ± 0.2 pCi/L

Canister ID# : 2707267 Test Start : 04/15/2019 @ 05:27
Canister Type : Charcoal Canister 3 inch Test Stop : 04/17/2019 @ 05:56
Location : 1st FL=Rm in Cafe NW Received: 04/22/2019 @ 10:28
Radon Level : 0.3 pCi/L Analyzed: 04/23/2019 @ 16:38
Error for Measurement is: ± 0.5 pCi/L



Andreas C. George

Andreas C. George
Radon Measurement Specialist
NJ MES 11089

Dante Galan

Dante Galan
Laboratory Director

NRSB ARL0001
NYS ELAP ID: 10806
PADEP ID: 0346
NJDEP ID: NY933
NJ MEB 90036
FL DOH RB1609
IL RNL2000201



Site Radon Inspection Report

Date : 04/22/2019

Bryan Hogan/Ron Havniear
MEDFORD SCHOOL DISTRICT
815 South Oakdale Avenue
Medford, OR 97501-

Client: Kennedy E.S.
Test Location: 2860 North Keeneway Drive
Medford, OR 97504-

Individual Canister Results

Canister ID# :	2707274	Test Start :	04/15/2019 @ 05:57
Canister Type :	Charcoal Canister 3 inch	Test Stop :	04/17/2019 @ 06:08
Location :	1st FL=Lactation Rm	Received:	04/22/2019 @ 10:28
Radon Level :	0.2 pCi/L	Analyzed:	04/23/2019 @ 13:56
Error for Measurement is: ±	0.4 pCi/L		

Canister ID# :	2707276	Test Start :	04/15/2019 @ 05:45
Canister Type :	Charcoal Canister 3 inch	Test Stop :	04/17/2019 @ 05:57
Location :	1st FL = 13	Received:	04/22/2019 @ 10:28
Radon Level :	0.1 pCi/L	Analyzed:	04/23/2019 @ 14:12
Error for Measurement is: ±	0.2 pCi/L		

Canister ID# :	2707281	Test Start :	04/15/2019 @ 05:28
Canister Type :	Charcoal Canister 3 inch	Test Stop :	04/17/2019 @ 05:28
Location :	1st FL=Staff Break Rm	Received:	04/22/2019 @ 10:28
Radon Level :	0.2 pCi/L	Analyzed:	04/23/2019 @ 16:55
Error for Measurement is: ±	0.5 pCi/L		

Canister ID# :	2707285	Test Start :	04/15/2019 @ 05:12
Canister Type :	Charcoal Canister 3 inch	Test Stop :	04/17/2019 @ 05:12
Location :	1st FL=Main Off.	Received:	04/22/2019 @ 10:28
Radon Level :	0.1 pCi/L	Analyzed:	04/23/2019 @ 14:29
Error for Measurement is: ±	0.1 pCi/L		

Canister ID# :	2707287	Test Start :	04/15/2019 @ 05:38
Canister Type :	Charcoal Canister 3 inch	Test Stop :	04/17/2019 @ 06:07
Location :	1st FL = 23	Received:	04/22/2019 @ 10:28
Radon Level :	0.1 pCi/L	Analyzed:	04/23/2019 @ 17:18
Error for Measurement is: ±	0.3 pCi/L		

Canister ID# :	2707294	Test Start :	04/15/2019 @ 05:47
Canister Type :	Charcoal Canister 3 inch	Test Stop :	04/17/2019 @ 05:47
Location :	1st FL=Rm S of Music Rm BL	Received:	04/22/2019 @ 10:28
Radon Level :	0.1 pCi/L	Analyzed:	04/23/2019 @ 14:14
Error for Measurement is: ±	0.2 pCi/L		



Andreas C. George

Andreas C. George
Radon Measurement Specialist
NJ MES 11089

Dante Galan

Dante Galan
Laboratory Director

NRSB ARL0001
NYS ELAP ID: 10806
PADEP ID: 0346
NJDEP ID: NY933
NJ MEB 90036
FL DOH RB1609
IL RNL2000201

Site Radon Inspection Report

Date : 04/22/2019

Bryan Hogan/Ron Havniear
 MEDFORD SCHOOL DISTRICT
 815 South Oakdale Avenue
 Medford, OR 97501-

Client: Kennedy E.S.

Test Location: 2860 North Keeneway Drive
 Medford, OR 97504-

Individual Canister Results

Canister ID# : 2707297 Test Start : 04/15/2019 @ 05:47
 Canister Type : Charcoal Canister 3 inch Test Stop : 04/17/2019 @ 06:05
 Location : 1st FL=Media Ctr. 2 Received: 04/22/2019 @ 10:28
 Radon Level : 0.2 pCi/L Analyzed: 04/23/2019 @ 14:14
 Error for Measurement is: \pm 0.7 pCi/L


Canister ID# : 2707298 Test Start : 04/15/2019 @ 05:21
 Canister Type : Charcoal Canister 3 inch Test Stop : 04/17/2019 @ 05:21
 Location : 1st FL=Conf. Rm Received: 04/22/2019 @ 10:28
 Radon Level : 0.1 pCi/L Analyzed: 04/23/2019 @ 14:29
 Error for Measurement is: \pm 0.2 pCi/L

Canister ID# : 2707299 Test Start : 04/15/2019 @ 05:27
 Canister Type : Charcoal Canister 3 inch Test Stop : 04/17/2019 @ 05:45
 Location : 1st FL = 28 Received: 04/22/2019 @ 10:28
 Radon Level : 0.1 pCi/L Analyzed: 04/23/2019 @ 14:15
 Error for Measurement is: \pm 0.4 pCi/L

Canister ID# : 2707300 Test Start : 04/15/2019 @ 05:22
 Canister Type : Charcoal Canister 3 inch Test Stop : 04/17/2019 @ 05:51
 Location : 1st FL = Cafe 1 Received: 04/22/2019 @ 10:28
 Radon Level : 0.2 pCi/L Analyzed: 04/23/2019 @ 16:59
 Error for Measurement is: \pm 0.5 pCi/L

Canister ID# : 2707301 Test Start : 04/15/2019 @ 05:30
 Canister Type : Charcoal Canister 3 inch Test Stop : 04/17/2019 @ 05:30
 Location : 1st FL=Amgs Closet Received: 04/22/2019 @ 10:28
 Radon Level : 0.1 pCi/L Analyzed: 04/23/2019 @ 14:15
 Error for Measurement is: \pm 0.3 pCi/L

Canister ID# : 2707302 Test Start : 04/15/2019 @ 05:47
 Canister Type : Charcoal Canister 3 inch Test Stop : 04/17/2019 @ 06:05
 Location : 1st FL=Media Ctr. DP Received: 04/22/2019 @ 10:28
 Radon Level : 0.2 pCi/L Analyzed: 04/23/2019 @ 17:18
 Error for Measurement is: \pm 0.4 pCi/L

Andreas C. George
 Radon Measurement Specialist
 NJ MES 11089



Dante Galan
 Laboratory Director

NRSB ARL0001
 NYS ELAP ID: 10806
 PADEP ID: 0346
 NJDEP ID: NY933
 NJ MEB 90036
 FL DOH RB1609
 IL RNL2000201



Site Radon Inspection Report

Date : 04/22/2019

Bryan Hogan/Ron Havniear
MEDFORD SCHOOL DISTRICT
815 South Oakdale Avenue
Medford, OR 97501-

Client: Kennedy E.S.
Test Location: 2860 North Keeneway Drive
Medford, OR 97504-

Individual Canister Results

Canister ID# :	2707304	Test Start :	04/15/2019 @ 05:49
Canister Type :	Charcoal Canister 3 inch	Test Stop :	04/17/2019 @ 05:56
Location :	1st FL = 10 DP	Received:	04/22/2019 @ 10:28
Radon Level :	0.2 pCi/L	Analyzed:	04/23/2019 @ 16:58
Error for Measurement is: ±	0.4 pCi/L		

Canister ID# :	2707313	Test Start :	04/15/2019 @ 05:54
Canister Type :	Charcoal Canister 3 inch	Test Stop :	04/17/2019 @ 06:07
Location :	1st FL=Comp. Rm BL	Received:	04/22/2019 @ 10:28
Radon Level :	0.1 pCi/L	Analyzed:	04/23/2019 @ 14:14
Error for Measurement is: ±	0.2 pCi/L		

Canister ID# :	2707315	Test Start :	04/15/2019 @ 05:15
Canister Type :	Charcoal Canister 3 inch	Test Stop :	04/17/2019 @ 05:15
Location :	1st FL=Health Rm	Received:	04/22/2019 @ 10:28
Radon Level :	0.1 pCi/L	Analyzed:	04/23/2019 @ 16:55
Error for Measurement is: ±	0.5 pCi/L		

Canister ID# :	2707316	Test Start :	04/15/2019 @ 05:29
Canister Type :	Charcoal Canister 3 inch	Test Stop :	04/17/2019 @ 05:53
Location :	1st FL = 4	Received:	04/22/2019 @ 10:28
Radon Level :	0.1 pCi/L	Analyzed:	04/23/2019 @ 17:22
Error for Measurement is: ±	0.4 pCi/L		

Canister ID# :	2707318	Test Start :	04/15/2019 @ 05:38
Canister Type :	Charcoal Canister 3 inch	Test Stop :	04/17/2019 @ 05:56
Location :	1st FL = 17 DP	Received:	04/22/2019 @ 10:28
Radon Level :	0.2 pCi/L	Analyzed:	04/23/2019 @ 16:55
Error for Measurement is: ±	0.5 pCi/L		

Canister ID# :	2707319	Test Start :	04/15/2019 @ 05:37
Canister Type :	Charcoal Canister 3 inch	Test Stop :	04/17/2019 @ 05:55
Location :	1st FL = 17	Received:	04/22/2019 @ 10:28
Radon Level :	0.1 pCi/L	Analyzed:	04/23/2019 @ 14:11
Error for Measurement is: ±	0.2 pCi/L		



Andreas C. George

Andreas C. George
Radon Measurement Specialist
NJ MES 11089

Dante Galan

Dante Galan
Laboratory Director

NRSB ARL0001
NYS ELAP ID: 10806
PADEP ID: 0346
NJDEP ID: NY933
NJ MEB 90036
FL DOH RB1609
IL RNL2000201

Site Radon Inspection Report

Date : 04/22/2019

Bryan Hogan/Ron Havniear
MEDFORD SCHOOL DISTRICT
815 South Oakdale Avenue
Medford, OR 97501-

Client: Kennedy E.S.
Test Location: 2860 North Keeneway Drive
Medford, OR 97504-

Individual Canister Results

The results indicate that at least one testing device registered at or above the United States Environmental Protection Agency (EPA) action level of 4.0 picoCuries per liter of air (pCi/L). The EPA recommends mitigation if the average of two short-term tests taken in the lowest level of the building suitable for occupancy show radon levels that are equal to or greater than 4.0 pCi/L.

For information on how to reduce radon levels in your home, please review the EPA booklet: Consumer's Guide to Radon Reduction (www.epa.gov/radon/pdfs/consguid.pdf) and contact your state health department. The EPA maintains a radon information website, including copies of its publications, at www.epa.gov/iaq/radon.

For New Jersey clients: Please see the attached guidance document entitled Radon Testing and Mitigation: The Basics for further information.

For New York clients: If the radon level of one or more testing devices is equal to or exceeds 20 pCi/L please contact the New York State Department of Health, Bureau of Environmental Radiation Protection, for technical advice and assistance at 518-402-7556 or toll free 1-800-458-1158.

PLEDGE OF ASSURED QUALITY

All procedures used for generating this report are in complete accordance with the current EPA protocols for the analysis of radon in air (EPA 402-R-92-004). The analytical results relate only to the samples tested, in the condition received by the lab, and that calculations were based upon the information supplied by client. RTCA and its personnel do not assume responsibility or liability, collectively and individually, for analysis results when detectors have been improperly handled or placed by the consumer, nor does RTCA and its personnel accept responsibility for any financial or health consequences of subsequent action or lack of action, taken by the customer or its consultants based on RTCA-provided results.



Andreas C. George

Andreas C. George
Radon Measurement Specialist
NJ MES 11089

Dante Galan

Dante Galan
Laboratory Director

NRSB ARL0001
NYS ELAP ID: 10806
PADEP ID: 0346
NJDEP ID: NY933
NJ MEB 90036
FL DOH RB1609
IL RNL2000201