

Site Radon Inspection Report

Date : 04/29/2019

Bryan Hogan / Ron Havnear
MEDFORD SCHOOL DISTRICT
815 South Oakdale Avenue
Medford, OR 97501-

Client: Lone Pine E.S.
Test Location: 3158 Lone Pine Road
Medford, OR 97504-
Individual Canister Results

Canister ID# : 2679157 Test Start : 04/22/2019 @ 05:52
Canister Type : Charcoal Canister 3 inch Test Stop : 04/24/2019 @ 05:59
Location : 1st FL = Rm 12 Received: 04/29/2019 @ 10:13
Radon Level : 0.4 pCi/L Analyzed: 04/30/2019 @ 15:03
Error for Measurement is: ± 0.7 pCi/L

Canister ID# : 2679168 Test Start : 04/22/2019 @ 05:27
Canister Type : Charcoal Canister 3 inch Test Stop : 04/24/2019 @ 05:48
Location : 1st FL = Rm 26 DP Received: 04/29/2019 @ 10:13
Radon Level : 0.1 pCi/L Analyzed: 04/30/2019 @ 16:38
Error for Measurement is: ± 0.7 pCi/L

Canister ID# : 2679224 Test Start : 04/22/2019 @ 05:33
Canister Type : Charcoal Canister 3 inch Test Stop : 04/24/2019 @ 05:33
Location : 1st FL = Rm 17 BL Received: 04/29/2019 @ 10:13
Radon Level : 0.3 pCi/L Analyzed: 05/01/2019 @ 11:31
Error for Measurement is: ± 0.6 pCi/L

Canister ID# : 2679249 Test Start : 04/22/2019 @ 06:00
Canister Type : Charcoal Canister 3 inch Test Stop : 04/24/2019 @ 06:03
Location : 1st FL = Rm 31 Received: 04/29/2019 @ 10:13
Radon Level : 11.7 pCi/L Analyzed: 04/30/2019 @ 15:48
Error for Measurement is: ± 0.8 pCi/L

This is a quality control test known as a spike. This canister has never been on the school site.

Canister ID# : 2679258 Test Start : 04/22/2019 @ 05:36
Canister Type : Charcoal Canister 3 inch Test Stop : 04/24/2019 @ 05:50
Location : 1st FL = Rm 16 Received: 04/29/2019 @ 10:13
Radon Level : 0.4 pCi/L Analyzed: 04/30/2019 @ 17:29
Error for Measurement is: ± 0.7 pCi/L

Canister ID# : 2680662 Test Start : 04/22/2019 @ 06:00
Canister Type : Charcoal Canister 3 inch Test Stop : 04/24/2019 @ 06:03
Location : 1st FL = Rm 10 Received: 04/29/2019 @ 10:13
Radon Level : 0.5 pCi/L Analyzed: 04/30/2019 @ 15:48
Error for Measurement is: ± 0.6 pCi/L



Andreas C. George

Andreas C. George
Radon Measurement Specialist
NJ MES 11089

Dante Galan

Dante Galan
Laboratory Director

NRSB ARL0001
NYS ELAP ID: 10806
PADEP ID: 0346
NJDEP ID: NY933
NJ MEB 90036
FL DOH RB1609
IL RNL2000201



Site Radon Inspection Report

Date : 04/29/2019

Bryan Hogan / Ron Havnear
MEDFORD SCHOOL DISTRICT
815 South Oakdale Avenue
Medford, OR 97501-

Client: Lone Pine E.S.
Test Location: 3158 Lone Pine Road
Medford, OR 97504-
Individual Canister Results

Canister ID# : 2680675
Canister Type : Charcoal Canister 3 inch
Location : 1st FL = Rm 17
Radon Level : 0.1 pCi/L
Error for Measurement is: ± 0.5 pCi/L

Test Start : 04/22/2019 @ 05:32
Test Stop : 04/24/2019 @ 05:48
Received: 04/29/2019 @ 10:13
Analyzed: 04/30/2019 @ 16:34

Canister ID# : 2680690
Canister Type : Charcoal Canister 3 inch
Location : 1st FL=Health Rm
Radon Level : 0.9 pCi/L
Error for Measurement is: ± 0.5 pCi/L

Test Start : 04/22/2019 @ 05:29
Test Stop : 04/24/2019 @ 05:29
Received: 04/29/2019 @ 10:13
Analyzed: 04/30/2019 @ 17:14

Canister ID# : 2680917
Canister Type : Charcoal Canister 3 inch
Location : 1st FL=Main Off. BL
Radon Level : 0.2 pCi/L
Error for Measurement is: ± 0.5 pCi/L

Test Start : 04/22/2019 @ 05:14
Test Stop : 04/24/2019 @ 05:14
Received: 04/29/2019 @ 10:13
Analyzed: 04/30/2019 @ 17:28

Canister ID# : 2681510
Canister Type : Charcoal Canister 3 inch
Location : 1st FI = Rm 30
Radon Level : 12.6 pCi/L
Error for Measurement is: ± 0.9 pCi/L

Test Start : 04/22/2019 @ 06:00
Test Stop : 04/24/2019 @ 06:03
Received: 04/29/2019 @ 10:13
Analyzed: 04/30/2019 @ 16:04

This is a quality control test known as a spike. This canister has never been on the school site.

Canister ID# : 2704118
Canister Type : Charcoal Canister 3 inch
Location : 1st FL = Rm 13
Radon Level : 0.2 pCi/L
Error for Measurement is: ± 0.6 pCi/L

Test Start : 04/22/2019 @ 05:49
Test Stop : 04/24/2019 @ 05:56
Received: 04/29/2019 @ 10:13
Analyzed: 04/30/2019 @ 17:14

Canister ID# : 2704129
Canister Type : Charcoal Canister 3 inch
Location : 1st FL=Main Off. B
Radon Level : 0.2 pCi/L
Error for Measurement is: ± 0.4 pCi/L

Test Start : 04/22/2019 @ 05:35
Test Stop : 04/24/2019 @ 05:41
Received: 04/29/2019 @ 10:13
Analyzed: 04/30/2019 @ 16:34



Andreas C. George

Andreas C. George
Radon Measurement Specialist
NJ MES 11089

Dante Galan

Dante Galan
Laboratory Director

NRSB ARL0001
NYS ELAP ID: 10806
PADEP ID: 0346
NJDEP ID: NY933
NJ MEB 90036
FL DOH RB1609
IL RNL2000201



Site Radon Inspection Report

Date : 04/29/2019

Bryan Hogan / Ron Havnear
MEDFORD SCHOOL DISTRICT
815 South Oakdale Avenue
Medford, OR 97501-

Client: Lone Pine E.S.
Test Location: 3158 Lone Pine Road
Medford, OR 97504-

Individual Canister Results

Canister ID# :	2704131	Test Start :	04/22/2019 @ 05:31
Canister Type :	Charcoal Canister 3 inch	Test Stop :	04/24/2019 @ 05:39
Location :	1st FL=Comp. Rm DP	Received:	04/29/2019 @ 10:13
Radon Level :	0.4 pCi/L	Analyzed:	04/30/2019 @ 17:11
Error for Measurement is: ±	0.6 pCi/L		

Canister ID# :	2704133	Test Start :	04/22/2019 @ 05:44
Canister Type :	Charcoal Canister 3 inch	Test Stop :	04/24/2019 @ 06:08
Location :	1st FL=Gym 1	Received:	04/29/2019 @ 10:13
Radon Level :	0.1 pCi/L	Analyzed:	04/30/2019 @ 16:55
Error for Measurement is: ±	0.7 pCi/L		

Canister ID# :	2704144	Test Start :	04/22/2019 @ 05:54
Canister Type :	Charcoal Canister 3 inch	Test Stop :	04/24/2019 @ 05:55
Location :	1st FL=Media Ctr Conf	Received:	04/29/2019 @ 10:13
Radon Level :	0.2 pCi/L	Analyzed:	05/01/2019 @ 11:31
Error for Measurement is: ±	0.6 pCi/L		

Canister ID# :	2704176	Test Start :	04/22/2019 @ 05:32
Canister Type :	Charcoal Canister 3 inch	Test Stop :	04/24/2019 @ 05:52
Location :	1st FL = Rm 25 BL	Received:	04/29/2019 @ 10:13
Radon Level :	0.1 pCi/L	Analyzed:	04/30/2019 @ 16:07
Error for Measurement is: ±	0.3 pCi/L		

Canister ID# :	2704177	Test Start :	04/22/2019 @ 05:37
Canister Type :	Charcoal Canister 3 inch	Test Stop :	04/24/2019 @ 06:03
Location :	1st FL=Cafe 1	Received:	04/29/2019 @ 10:13
Radon Level :	0.2 pCi/L	Analyzed:	04/30/2019 @ 17:15
Error for Measurement is: ±	0.4 pCi/L		

Canister ID# :	2704179	Test Start :	04/22/2019 @ 05:46
Canister Type :	Charcoal Canister 3 inch	Test Stop :	04/24/2019 @ 06:10
Location :	1st FL=Gym 2	Received:	04/29/2019 @ 10:13
Radon Level :	0.1 pCi/L	Analyzed:	04/30/2019 @ 17:29
Error for Measurement is: ±	0.5 pCi/L		



Andreas C. George

Andreas C. George
Radon Measurement Specialist
NJ MES 11089

Dante Galan

Dante Galan
Laboratory Director

NRSB ARL0001
NYS ELAP ID: 10806
PADEP ID: 0346
NJDEP ID: NY933
NJ MEB 90036
FL DOH RB1609
IL RNL2000201

Site Radon Inspection Report

Date : 04/29/2019

Bryan Hogan / Ron Havnear
MEDFORD SCHOOL DISTRICT
815 South Oakdale Avenue
Medford, OR 97501-

Client: Lone Pine E.S.
Test Location: 3158 Lone Pine Road
Medford, OR 97504-
Individual Canister Results

Canister ID# : 2704180 Test Start : 04/22/2019 @ 05:14
Canister Type : Charcoal Canister 3 inch Test Stop : 04/24/2019 @ 05:14
Location : 1st FL=Main Office Received: 04/29/2019 @ 10:13
Radon Level : 0.1 pCi/L Analyzed: 04/30/2019 @ 15:48
Error for Measurement is: ± No Result

Canister ID# : 2704183 Test Start : 04/22/2019 @ 05:31
Canister Type : Charcoal Canister 3 inch Test Stop : 04/24/2019 @ 05:31
Location : 1st FL=Work Rm Received: 04/29/2019 @ 10:13
Radon Level : 0.1 pCi/L Analyzed: 04/30/2019 @ 17:28
Error for Measurement is: ± 0.5 pCi/L

Canister ID# : 2704187 Test Start : 04/22/2019 @ 05:43
Canister Type : Charcoal Canister 3 inch Test Stop : 04/24/2019 @ 05:46
Location : 1st FL=Media Ctr 1 Received: 04/29/2019 @ 10:13
Radon Level : 0.5 pCi/L Analyzed: 04/30/2019 @ 16:18
Error for Measurement is: ± 0.5 pCi/L

Canister ID# : 2704188 Test Start : 04/22/2019 @ 05:45
Canister Type : Charcoal Canister 3 inch Test Stop : 04/24/2019 @ 06:09
Location : 1st FL = Rm 18 Received: 04/29/2019 @ 10:13
Radon Level : 0.1 pCi/L Analyzed: 04/30/2019 @ 17:29
Error for Measurement is: ± 0.3 pCi/L

Canister ID# : 2704192 Test Start : 04/22/2019 @ 05:43
Canister Type : Charcoal Canister 3 inch Test Stop : 04/24/2019 @ 06:00
Location : 1st FL = Rm 23 DP Received: 04/29/2019 @ 10:13
Radon Level : 0.1 pCi/L Analyzed: 04/30/2019 @ 17:14
Error for Measurement is: ± 0.5 pCi/L

Canister ID# : 2704196 Test Start : 04/22/2019 @ 05:50
Canister Type : Charcoal Canister 3 inch Test Stop : 04/24/2019 @ 06:12
Location : 1st FL=Music Rm Received: 04/29/2019 @ 10:13
Radon Level : 0.9 pCi/L Analyzed: 04/30/2019 @ 17:11
Error for Measurement is: ± 0.6 pCi/L



Andreas C. George

Andreas C. George
Radon Measurement Specialist
NJ MES 11089

Dante Galan

Dante Galan
Laboratory Director

NRSB ARL0001
NYS ELAP ID: 10806
PADEP ID: 0346
NJDEP ID: NY933
NJ MEB 90036
FL DOH RB1609
IL RNL2000201

Site Radon Inspection Report

Date : 04/29/2019

Bryan Hogan / Ron Havnear
MEDFORD SCHOOL DISTRICT
815 South Oakdale Avenue
Medford, OR 97501-

Client: Lone Pine E.S.
Test Location: 3158 Lone Pine Road
Medford, OR 97504-

Individual Canister Results

Canister ID# : 2704199 Test Start : 04/22/2019 @ 05:17
Canister Type : Charcoal Canister 3 inch Test Stop : 04/24/2019 @ 05:17
Location : 1st FL=Principal's Off. Received: 04/29/2019 @ 10:13
Radon Level : 0.6 pCi/L Analyzed: 04/30/2019 @ 15:20
Error for Measurement is: ± 0.5 pCi/L

Canister ID# : 2704200 Test Start : 04/22/2019 @ 05:31
Canister Type : Charcoal Canister 3 inch Test Stop : 04/24/2019 @ 05:39
Location : 1st FL=Comp. Rm Received: 04/29/2019 @ 10:13
Radon Level : 0.5 pCi/L Analyzed: 04/30/2019 @ 16:21
Error for Measurement is: ± 0.7 pCi/L

Canister ID# : 2704201 Test Start : 04/22/2019 @ 05:33
Canister Type : Charcoal Canister 3 inch Test Stop : 04/24/2019 @ 06:01
Location : 1st FL=Staff Break Rm Received: 04/29/2019 @ 10:13
Radon Level : 1.6 pCi/L Analyzed: 04/30/2019 @ 16:55
Error for Measurement is: ± 0.6 pCi/L

Canister ID# : 2704203 Test Start : 04/22/2019 @ 05:50
Canister Type : Charcoal Canister 3 inch Test Stop : 04/24/2019 @ 05:57
Location : 1st FL = Rm 13 DP Received: 04/29/2019 @ 10:13
Radon Level : 0.1 pCi/L Analyzed: 04/30/2019 @ 15:51
Error for Measurement is: ± 0.4 pCi/L

Canister ID# : 2704213 Test Start : 04/22/2019 @ 05:43
Canister Type : Charcoal Canister 3 inch Test Stop : 04/24/2019 @ 05:50
Location : 1st FL=Rm 6 Received: 04/29/2019 @ 10:13
Radon Level : 0.3 pCi/L Analyzed: 04/30/2019 @ 16:58
Error for Measurement is: ± 0.5 pCi/L

Canister ID# : 2704220 Test Start : 04/22/2019 @ 05:45
Canister Type : Charcoal Canister 3 inch Test Stop : 04/24/2019 @ 05:45
Location : 1st FL = Rm 18 BL Received: 04/29/2019 @ 10:13
Radon Level : 0.1 pCi/L Analyzed: 04/30/2019 @ 15:51
Error for Measurement is: ± 0.2 pCi/L



Andreas C. George

Andreas C. George
Radon Measurement Specialist
NJ MES 11089

Dante Galan

Dante Galan
Laboratory Director

NRSB ARL0001
NYS ELAP ID: 10806
PADEP ID: 0346
NJDEP ID: NY933
NJ MEB 90036
FL DOH RB1609
IL RNL2000201

Site Radon Inspection Report

Date : 04/29/2019

Bryan Hogan / Ron Havnear
MEDFORD SCHOOL DISTRICT
815 South Oakdale Avenue
Medford, OR 97501-

Client: Lone Pine E.S.
Test Location: 3158 Lone Pine Road
Medford, OR 97504-
Individual Canister Results

Canister ID# : 2704251 Test Start : 04/22/2019 @ 05:40
Canister Type : Charcoal Canister 3 inch Test Stop : 04/24/2019 @ 06:04
Location : 1st FL=Cafe 2 Received: 04/29/2019 @ 10:13
Radon Level : 0.1 pCi/L Analyzed: 04/30/2019 @ 16:18
Error for Measurement is: ± 0.8 pCi/L

Canister ID# : 2704255 Test Start : 04/22/2019 @ 05:37
Canister Type : Charcoal Canister 3 inch Test Stop : 04/24/2019 @ 05:43
Location : 1st FL=Main Off. C Received: 04/29/2019 @ 10:13
Radon Level : 0.4 pCi/L Analyzed: 05/01/2019 @ 11:31
Error for Measurement is: ± 0.6 pCi/L

Canister ID# : 2704258 Test Start : 04/22/2019 @ 05:48
Canister Type : Charcoal Canister 3 inch Test Stop : 04/24/2019 @ 05:50
Location : 1st FL=Media Comp Rm Received: 04/29/2019 @ 10:13
Radon Level : 0.1 pCi/L Analyzed: 04/30/2019 @ 15:32
Error for Measurement is: ± 0.3 pCi/L

Canister ID# : 2704260 Test Start : 04/22/2019 @ 05:39
Canister Type : Charcoal Canister 3 inch Test Stop : 04/24/2019 @ 05:45
Location : 1st FL=Rm 1 DP Received: 04/29/2019 @ 10:13
Radon Level : 0.1 pCi/L Analyzed: 04/30/2019 @ 15:36
Error for Measurement is: ± 0.3 pCi/L

Canister ID# : 2704479 Test Start : 04/22/2019 @ 05:41
Canister Type : Charcoal Canister 3 inch Test Stop : 04/24/2019 @ 05:52
Location : 1st FL = Rm 15 Received: 04/29/2019 @ 10:13
Radon Level : 0.2 pCi/L Analyzed: 04/30/2019 @ 16:22
Error for Measurement is: ± 0.6 pCi/L

Canister ID# : 2704486 Test Start : 04/22/2019 @ 05:45
Canister Type : Charcoal Canister 3 inch Test Stop : 04/24/2019 @ 05:45
Location : 1st FL=Media BL Received: 04/29/2019 @ 10:13
Radon Level : 0.1 pCi/L Analyzed: 04/30/2019 @ 16:03
Error for Measurement is: ± 0.7 pCi/L



Andreas C. George

Andreas C. George
Radon Measurement Specialist
NJ MES 11089

Dante Galan

Dante Galan
Laboratory Director

NRSB ARL0001
NYS ELAP ID: 10806
PADEP ID: 0346
NJDEP ID: NY933
NJ MEB 90036
FL DOH RB1609
IL RNL2000201

Site Radon Inspection Report

Date : 04/29/2019

Bryan Hogan / Ron Havnear
MEDFORD SCHOOL DISTRICT
815 South Oakdale Avenue
Medford, OR 97501-

Client: Lone Pine E.S.
Test Location: 3158 Lone Pine Road
Medford, OR 97504-

Individual Canister Results

Canister ID# : 2707266 Test Start : 04/22/2019 @ 05:47
Canister Type : Charcoal Canister 3 inch Test Stop : 04/24/2019 @ 05:53
Location : 1st FL=Rm 8 Received: 04/29/2019 @ 10:13
Radon Level : 0.4 pCi/L Analyzed: 04/30/2019 @ 16:07
Error for Measurement is: ± 0.5 pCi/L

Canister ID# : 2707278 Test Start : 04/22/2019 @ 05:43
Canister Type : Charcoal Canister 3 inch Test Stop : 04/24/2019 @ 06:00
Location : 1st FL = Rm 23 Received: 04/29/2019 @ 10:13
Radon Level : 0.4 pCi/L Analyzed: 04/30/2019 @ 16:58
Error for Measurement is: ± 0.6 pCi/L

Canister ID# : 2707280 Test Start : 04/22/2019 @ 05:39
Canister Type : Charcoal Canister 3 inch Test Stop : 04/24/2019 @ 05:45
Location : 1st FL=Rm 1 Received: 04/29/2019 @ 10:13
Radon Level : 0.2 pCi/L Analyzed: 04/30/2019 @ 16:34
Error for Measurement is: ± 0.5 pCi/L

Canister ID# : 2707291 Test Start : 04/22/2019 @ 05:56
Canister Type : Charcoal Canister 3 inch Test Stop : 04/24/2019 @ 06:00
Location : 1st FL = Rm 11 Received: 04/29/2019 @ 10:13
Radon Level : 0.4 pCi/L Analyzed: 04/30/2019 @ 16:58
Error for Measurement is: ± 0.6 pCi/L

Canister ID# : 2707292 Test Start : 04/22/2019 @ 05:40
Canister Type : Charcoal Canister 3 inch Test Stop : 04/24/2019 @ 05:40
Location : 1st FL = Rm 24 BL Received: 04/29/2019 @ 10:13
Radon Level : 0.1 pCi/L Analyzed: 04/30/2019 @ 16:59
Error for Measurement is: ± 0.9 pCi/L

Canister ID# : 2707296 Test Start : 04/22/2019 @ 05:45
Canister Type : Charcoal Canister 3 inch Test Stop : 04/24/2019 @ 05:54
Location : 1st FL = Rm 14 Received: 04/29/2019 @ 10:13
Radon Level : 0.1 pCi/L Analyzed: 04/30/2019 @ 16:38
Error for Measurement is: ± 0.2 pCi/L



Andreas C. George

Andreas C. George
Radon Measurement Specialist
NJ MES 11089

Dante Galan

Dante Galan
Laboratory Director

NRSB ARL0001
NYS ELAP ID: 10806
PADEP ID: 0346
NJDEP ID: NY933
NJ MEB 90036
FL DOH RB1609
IL RNL2000201



Site Radon Inspection Report

Date : 04/29/2019

Bryan Hogan / Ron Havnear
MEDFORD SCHOOL DISTRICT
815 South Oakdale Avenue
Medford, OR 97501-

Client: Lone Pine E.S.
Test Location: 3158 Lone Pine Road
Medford, OR 97504-

Individual Canister Results

Canister ID# :	2707320	Test Start :	04/22/2019 @ 05:49
Canister Type :	Charcoal Canister 3 inch	Test Stop :	04/24/2019 @ 05:55
Location :	1st FL=Rm 9	Received:	04/29/2019 @ 10:13
Radon Level :	0.3 pCi/L	Analyzed:	04/30/2019 @ 16:58
Error for Measurement is: ±	0.5 pCi/L		

Canister ID# :	2707321	Test Start :	04/22/2019 @ 05:32
Canister Type :	Charcoal Canister 3 inch	Test Stop :	04/24/2019 @ 05:52
Location :	1st FL = Rm 25	Received:	04/29/2019 @ 10:13
Radon Level :	0.1 pCi/L	Analyzed:	04/30/2019 @ 16:38
Error for Measurement is: ±	0.8 pCi/L		

Canister ID# :	2736406	Test Start :	04/22/2019 @ 05:45
Canister Type :	Charcoal Canister 3 inch	Test Stop :	04/24/2019 @ 05:51
Location :	1st FL=Rm 7	Received:	04/29/2019 @ 10:13
Radon Level :	0.2 pCi/L	Analyzed:	04/30/2019 @ 17:11
Error for Measurement is: ±	0.7 pCi/L		

The results indicate that at least one testing device registered at or above the United States Environmental Protection Agency (EPA) action level of 4.0 picoCuries per liter of air (pCi/L). The EPA recommends mitigation if the average of two short-term tests taken in the lowest level of the building suitable for occupancy show radon levels that are equal to or greater than 4.0 pCi/L.

For information on how to reduce radon levels in your home, please review the EPA booklet: Consumer's Guide to Radon Reduction (www.epa.gov/radon/pdfs/consguid.pdf) and contact your state health department. The EPA maintains a radon information website, including copies of its publications, at www.epa.gov/iaq/radon.

For New Jersey clients: Please see the attached guidance document entitled Radon Testing and Mitigation: The Basics for further information.

For New York clients: If the radon level of one or more testing devices is equal to or exceeds 20 pCi/L please contact the New York State Department of Health, Bureau of Environmental Radiation Protection, for technical advice and assistance at 518-402-7556 or toll free 1-800-458-1158.



Andreas C. George

Andreas C. George
Radon Measurement Specialist
NJ MES 11089

Dante Galan

Dante Galan
Laboratory Director

NRSB ARL0001
NYS ELAP ID: 10806
PADEP ID: 0346
NJDEP ID: NY933
NJ MEB 90036
FL DOH RB1609
IL RNL2000201

Site Radon Inspection Report

Date : 04/29/2019

Bryan Hogan / Ron Havnear
MEDFORD SCHOOL DISTRICT
815 South Oakdale Avenue
Medford, OR 97501-

Client: Lone Pine E.S.
Test Location: 3158 Lone Pine Road
Medford, OR 97504-
Individual Canister Results

PLEDGE OF ASSURED QUALITY

All procedures used for generating this report are in complete accordance with the current EPA protocols for the analysis of radon in air (EPA 402-R-92-004). The analytical results relate only to the samples tested, in the condition received by the lab, and that calculations were based upon the information supplied by client. RTCA and its personnel do not assume responsibility or liability, collectively and individually, for analysis results when detectors have been improperly handled or placed by the consumer, nor does RTCA and its personnel accept responsibility for any financial or health consequences of subsequent action or lack of action, taken by the customer or it's consultants based on RTCA-provided results.



Andreas C. George

Andreas C. George
Radon Measurement Specialist
NJ MES 11089

Dante Galan

Dante Galan
Laboratory Director

NRSB ARL0001
NYS ELAP ID: 10806
PADEP ID: 0346
NJDEP ID: NY933
NJ MEB 90036
FL DOH RB1609
IL RNL2000201