

Site Radon Inspection Report

Date : 02/01/2018

Mr. Bryan Hogan
MEDFORD SCHOOL DISTRICT
815 South Oakdale Avenue
Medford, OR 97501-

Client: Howard Elementary School
Test Location: 286 Mace Road
Medford, OR 97501-

Individual Canister Results

Canister ID# : 2533155
Canister Type : Charcoal Canister 3 inch
Location : 1st FL-Rm 33B DUP
Radon Level : 17.8 pCi/L
Error for Measurement is: \pm 1.0 pCi/L

Test Start : 01/22/2018 @ 06:00
Test Stop : 01/24/2018 @ 06:00
Received: 02/01/2018 @ 10:55
Analyzed: 01/31/2018 @ 11:07

This is a quality control test known as a spike. This canister has never been on the school site.

Canister ID# : 2533256
Canister Type : Charcoal Canister 3 inch
Location : 1st FL-Rm 33A
Radon Level : 19.6 pCi/L
Error for Measurement is: \pm 0.9 pCi/L

Test Start : 01/22/2018 @ 06:00
Test Stop : 01/24/2018 @ 06:00
Received: 02/01/2018 @ 10:55
Analyzed: 01/30/2018 @ 18:57

This is a quality control test known as a spike. This canister has never been on the school site.

Canister ID# : 2569096
Canister Type : Charcoal Canister 3 inch
Location : 1st FL-Rm 30 DUP
Radon Level : 0.2 pCi/L
Error for Measurement is: \pm 0.6 pCi/L

Test Start : 01/22/2018 @ 06:12
Test Stop : 01/24/2018 @ 06:20
Received: 02/01/2018 @ 10:55
Analyzed: 01/31/2018 @ 11:33

Canister ID# : 2569098
Canister Type : Charcoal Canister 3 inch
Location : 1st FL-Rm 10
Radon Level : 0.1 pCi/L
Error for Measurement is: \pm 0.3 pCi/L

Test Start : 01/22/2018 @ 06:15
Test Stop : 01/24/2018 @ 06:20
Received: 02/01/2018 @ 10:54
Analyzed: 01/31/2018 @ 11:07

Canister ID# : 2569192
Canister Type : Charcoal Canister 3 inch
Location : 1st FL-Gym DUP
Radon Level : 0.1 pCi/L
Error for Measurement is: \pm 0.4 pCi/L

Test Start : 01/22/2018 @ 06:02
Test Stop : 01/24/2018 @ 06:12
Received: 02/01/2018 @ 10:55
Analyzed: 01/31/2018 @ 11:33

Canister ID# : 2570743
Canister Type : Charcoal Canister 3 inch
Location : 1st FL-Rm 1
Radon Level : 0.2 pCi/L
Error for Measurement is: \pm 0.4 pCi/L

Test Start : 01/22/2018 @ 06:14
Test Stop : 01/24/2018 @ 06:25
Received: 02/01/2018 @ 10:55
Analyzed: 01/30/2018 @ 18:57



Andreas C. George

Andreas C. George
Radon Measurement Specialist
NJ MES 11089

Dante Galan

Dante Galan
Laboratory Director

NRSB ARL0001
NYS ELAP ID: 10806
PADEP ID: 0346
NJDEP ID: NY933
NJ MEB 90036
FL DOH RB1609
IL RNL2000201

Site Radon Inspection Report

Date : 02/01/2018

Mr. Bryan Hogan
MEDFORD SCHOOL DISTRICT
815 South Oakdale Avenue
Medford, OR 97501-

Client: Howard Elementary School
Test Location: 286 Mace Road
Medford, OR 97501-

Individual Canister Results

Canister ID# : 2570765 Test Start : 01/22/2018 @ 06:10
Canister Type : Charcoal Canister 3 inch Test Stop : 01/24/2018 @ 06:22
Location : 1st FL-Rm 2 Received: 02/01/2018 @ 10:55
Radon Level : 0.6 pCi/L Analyzed: 01/30/2018 @ 16:00
Error for Measurement is: \pm 0.5 pCi/L

Canister ID# : 2570808 Test Start : 01/22/2018 @ 06:12
Canister Type : Charcoal Canister 3 inch Test Stop : 01/24/2018 @ 06:20
Location : 1st FL-Rm 30 Received: 02/01/2018 @ 10:55
Radon Level : 0.1 pCi/L Analyzed: 01/31/2018 @ 11:33
Error for Measurement is: \pm 0.3 pCi/L

Canister ID# : 2612113 Test Start : 01/22/2018 @ 06:25
Canister Type : Charcoal Canister 3 inch Test Stop : 01/24/2018 @ 06:30
Location : 1st FL-Rm 161 Received: 02/01/2018 @ 10:55
Radon Level : 0.7 pCi/L Analyzed: 01/31/2018 @ 11:33
Error for Measurement is: \pm 0.6 pCi/L

Canister ID# : 2612131 Test Start : 01/22/2018 @ 06:20
Canister Type : Charcoal Canister 3 inch Test Stop : 01/24/2018 @ 06:25
Location : 1st FL-Cafeteria 1 Received: 02/01/2018 @ 10:55
Radon Level : 0.4 pCi/L Analyzed: 01/31/2018 @ 12:21
Error for Measurement is: \pm 0.7 pCi/L

Canister ID# : 2612470 Test Start : 01/22/2018 @ 05:54
Canister Type : Charcoal Canister 3 inch Test Stop : 01/24/2018 @ 06:14
Location : 1st FL-Rm 6 Received: 02/01/2018 @ 10:55
Radon Level : 0.2 pCi/L Analyzed: 01/30/2018 @ 16:00
Error for Measurement is: \pm 0.6 pCi/L

Canister ID# : 2612471 Test Start : 01/22/2018 @ 05:11
Canister Type : Charcoal Canister 3 inch Test Stop : 01/24/2018 @ 05:11
Location : 1st FL-Health Received: 02/01/2018 @ 10:54
Radon Level : 0.8 pCi/L Analyzed: 01/30/2018 @ 16:00
Error for Measurement is: \pm 0.6 pCi/L



Andreas C. George

Andreas C. George
Radon Measurement Specialist
NJ MES 11089

Dante Galan

Dante Galan
Laboratory Director

NRSB ARL0001
NYS ELAP ID: 10806
PADEP ID: 0346
NJDEP ID: NY933
NJ MEB 90036
FL DOH RB1609
IL RNL2000201

Site Radon Inspection Report

Date : 02/01/2018

Mr. Bryan Hogan
MEDFORD SCHOOL DISTRICT
815 South Oakdale Avenue
Medford, OR 97501-

Client: Howard Elementary School
Test Location: 286 Mace Road
Medford, OR 97501-

Individual Canister Results

Canister ID# : 2612473 Test Start : 01/22/2018 @ 06:22
Canister Type : Charcoal Canister 3 inch Test Stop : 01/24/2018 @ 06:30
Location : 1st FL-Resource B4 Received: 02/01/2018 @ 10:55
Radon Level : 0.7 pCi/L Analyzed: 01/30/2018 @ 16:00
Error for Measurement is: \pm 0.5 pCi/L

Canister ID# : 2612478 Test Start : 01/22/2018 @ 05:35
Canister Type : Charcoal Canister 3 inch Test Stop : 01/24/2018 @ 05:35
Location : 1st FL-Rm 158 Received: 02/01/2018 @ 10:55
Radon Level : 0.3 pCi/L Analyzed: 01/30/2018 @ 15:59
Error for Measurement is: \pm 0.6 pCi/L

Canister ID# : 2612485 Test Start : 01/22/2018 @ 05:55
Canister Type : Charcoal Canister 3 inch Test Stop : 01/24/2018 @ 06:09
Location : 1st FL-Gym 1 Received: 02/01/2018 @ 10:55
Radon Level : 0.2 pCi/L Analyzed: 01/31/2018 @ 12:04
Error for Measurement is: \pm 0.7 pCi/L

Canister ID# : 2612491 Test Start : 01/22/2018 @ 05:19
Canister Type : Charcoal Canister 3 inch Test Stop : 01/24/2018 @ 05:19
Location : 1st FL-Rm 14 Received: 02/01/2018 @ 10:54
Radon Level : 0.7 pCi/L Analyzed: 01/30/2018 @ 16:00
Error for Measurement is: \pm 0.6 pCi/L

Canister ID# : 2612492 Test Start : 01/22/2018 @ 05:21
Canister Type : Charcoal Canister 3 inch Test Stop : 01/24/2018 @ 05:21
Location : 1st FL-Rm 18 Received: 02/01/2018 @ 10:54
Radon Level : 0.2 pCi/L Analyzed: 01/31/2018 @ 12:38
Error for Measurement is: \pm 0.6 pCi/L

Canister ID# : 2612554 Test Start : 01/22/2018 @ 05:54
Canister Type : Charcoal Canister 3 inch Test Stop : 01/24/2018 @ 06:14
Location : 1st FL-Rm 6 DUP Received: 02/01/2018 @ 10:55
Radon Level : 0.2 pCi/L Analyzed: 01/31/2018 @ 12:38
Error for Measurement is: \pm 0.8 pCi/L



Andreas C. George

Andreas C. George
Radon Measurement Specialist
NJ MES 11089

Dante Galan

Dante Galan
Laboratory Director

NRSB ARL0001
NYS ELAP ID: 10806
PADEP ID: 0346
NJDEP ID: NY933
NJ MEB 90036
FL DOH RB1609
IL RNL2000201

Site Radon Inspection Report

Date : 02/01/2018

Mr. Bryan Hogan
MEDFORD SCHOOL DISTRICT
815 South Oakdale Avenue
Medford, OR 97501-

Client: Howard Elementary School
Test Location: 286 Mace Road
Medford, OR 97501-

Individual Canister Results

Canister ID# : 2612555 Test Start : 01/22/2018 @ 06:15
Canister Type : Charcoal Canister 3 inch Test Stop : 01/24/2018 @ 06:23
Location : 1st FL-Rm 28 BLANK Received: 02/01/2018 @ 10:55
Radon Level : 0.1 pCi/L Analyzed: 01/31/2018 @ 12:04
Error for Measurement is: \pm 0.3 pCi/L

Canister ID# : 2612562 Test Start : 01/22/2018 @ 06:24
Canister Type : Charcoal Canister 3 inch Test Stop : 01/24/2018 @ 06:34
Location : 1st FL-Rm 25 Received: 02/01/2018 @ 10:55
Radon Level : 0.1 pCi/L Analyzed: 01/31/2018 @ 12:21
Error for Measurement is: \pm 0.4 pCi/L

Canister ID# : 2612567 Test Start : 01/22/2018 @ 05:36
Canister Type : Charcoal Canister 3 inch Test Stop : 01/24/2018 @ 05:36
Location : 1st FL-Rm 156/157 Received: 02/01/2018 @ 10:55
Radon Level : 0.2 pCi/L Analyzed: 01/30/2018 @ 16:00
Error for Measurement is: \pm 0.5 pCi/L

Canister ID# : 2619221 Test Start : 01/22/2018 @ 06:23
Canister Type : Charcoal Canister 3 inch Test Stop : 01/24/2018 @ 06:29
Location : 1st FL-Rm 7 Received: 02/01/2018 @ 10:55
Radon Level : 0.6 pCi/L Analyzed: 01/31/2018 @ 12:04
Error for Measurement is: \pm 0.6 pCi/L

Canister ID# : 2619231 Test Start : 01/22/2018 @ 06:02
Canister Type : Charcoal Canister 3 inch Test Stop : 01/24/2018 @ 06:18
Location : 1st FL-Rm 4 BLANK Received: 02/01/2018 @ 10:55
Radon Level : 0.1 pCi/L Analyzed: 01/31/2018 @ 12:38
Error for Measurement is: \pm 0.4 pCi/L

Canister ID# : 2619233 Test Start : 01/22/2018 @ 06:04
Canister Type : Charcoal Canister 3 inch Test Stop : 01/24/2018 @ 06:13
Location : 1st FL-Rm 12 Received: 02/01/2018 @ 10:54
Radon Level : 0.4 pCi/L Analyzed: 01/31/2018 @ 12:04
Error for Measurement is: \pm 0.6 pCi/L



Andreas C. George

Andreas C. George
Radon Measurement Specialist
NJ MES 11089

Dante Galan

Dante Galan
Laboratory Director

NRSB ARL0001
NYS ELAP ID: 10806
PADEP ID: 0346
NJDEP ID: NY933
NJ MEB 90036
FL DOH RB1609
IL RNL2000201

Site Radon Inspection Report

Date : 02/01/2018

Mr. Bryan Hogan
MEDFORD SCHOOL DISTRICT
815 South Oakdale Avenue
Medford, OR 97501-

Client: Howard Elementary School
Test Location: 286 Mace Road
Medford, OR 97501-

Individual Canister Results

Canister ID# : 2619242 Test Start : 01/22/2018 @ 06:07
Canister Type : Charcoal Canister 3 inch Test Stop : 01/24/2018 @ 06:11
Location : 1st FL-Rm 31 Received: 02/01/2018 @ 10:55
Radon Level : 0.3 pCi/L Analyzed: 01/31/2018 @ 12:04
Error for Measurement is: \pm 0.5 pCi/L

Canister ID# : 2619243 Test Start : 01/22/2018 @ 06:13
Canister Type : Charcoal Canister 3 inch Test Stop : 01/24/2018 @ 06:21
Location : 1st FL-Rm 29 Received: 02/01/2018 @ 10:55
Radon Level : 0.5 pCi/L Analyzed: 01/31/2018 @ 11:33
Error for Measurement is: \pm 0.7 pCi/L

Canister ID# : 2619244 Test Start : 01/22/2018 @ 06:20
Canister Type : Charcoal Canister 3 inch Test Stop : 01/24/2018 @ 06:29
Location : 1st FL-Rm 26 Received: 02/01/2018 @ 10:55
Radon Level : 0.6 pCi/L Analyzed: 01/31/2018 @ 11:33
Error for Measurement is: \pm 0.7 pCi/L

Canister ID# : 2619246 Test Start : 01/22/2018 @ 05:58
Canister Type : Charcoal Canister 3 inch Test Stop : 01/24/2018 @ 06:07
Location : 1st FL-Rm 20 Received: 02/01/2018 @ 10:54
Radon Level : 0.4 pCi/L Analyzed: 01/31/2018 @ 12:21
Error for Measurement is: \pm 0.6 pCi/L

Canister ID# : 2619247 Test Start : 01/22/2018 @ 06:26
Canister Type : Charcoal Canister 3 inch Test Stop : 01/24/2018 @ 06:32
Location : 1st FL-Rm 24 Received: 02/01/2018 @ 10:55
Radon Level : 0.8 pCi/L Analyzed: 01/31/2018 @ 11:33
Error for Measurement is: \pm 0.6 pCi/L

Canister ID# : 2619249 Test Start : 01/22/2018 @ 06:10
Canister Type : Charcoal Canister 3 inch Test Stop : 01/24/2018 @ 06:16
Location : 1st FL-Staff Break Rm Received: 02/01/2018 @ 10:54
Radon Level : 0.1 pCi/L Analyzed: 01/31/2018 @ 12:04
Error for Measurement is: \pm 0.3 pCi/L



Andreas C. George

Andreas C. George
Radon Measurement Specialist
NJ MES 11089

Dante Galan

Dante Galan
Laboratory Director

NRSB ARL0001
NYS ELAP ID: 10806
PADEP ID: 0346
NJDEP ID: NY933
NJ MEB 90036
FL DOH RB1609
IL RNL2000201

Site Radon Inspection Report

Date : 02/01/2018

Mr. Bryan Hogan
MEDFORD SCHOOL DISTRICT
815 South Oakdale Avenue
Medford, OR 97501-

Client: Howard Elementary School
Test Location: 286 Mace Road
Medford, OR 97501-

Individual Canister Results

Canister ID# : 2619251 Test Start : 01/22/2018 @ 05:31
Canister Type : Charcoal Canister 3 inch Test Stop : 01/24/2018 @ 05:32
Location : 1st FL-Comp. Rm Received: 02/01/2018 @ 10:55
Radon Level : 0.1 pCi/L Analyzed: 01/31/2018 @ 12:21
Error for Measurement is: \pm 0.3 pCi/L

Canister ID# : 2619252 Test Start : 01/22/2018 @ 06:23
Canister Type : Charcoal Canister 3 inch Test Stop : 01/24/2018 @ 06:26
Location : 1st FL-Cafeteria DUP Received: 02/01/2018 @ 10:55
Radon Level : 0.2 pCi/L Analyzed: 01/31/2018 @ 12:04
Error for Measurement is: \pm 0.5 pCi/L

Canister ID# : 2619253 Test Start : 01/22/2018 @ 06:00
Canister Type : Charcoal Canister 3 inch Test Stop : 01/24/2018 @ 06:09
Location : 1st FL-Rm 13 Received: 02/01/2018 @ 10:54
Radon Level : 0.1 pCi/L Analyzed: 01/31/2018 @ 12:04
Error for Measurement is: \pm 0.2 pCi/L

Canister ID# : 2619254 Test Start : 01/22/2018 @ 06:22
Canister Type : Charcoal Canister 3 inch Test Stop : 01/24/2018 @ 06:25
Location : 1st FL-Cafeteria 2 Received: 02/01/2018 @ 10:55
Radon Level : 0.1 pCi/L Analyzed: 01/30/2018 @ 18:57
Error for Measurement is: \pm 0.3 pCi/L

Canister ID# : 2619266 Test Start : 01/22/2018 @ 06:18
Canister Type : Charcoal Canister 3 inch Test Stop : 01/24/2018 @ 06:26
Location : 1st FL-Rm 32 Received: 02/01/2018 @ 10:55
Radon Level : 0.2 pCi/L Analyzed: 01/31/2018 @ 12:21
Error for Measurement is: \pm 0.8 pCi/L

Canister ID# : 2619269 Test Start : 01/22/2018 @ 06:19
Canister Type : Charcoal Canister 3 inch Test Stop : 01/24/2018 @ 06:25
Location : 1st FL-Rm 9 Received: 02/01/2018 @ 10:55
Radon Level : 0.6 pCi/L Analyzed: 01/31/2018 @ 12:21
Error for Measurement is: \pm 0.7 pCi/L



Andreas C. George

Andreas C. George
Radon Measurement Specialist
NJ MES 11089

Dante Galan

Dante Galan
Laboratory Director

NRSB ARL0001
NYS ELAP ID: 10806
PADEP ID: 0346
NJDEP ID: NY933
NJ MEB 90036
FL DOH RB1609
IL RNL2000201

Site Radon Inspection Report

Date : 02/01/2018

Mr. Bryan Hogan
MEDFORD SCHOOL DISTRICT
815 South Oakdale Avenue
Medford, OR 97501-

Client: Howard Elementary School
Test Location: 286 Mace Road
Medford, OR 97501-

Individual Canister Results

Canister ID# : 2619270 Test Start : 01/22/2018 @ 05:09
Canister Type : Charcoal Canister 3 inch Test Stop : 01/24/2018 @ 05:09
Location : 1st FL-Principal Received: 02/01/2018 @ 10:54
Radon Level : 0.1 pCi/L Analyzed: 01/31/2018 @ 12:04
Error for Measurement is: \pm 0.1 pCi/L

Canister ID# : 2619271 Test Start : 01/22/2018 @ 05:12
Canister Type : Charcoal Canister 3 inch Test Stop : 01/24/2018 @ 05:12
Location : 1st FL-Staff Work Rm Received: 02/01/2018 @ 10:54
Radon Level : 0.4 pCi/L Analyzed: 01/31/2018 @ 12:21
Error for Measurement is: \pm 0.7 pCi/L

Canister ID# : 2619272 Test Start : 01/22/2018 @ 06:10
Canister Type : Charcoal Canister 3 inch Test Stop : 01/24/2018 @ 06:22
Location : 1st FL-Rm 2 DUP Received: 02/01/2018 @ 10:55
Radon Level : 1.2 pCi/L Analyzed: 01/31/2018 @ 11:33
Error for Measurement is: \pm 0.6 pCi/L

Canister ID# : 2619277 Test Start : 01/22/2018 @ 05:24
Canister Type : Charcoal Canister 3 inch Test Stop : 01/24/2018 @ 05:25
Location : 1st FL-Rm 19 Received: 02/01/2018 @ 10:54
Radon Level : 0.4 pCi/L Analyzed: 01/30/2018 @ 16:00
Error for Measurement is: \pm 0.6 pCi/L

Canister ID# : 2619279 Test Start : 01/22/2018 @ 06:16
Canister Type : Charcoal Canister 3 inch Test Stop : 01/24/2018 @ 06:21
Location : 1st FL-Rm 21 Received: 02/01/2018 @ 10:55
Radon Level : 1.9 pCi/L Analyzed: 01/30/2018 @ 18:57
Error for Measurement is: \pm 0.7 pCi/L

Canister ID# : 2619280 Test Start : 01/22/2018 @ 05:15
Canister Type : Charcoal Canister 3 inch Test Stop : 01/24/2018 @ 05:15
Location : 1st FL-Rm 16 Received: 02/01/2018 @ 10:54
Radon Level : 0.1 pCi/L Analyzed: 01/31/2018 @ 12:04
Error for Measurement is: \pm 0.4 pCi/L



Andreas C. George

Andreas C. George
Radon Measurement Specialist
NJ MES 11089

Dante Galan

Dante Galan
Laboratory Director

NRSB ARL0001
NYS ELAP ID: 10806
PADEP ID: 0346
NJDEP ID: NY933
NJ MEB 90036
FL DOH RB1609
IL RNL2000201

Site Radon Inspection Report

Date : 02/01/2018

Mr. Bryan Hogan
MEDFORD SCHOOL DISTRICT
815 South Oakdale Avenue
Medford, OR 97501-

Client: Howard Elementary School
Test Location: 286 Mace Road
Medford, OR 97501-

Individual Canister Results

Canister ID# : 2619281 Test Start : 01/22/2018 @ 05:18
Canister Type : Charcoal Canister 3 inch Test Stop : 01/24/2018 @ 05:18
Location : 1st FL-Rm 15 Received: 02/01/2018 @ 10:54
Radon Level : 0.2 pCi/L Analyzed: 01/31/2018 @ 12:04
Error for Measurement is: \pm 0.5 pCi/L

Canister ID# : 2619282 Test Start : 01/22/2018 @ 06:17
Canister Type : Charcoal Canister 3 inch Test Stop : 01/24/2018 @ 06:24
Location : 1st FL-Rm 27 Received: 02/01/2018 @ 10:55
Radon Level : 0.8 pCi/L Analyzed: 01/31/2018 @ 12:21
Error for Measurement is: \pm 0.8 pCi/L

Canister ID# : 2619283 Test Start : 01/22/2018 @ 05:06
Canister Type : Charcoal Canister 3 inch Test Stop : 01/24/2018 @ 05:06
Location : 1st FL-Office Received: 02/01/2018 @ 10:54
Radon Level : 0.1 pCi/L Analyzed: 01/31/2018 @ 12:21
Error for Measurement is: \pm 0.5 pCi/L

Canister ID# : 2619289 Test Start : 01/22/2018 @ 05:32
Canister Type : Charcoal Canister 3 inch Test Stop : 01/24/2018 @ 05:34
Location : 1st FL-Rm 160/59 Received: 02/01/2018 @ 10:55
Radon Level : 0.6 pCi/L Analyzed: 01/31/2018 @ 11:33
Error for Measurement is: \pm 0.6 pCi/L

Canister ID# : 2619296 Test Start : 01/22/2018 @ 06:20
Canister Type : Charcoal Canister 3 inch Test Stop : 01/24/2018 @ 06:29
Location : 1st FL-Rm 26 DUP Received: 02/01/2018 @ 10:55
Radon Level : 0.2 pCi/L Analyzed: 01/31/2018 @ 12:39
Error for Measurement is: \pm 0.6 pCi/L

Canister ID# : 2619301 Test Start : 01/22/2018 @ 05:30
Canister Type : Charcoal Canister 3 inch Test Stop : 01/24/2018 @ 05:31
Location : 1st FL-Media Ctr 3 Received: 02/01/2018 @ 10:55
Radon Level : 1.0 pCi/L Analyzed: 01/31/2018 @ 11:33
Error for Measurement is: \pm 0.6 pCi/L



Andreas C. George

Andreas C. George
Radon Measurement Specialist
NJ MES 11089

Dante Galan

Dante Galan
Laboratory Director

NRSB ARL0001
NYS ELAP ID: 10806
PADEP ID: 0346
NJDEP ID: NY933
NJ MEB 90036
FL DOH RB1609
IL RNL2000201

Site Radon Inspection Report

Date : 02/01/2018

Mr. Bryan Hogan
MEDFORD SCHOOL DISTRICT
815 South Oakdale Avenue
Medford, OR 97501-

Client: Howard Elementary School
Test Location: 286 Mace Road
Medford, OR 97501-

Individual Canister Results

Canister ID# : 2619309 Test Start : 01/22/2018 @ 06:06
Canister Type : Charcoal Canister 3 inch Test Stop : 01/24/2018 @ 06:19
Location : 1st FL-Rm 3 Received: 02/01/2018 @ 10:55
Radon Level : 0.1 pCi/L Analyzed: 01/31/2018 @ 12:21
Error for Measurement is: ± 0.3 pCi/L

Canister ID# : 2619313 Test Start : 01/22/2018 @ 05:58
Canister Type : Charcoal Canister 3 inch Test Stop : 01/24/2018 @ 06:17
Location : 1st FL-Rm 5 Received: 02/01/2018 @ 10:55
Radon Level : 0.2 pCi/L Analyzed: 01/31/2018 @ 12:21
Error for Measurement is: ± 0.7 pCi/L

Canister ID# : 2619314 Test Start : 01/22/2018 @ 06:22
Canister Type : Charcoal Canister 3 inch Test Stop : 01/24/2018 @ 06:27
Location : 1st FL-Rm 8 Received: 02/01/2018 @ 10:55
Radon Level : 0.2 pCi/L Analyzed: 01/31/2018 @ 11:33
Error for Measurement is: ± 0.4 pCi/L

Canister ID# : 2619334 Test Start : 01/22/2018 @ 06:03
Canister Type : Charcoal Canister 3 inch Test Stop : 01/24/2018 @ 06:13
Location : 1st FL-Stage Received: 02/01/2018 @ 10:55
Radon Level : 0.1 pCi/L Analyzed: 01/31/2018 @ 11:33
Error for Measurement is: ± 0.7 pCi/L

Canister ID# : 2619339 Test Start : 01/22/2018 @ 05:13
Canister Type : Charcoal Canister 3 inch Test Stop : 01/24/2018 @ 05:13
Location : 1st FL-Rm 17 Received: 02/01/2018 @ 10:54
Radon Level : 0.1 pCi/L Analyzed: 01/31/2018 @ 12:38
Error for Measurement is: ± 0.4 pCi/L

Canister ID# : 2619340 Test Start : 01/22/2018 @ 06:04
Canister Type : Charcoal Canister 3 inch Test Stop : 01/24/2018 @ 06:14
Location : 1st FL-Stage BLANK Received: 02/01/2018 @ 10:55
Radon Level : 0.1 pCi/L Analyzed: 01/31/2018 @ 12:04
Error for Measurement is: ± 0.2 pCi/L



Andreas C. George

Andreas C. George
Radon Measurement Specialist
NJ MES 11089

Dante Galan

Dante Galan
Laboratory Director

NRSB ARL0001
NYS ELAP ID: 10806
PADEP ID: 0346
NJDEP ID: NY933
NJ MEB 90036
FL DOH RB1609
IL RNL2000201

Site Radon Inspection Report

Date : 02/01/2018

Mr. Bryan Hogan
MEDFORD SCHOOL DISTRICT
815 South Oakdale Avenue
Medford, OR 97501-

Client: Howard Elementary School
Test Location: 286 Mace Road
Medford, OR 97501-

Individual Canister Results

Canister ID# : 2619341 Test Start : 01/22/2018 @ 06:26
Canister Type : Charcoal Canister 3 inch Test Stop : 01/24/2018 @ 06:32
Location : 1st FL-Rm 24 BLANK Received: 02/01/2018 @ 10:55
Radon Level : 0.1 pCi/L Analyzed: 01/31/2018 @ 11:33
Error for Measurement is: \pm 0.7 pCi/L

Canister ID# : 2619348 Test Start : 01/22/2018 @ 05:58
Canister Type : Charcoal Canister 3 inch Test Stop : 01/24/2018 @ 06:12
Location : 1st FL-Gym 2 Received: 02/01/2018 @ 10:55
Radon Level : 0.8 pCi/L Analyzed: 01/31/2018 @ 12:39
Error for Measurement is: \pm 0.6 pCi/L

Canister ID# : 2619358 Test Start : 01/22/2018 @ 06:18
Canister Type : Charcoal Canister 3 inch Test Stop : 01/24/2018 @ 06:24
Location : 1st FL-Rm 136 Received: 02/01/2018 @ 10:55
Radon Level : 0.2 pCi/L Analyzed: 01/31/2018 @ 12:21
Error for Measurement is: \pm 0.6 pCi/L

Canister ID# : 2619401 Test Start : 01/22/2018 @ 05:27
Canister Type : Charcoal Canister 3 inch Test Stop : 01/24/2018 @ 05:27
Location : 1st FL-Media Ctr 1 Received: 12/31/-4714 @ 00:00
Radon Level : 0.1 pCi/L Analyzed: 01/31/2018 @ 12:04
Error for Measurement is: \pm 0.4 pCi/L

Canister ID# : 2619414 Test Start : 01/22/2018 @ 06:08
Canister Type : Charcoal Canister 3 inch Test Stop : 01/24/2018 @ 06:14
Location : 1st FL-Rm 11 Received: 02/01/2018 @ 10:54
Radon Level : 0.2 pCi/L Analyzed: 01/31/2018 @ 12:21
Error for Measurement is: \pm 0.8 pCi/L

Canister ID# : 2619419 Test Start : 01/22/2018 @ 06:02
Canister Type : Charcoal Canister 3 inch Test Stop : 01/24/2018 @ 06:18
Location : 1st FL-Rm 4 Received: 02/01/2018 @ 10:55
Radon Level : 0.4 pCi/L Analyzed: 01/31/2018 @ 12:39
Error for Measurement is: \pm 0.7 pCi/L



Andreas C. George

Dante Galan

Andreas C. George
Radon Measurement Specialist
NJ MES 11089

Dante Galan
Laboratory Director

NRSB ARL0001
NYS ELAP ID: 10806
PADEP ID: 0346
NJDEP ID: NY933
NJ MEB 90036
FL DOH RB1609
IL RNL2000201

Site Radon Inspection Report

Date : 02/01/2018

Mr. Bryan Hogan
MEDFORD SCHOOL DISTRICT
815 South Oakdale Avenue
Medford, OR 97501-

Client: Howard Elementary School
Test Location: 286 Mace Road
Medford, OR 97501-

Individual Canister Results

Canister ID# : 2619450 Test Start : 01/22/2018 @ 06:10
Canister Type : Charcoal Canister 3 inch Test Stop : 01/24/2018 @ 06:10
Location : 1st FL-E. Commons Received: 02/01/2018 @ 10:55
Radon Level : 0.1 pCi/L Analyzed: 01/31/2018 @ 12:38
Error for Measurement is: \pm 0.2 pCi/L

Canister ID# : 2619454 Test Start : 01/22/2018 @ 05:07
Canister Type : Charcoal Canister 3 inch Test Stop : 01/24/2018 @ 05:07
Location : 1st FL-Off. Mgr. Received: 02/01/2018 @ 10:54
Radon Level : 0.1 pCi/L Analyzed: 01/31/2018 @ 12:04
Error for Measurement is: \pm 0.7 pCi/L

Canister ID# : 2619458 Test Start : 01/22/2018 @ 05:28
Canister Type : Charcoal Canister 3 inch Test Stop : 01/24/2018 @ 05:29
Location : 1st FL-Media Ctr 2 Received: 02/01/2018 @ 10:55
Radon Level : 0.6 pCi/L Analyzed: 01/30/2018 @ 16:00
Error for Measurement is: \pm 0.5 pCi/L

Canister ID# : 2619460 Test Start : 01/22/2018 @ 06:26
Canister Type : Charcoal Canister 3 inch Test Stop : 01/24/2018 @ 06:30
Location : 1st FL-Rm 161 BLANK Received: 02/01/2018 @ 10:55
Radon Level : 0.1 pCi/L Analyzed: 01/31/2018 @ 12:38
Error for Measurement is: \pm 0.2 pCi/L

Canister ID# : 2619471 Test Start : 01/22/2018 @ 06:16
Canister Type : Charcoal Canister 3 inch Test Stop : 01/24/2018 @ 06:22
Location : 1st FL-Rm 137 Received: 02/01/2018 @ 10:55
Radon Level : 0.3 pCi/L Analyzed: 01/31/2018 @ 12:04
Error for Measurement is: \pm 0.6 pCi/L

Canister ID# : 2619474 Test Start : 01/22/2018 @ 06:15
Canister Type : Charcoal Canister 3 inch Test Stop : 01/24/2018 @ 06:23
Location : 1st FL-Rm 28 Received: 02/01/2018 @ 10:55
Radon Level : 0.6 pCi/L Analyzed: 01/31/2018 @ 12:21
Error for Measurement is: \pm 0.6 pCi/L



Andreas C. George

Andreas C. George
Radon Measurement Specialist
NJ MES 11089

Dante Galan

Dante Galan
Laboratory Director

NRSB ARL0001
NYS ELAP ID: 10806
PADEP ID: 0346
NJDEP ID: NY933
NJ MEB 90036
FL DOH RB1609
IL RNL2000201

Site Radon Inspection Report

Date : 02/01/2018

Mr. Bryan Hogan
MEDFORD SCHOOL DISTRICT
815 South Oakdale Avenue
Medford, OR 97501-

Client: Howard Elementary School
Test Location: 286 Mace Road
Medford, OR 97501-

Individual Canister Results

The results indicate that at least one testing device registered at or above the United States Environmental Protection Agency (EPA) action level of 4.0 picoCuries per liter of air (pCi/L). The EPA recommends mitigation if the average of two short-term tests taken in the lowest level of the building suitable for occupancy show radon levels that are equal to or greater than 4.0 pCi/L.

For information on how to reduce radon levels in your home, please review the EPA booklet: Consumer's Guide to Radon Reduction (www.epa.gov/radon/pdfs/consguid.pdf) and contact your state health department. The EPA maintains a radon information website, including copies of its publications, at www.epa.gov/iaq/radon.

For New Jersey clients: Please see the attached guidance document entitled Radon Testing and Mitigation: The Basics for further information.

For New York clients: If the radon level of one or more testing devices is equal to or exceeds 20 pCi/L please contact the New York State Department of Health, Bureau of Environmental Radiation Protection, for technical advice and assistance at 518-402-7556 or toll free 1-800-458-1158.

PLEDGE OF ASSURED QUALITY

All procedures used for generating this report are in complete accordance with the current EPA protocols for the analysis of radon in air (EPA 402-R-92-004). The analytical results relate only to the samples tested, in the condition received by the lab, and that calculations were based upon the information supplied by client. RTCA and its personnel do not assume responsibility or liability, collectively and individually, for analysis results when detectors have been improperly handled or placed by the consumer, nor does RTCA and its personnel accept responsibility for any financial or health consequences of subsequent action or lack of action, taken by the customer or its consultants based on RTCA-provided results.



Andreas C. George
Radon Measurement Specialist
NJ MES 11089

Dante Galan
Laboratory Director

NRSB ARL0001
NYS ELAP ID: 10806
PADEP ID: 0346
NJDEP ID: NY933
NJ MEB 90036
FL DOH RB1609
IL RNL2000201