

Site Radon Inspection Report

Date : 12/11/2017

Mr. Bryan Hogan/Ron Havnear  
MEDFORD SCHOOL DISTRICT  
815 South Oakdale Avenue  
Medford, OR 97501-

Client: Howard Elementary School

Test Location: 286 Mace Road  
Medford, OR 97501-

### Individual Canister Results

Canister ID# : 2533167  
Canister Type : Charcoal Canister 3 inch  
Location : 1st FL-33 A  
Radon Level : **22.6 pCi/L**  
Error for Measurement is:  $\pm$  1.2 pCi/L

Test Start : 12/02/2017 @ 08:22  
Test Stop : 12/04/2017 @ 08:22  
Received: 12/11/2017 @ 14:14  
Analyzed: 12/12/2017 @ 15:37

This is a quality control test known as a spike. This canister has never been on the school site.

Canister ID# : 2533169  
Canister Type : Charcoal Canister 3 inch  
Location : 1st FL-33 B  
Radon Level : **26.3 pCi/L**  
Error for Measurement is:  $\pm$  1.4 pCi/L

Test Start : 12/02/2017 @ 08:22  
Test Stop : 12/04/2017 @ 08:22  
Received: 12/11/2017 @ 14:14  
Analyzed: 12/12/2017 @ 15:37

This is a quality control test known as a spike. This canister has never been on the school site.

Canister ID# : 2533174  
Canister Type : Charcoal Canister 3 inch  
Location : 1st FL-Cafeteria 1  
Radon Level : **N/C pCi/L**

Test Start : 11/29/2017 @ 06:05  
Test Stop : 12/01/2017 @ 06:11  
Received: 12/11/2017 @ 14:14  
Analyzed: 12/12/2017 @ 15:37

Canister ID# : 2533219  
Canister Type : Charcoal Canister 3 inch  
Location : 1st FL-Cafeteria 2  
Radon Level : **N/C pCi/L**

Test Start : 11/29/2017 @ 06:07  
Test Stop : 12/01/2017 @ 06:10  
Received: 12/11/2017 @ 14:14  
Analyzed: 12/12/2017 @ 14:10

Canister ID# : 2533280  
Canister Type : Charcoal Canister 3 inch  
Location : 1st FL-Stage-Blank  
Radon Level : **N/C pCi/L**

Test Start : 11/29/2017 @ 06:25  
Test Stop : 12/01/2017 @ 06:30  
Received: 12/11/2017 @ 14:14  
Analyzed: 12/12/2017 @ 13:44

Canister ID# : 2533274  
Canister Type : Charcoal Canister 3 inch  
Location : 1st FL-Cafeteria 2  
Radon Level : **N/C pCi/L**

Test Start : 11/29/2017 @ 06:07  
Test Stop : 12/01/2017 @ 06:10  
Received: 12/11/2017 @ 14:14  
Analyzed: 12/12/2017 @ 14:10



*Andreas C. George*

Andreas C. George  
Radon Measurement Specialist  
NJ MES 11089

*Dante Galan*

Dante Galan  
Laboratory Director

NRSB ARL0001  
NYS ELAP ID: 10806  
PADEP ID: 0346  
NJDEP ID: NY933  
NJ MEB 90036  
FL DOH RB1609  
IL RNL2000201

Site Radon Inspection Report

Date : 12/11/2017

Canister ID# : 2533251                      Test Start : 11/29/2017 @ 06:23  
Canister Type : Charcoal Canister 3 inch      Test Stop : 12/01/2017 @ 06:28  
Location : 1st FL-Gym 2                      Received: 12/11/2017 @ 14:14  
Radon Level : **N/C pCi/L**                      Analyzed: 12/12/2017 @ 14:10

Canister ID# : 2533282                      Test Start : 11/29/2017 @ 06:20  
Canister Type : Charcoal Canister 3 inch      Test Stop : 12/01/2017 @ 06:26  
Location : 1st FL-Gym1                      Received: 12/11/2017 @ 14:14  
Radon Level : **N/C pCi/L**                      Analyzed: 12/12/2017 @ 14:10

Canister ID# : 2570093                      Test Start : 11/29/2017 @ 06:15  
Canister Type : Charcoal Canister 3 inch      Test Stop : 12/01/2017 @ 06:17  
Location : 1st FL-Rm 161                      Received: 12/11/2017 @ 14:14  
Radon Level : **N/C pCi/L**                      Analyzed: 12/12/2017 @ 15:37

Canister ID# : 2570078                      Test Start : 11/29/2017 @ 06:25  
Canister Type : Charcoal Canister 3 inch      Test Stop : 12/01/2017 @ 06:30  
Location : 1st FL-Stage                      Received: 12/11/2017 @ 14:14  
Radon Level : **N/C pCi/L**                      Analyzed: 12/12/2017 @ 15:37

Canister ID# : 2570449                      Test Start : 11/29/2017 @ 06:14  
Canister Type : Charcoal Canister 3 inch      Test Stop : 12/01/2017 @ 06:16  
Location : 1st FL-Rm 1                      Received: 12/11/2017 @ 14:14  
Radon Level : **N/C pCi/L**                      Analyzed: 12/12/2017 @ 15:52

Canister ID# : 2569120                      Test Start : 11/29/2017 @ 06:13  
Canister Type : Charcoal Canister 3 inch      Test Stop : 12/01/2017 @ 06:14  
Location : 1st FL-Rm 32                      Received: 12/11/2017 @ 14:14  
Radon Level : **N/C pCi/L**                      Analyzed: 12/12/2017 @ 14:10

Canister ID# : 2569134                      Test Start : 11/29/2017 @ 06:05  
Canister Type : Charcoal Canister 3 inch      Test Stop : 12/01/2017 @ 06:05  
Location : 1st FL-Rm 4-Blank                      Received: 12/11/2017 @ 14:14  
Radon Level : **N/C pCi/L**                      Analyzed: 12/12/2017 @ 14:10

Canister ID# : 2569127                      Test Start : 11/29/2017 @ 05:44  
Canister Type : Charcoal Canister 3 inch      Test Stop : 12/01/2017 @ 05:47  
Location : 1st FL-Rm 15                      Received: 12/11/2017 @ 14:14  
Radon Level : **N/C pCi/L**                      Analyzed: 12/12/2017 @ 13:25

Canister ID# : 2569107                      Test Start : 11/29/2017 @ 05:30  
Canister Type : Charcoal Canister 3 inch      Test Stop : 12/01/2017 @ 05:30  
Location : 1st FL-Principals                      Received: 12/11/2017 @ 14:14  
Radon Level : **N/C pCi/L**                      Analyzed: 12/12/2017 @ 13:44



*Andreas C. George*

Andreas C. George  
Radon Measurement Specialist  
NJ MES 11089

*Dante Galan*

Dante Galan  
Laboratory Director

NRSB ARL0001  
NYS ELAP ID: 10806  
PADEP ID: 0346  
NJDEP ID: NY933  
NJ MEB 90036  
FL DOH RB1609  
IL RNL2000201

Site Radon Inspection Report

Date : 12/11/2017

Canister ID# :	2570458	Test Start :	11/29/2017 @ 06:05
Canister Type :	Charcoal Canister 3 inch	Test Stop :	12/01/2017 @ 06:05
Location :	1st FL-Rm 4	Received:	12/11/2017 @ 14:14
Radon Level :	<b>N/C pCi/L</b>	Analyzed:	12/12/2017 @ 16:44
Canister ID# :	2570491	Test Start :	11/29/2017 @ 06:05
Canister Type :	Charcoal Canister 3 inch	Test Stop :	12/01/2017 @ 06:05
Location :	1st FL-Rm 30	Received:	12/11/2017 @ 14:14
Radon Level :	<b>N/C pCi/L</b>	Analyzed:	12/12/2017 @ 13:25
Canister ID# :	2570493	Test Start :	11/29/2017 @ 06:10
Canister Type :	Charcoal Canister 3 inch	Test Stop :	12/01/2017 @ 06:10
Location :	1st FL-Rm 28	Received:	12/11/2017 @ 14:14
Radon Level :	<b>N/C pCi/L</b>	Analyzed:	12/12/2017 @ 13:44
Canister ID# :	2570440	Test Start :	11/29/2017 @ 06:09
Canister Type :	Charcoal Canister 3 inch	Test Stop :	12/01/2017 @ 06:09
Location :	1st FL-Rm 29	Received:	12/11/2017 @ 14:14
Radon Level :	<b>N/C pCi/L</b>	Analyzed:	12/12/2017 @ 15:52
Canister ID# :	2570847	Test Start :	11/29/2017 @ 06:05
Canister Type :	Charcoal Canister 3 inch	Test Stop :	12/01/2017 @ 06:06
Location :	1st FL-Media 1	Received:	12/11/2017 @ 14:14
Radon Level :	<b>N/C pCi/L</b>	Analyzed:	12/12/2017 @ 13:44
Canister ID# :	2570839	Test Start :	11/29/2017 @ 06:08
Canister Type :	Charcoal Canister 3 inch	Test Stop :	12/01/2017 @ 06:13
Location :	1st FL-Break Rm	Received:	12/11/2017 @ 14:14
Radon Level :	<b>N/C pCi/L</b>	Analyzed:	12/12/2017 @ 14:10
Canister ID# :	2570823	Test Start :	11/29/2017 @ 06:29
Canister Type :	Charcoal Canister 3 inch	Test Stop :	12/01/2017 @ 06:29
Location :	1st FL-Rm 137	Received:	12/11/2017 @ 14:14
Radon Level :	<b>N/C pCi/L</b>	Analyzed:	12/12/2017 @ 16:23
Canister ID# :	2570786	Test Start :	11/29/2017 @ 06:16
Canister Type :	Charcoal Canister 3 inch	Test Stop :	12/01/2017 @ 06:17
Location :	1st FL-Rm 26	Received:	12/11/2017 @ 14:14
Radon Level :	<b>N/C pCi/L</b>	Analyzed:	12/12/2017 @ 15:52
Canister ID# :	2570788	Test Start :	11/29/2017 @ 06:28
Canister Type :	Charcoal Canister 3 inch	Test Stop :	12/01/2017 @ 06:28
Location :	1st FL-Rm 136	Received:	12/11/2017 @ 14:14
Radon Level :	<b>N/C pCi/L</b>	Analyzed:	12/12/2017 @ 14:10



*Andreas C. George*

Andreas C. George  
Radon Measurement Specialist  
NJ MES 11089

*Dante Galan*

Dante Galan  
Laboratory Director

NRSB ARL0001  
NYS ELAP ID: 10806  
PADEP ID: 0346  
NJDEP ID: NY933  
NJ MEB 90036  
FL DOH RB1609  
IL RNL2000201

Site Radon Inspection Report

Date : 12/11/2017

Canister ID# : 2569194                      Test Start : 11/29/2017 @ 05:50  
Canister Type : Charcoal Canister 3 inch      Test Stop : 12/01/2017 @ 15:25  
Location : 1st FL-Rm 18                      Received: 12/11/2017 @ 14:14  
Radon Level : **N/C pCi/L**                      Analyzed: 12/12/2017 @ 14:10

Canister ID# : 2569160                      Test Start : 11/29/2017 @ 05:35  
Canister Type : Charcoal Canister 3 inch      Test Stop : 12/01/2017 @ 05:35  
Location : 1st FL-Work Rm                      Received: 12/11/2017 @ 14:14  
Radon Level : **N/C pCi/L**                      Analyzed: 12/12/2017 @ 14:10

Canister ID# : 2569196                      Test Start : 11/29/2017 @ 06:01  
Canister Type : Charcoal Canister 3 inch      Test Stop : 12/01/2017 @ 06:01  
Location : 1st FL-Rm 19                      Received: 12/11/2017 @ 14:14  
Radon Level : **N/C pCi/L**                      Analyzed: 12/12/2017 @ 15:52

Canister ID# : 2569180                      Test Start : 11/29/2017 @ 05:31  
Canister Type : Charcoal Canister 3 inch      Test Stop : 12/01/2017 @ 05:31  
Location : 1st FL-Office Manager              Received: 12/11/2017 @ 14:14  
Radon Level : **N/C pCi/L**                      Analyzed: 12/12/2017 @ 13:44

Canister ID# : 2569190                      Test Start : 11/29/2017 @ 05:57  
Canister Type : Charcoal Canister 3 inch      Test Stop : 12/01/2017 @ 05:58  
Location : 1st FL-Rm 6                      Received: 12/11/2017 @ 14:14  
Radon Level : **N/C pCi/L**                      Analyzed: 12/12/2017 @ 15:37

Canister ID# : 2569140                      Test Start : 11/29/2017 @ 05:39  
Canister Type : Charcoal Canister 3 inch      Test Stop : 12/01/2017 @ 05:42  
Location : 1st FL-Rm 17                      Received: 12/11/2017 @ 14:14  
Radon Level : **N/C pCi/L**                      Analyzed: 12/12/2017 @ 13:25

Canister ID# : 2569201                      Test Start : 11/29/2017 @ 06:16  
Canister Type : Charcoal Canister 3 inch      Test Stop : 12/01/2017 @ 06:17  
Location : 1st FL-Rm 26                      Received: 12/11/2017 @ 14:14  
Radon Level : **N/C pCi/L**                      Analyzed: 12/12/2017 @ 13:44

Canister ID# : 2569176                      Test Start : 11/29/2017 @ 05:32  
Canister Type : Charcoal Canister 3 inch      Test Stop : 12/01/2017 @ 05:32  
Location : 1st FL-Health Rm                      Received: 12/11/2017 @ 14:14  
Radon Level : **N/C pCi/L**                      Analyzed: 12/12/2017 @ 13:44

Canister ID# : 2569147                      Test Start : 11/29/2017 @ 06:10  
Canister Type : Charcoal Canister 3 inch      Test Stop : 12/01/2017 @ 06:10  
Location : 1st FL-Rm 3                      Received: 12/11/2017 @ 14:14  
Radon Level : **N/C pCi/L**                      Analyzed: 12/12/2017 @ 13:44



*Andreas C. George*

Andreas C. George  
Radon Measurement Specialist  
NJ MES 11089

*Dante Galan*

Dante Galan  
Laboratory Director

NRSB ARL0001  
NYS ELAP ID: 10806  
PADEP ID: 0346  
NJDEP ID: NY933  
NJ MEB 90036  
FL DOH RB1609  
IL RNL2000201

Site Radon Inspection Report

Date : 12/11/2017

Canister ID# : 2569185                      Test Start : 11/29/2017 @ 06:25  
Canister Type : Charcoal Canister 3 inch      Test Stop : 12/01/2017 @ 06:32  
Location : 1st FL-Rm 171                      Received: 12/11/2017 @ 14:14  
Radon Level : **N/C pCi/L**                      Analyzed: 12/12/2017 @ 13:25

Canister ID# : 2569183                      Test Start : 11/29/2017 @ 06:13  
Canister Type : Charcoal Canister 3 inch      Test Stop : 12/01/2017 @ 06:13  
Location : 1st FL-Rm 2                      Received: 12/11/2017 @ 14:14  
Radon Level : **N/C pCi/L**                      Analyzed: 12/12/2017 @ 13:25

Canister ID# : 2588951                      Test Start : 11/29/2017 @ 06:17  
Canister Type : Charcoal Canister 3 inch      Test Stop : 12/01/2017 @ 06:20  
Location : 1st FL-Rm 21 Comp                  Received: 12/11/2017 @ 14:14  
Radon Level : **N/C pCi/L**                      Analyzed: 12/12/2017 @ 13:44

Canister ID# : 2588962                      Test Start : 11/29/2017 @ 06:15  
Canister Type : Charcoal Canister 3 inch      Test Stop : 12/01/2017 @ 06:17  
Location : 1st FL-Rm 161-Blank                Received: 12/11/2017 @ 14:14  
Radon Level : **N/C pCi/L**                      Analyzed: 12/12/2017 @ 16:23

Canister ID# : 2589055                      Test Start : 11/29/2017 @ 06:23  
Canister Type : Charcoal Canister 3 inch      Test Stop : 12/01/2017 @ 06:28  
Location : 1st FL-Gym 2                      Received: 12/11/2017 @ 14:14  
Radon Level : **N/C pCi/L**                      Analyzed: 12/12/2017 @ 16:23

Canister ID# : 2570858                      Test Start : 11/29/2017 @ 06:11  
Canister Type : Charcoal Canister 3 inch      Test Stop : 12/01/2017 @ 06:11  
Location : 1st FL-Rm 27                      Received: 12/11/2017 @ 14:14  
Radon Level : **N/C pCi/L**                      Analyzed: 12/12/2017 @ 14:10

Canister ID# : 2570806                      Test Start : 11/29/2017 @ 06:07  
Canister Type : Charcoal Canister 3 inch      Test Stop : 12/01/2017 @ 06:07  
Location : 1st FL-"E" Commons                Received: 12/11/2017 @ 14:14  
Radon Level : **N/C pCi/L**                      Analyzed: 12/12/2017 @ 13:44

Canister ID# : 2570747                      Test Start : 11/29/2017 @ 05:55  
Canister Type : Charcoal Canister 3 inch      Test Stop : 12/01/2017 @ 06:08  
Location : 1st FL-Rm 20                      Received: 12/11/2017 @ 14:14  
Radon Level : **N/C pCi/L**                      Analyzed: 12/12/2017 @ 14:10

Canister ID# : 2570760                      Test Start : 11/29/2017 @ 06:19  
Canister Type : Charcoal Canister 3 inch      Test Stop : 12/01/2017 @ 06:19  
Location : 1st FL-Rm 9                      Received: 12/11/2017 @ 14:14  
Radon Level : **N/C pCi/L**                      Analyzed: 12/12/2017 @ 13:44



*Andreas C. George*

Andreas C. George  
Radon Measurement Specialist  
NJ MES 11089

*Dante Galan*

Dante Galan  
Laboratory Director

NRSB ARL0001  
NYS ELAP ID: 10806  
PADEP ID: 0346  
NJDEP ID: NY933  
NJ MEB 90036  
FL DOH RB1609  
IL RNL2000201

Site Radon Inspection Report

Date : 12/11/2017

Canister ID# : 2570781 Test Start : 11/29/2017 @ 06:10  
Canister Type : Charcoal Canister 3 inch Test Stop : 12/01/2017 @ 06:12  
Location : 1st FL-Rm 160/159 Received: 12/11/2017 @ 14:14  
Radon Level : **N/C pCi/L** Analyzed: 12/12/2017 @ 13:25

Canister ID# : 2570816 Test Start : 11/29/2017 @ 06:15  
Canister Type : Charcoal Canister 3 inch Test Stop : 12/01/2017 @ 06:16  
Location : 1st FL-Rm 158 Received: 12/11/2017 @ 14:14  
Radon Level : **N/C pCi/L** Analyzed: 12/12/2017 @ 13:44

Canister ID# : 2570854 Test Start : 11/29/2017 @ 06:12  
Canister Type : Charcoal Canister 3 inch Test Stop : 12/01/2017 @ 06:16  
Location : 1st FL-Rm 10 Received: 12/11/2017 @ 14:14  
Radon Level : **N/C pCi/L** Analyzed: 12/12/2017 @ 13:44

Canister ID# : 2570742 Test Start : 11/29/2017 @ 06:02  
Canister Type : Charcoal Canister 3 inch Test Stop : 12/01/2017 @ 06:11  
Location : 1st FL-Rm 12 Received: 12/11/2017 @ 14:14  
Radon Level : **N/C pCi/L** Analyzed: 12/12/2017 @ 16:23

Canister ID# : 2570811 Test Start : 11/29/2017 @ 06:27  
Canister Type : Charcoal Canister 3 inch Test Stop : 12/01/2017 @ 06:27  
Location : 1st FL-Rm 7 Received: 12/11/2017 @ 14:14  
Radon Level : **N/C pCi/L** Analyzed: 12/12/2017 @ 13:44

Canister ID# : 2570848 Test Start : 12/31-4714 @ 00:00  
Canister Type : Charcoal Canister 3 inch Test Stop : 10/09/2017 @ 15:13  
Location : Crawl Space Received: 12/11/2017 @ 14:14  
Radon Level : **No Result** Analyzed: 12/12/2017 @ 13:44  
Radon concentration cannot be calculated due to detector not received in time.

Error for Measurement is:  $\pm$  pCi/L

Canister ID# : 2570814 Test Start : 11/29/2017 @ 05:26  
Canister Type : Charcoal Canister 3 inch Test Stop : 12/01/2017 @ 05:27  
Location : 1st FL- Office Received: 12/11/2017 @ 14:14  
Radon Level : **N/C pCi/L** Analyzed: 12/12/2017 @ 15:52

Canister ID# : 2570790 Test Start : 11/29/2017 @ 06:03  
Canister Type : Charcoal Canister 3 inch Test Stop : 12/01/2017 @ 06:04  
Location : 1st FL-Media 2 Received: 12/11/2017 @ 14:14  
Radon Level : **N/C pCi/L** Analyzed: 12/12/2017 @ 16:23



*Andreas C. George*

Andreas C. George  
Radon Measurement Specialist  
NJ MES 11089

*Dante Galan*

Dante Galan  
Laboratory Director

NRSB ARL0001  
NYS ELAP ID: 10806  
PADEP ID: 0346  
NJDEP ID: NY933  
NJ MEB 90036  
FL DOH RB1609  
IL RNL2000201



Site Radon Inspection Report

Date : 12/11/2017

Canister ID# :	2570751	Test Start :	11/29/2017 @ 06:05
Canister Type :	Charcoal Canister 3 inch	Test Stop :	12/01/2017 @ 06:05
Location :	1st FL-Rm 30	Received:	12/11/2017 @ 14:14
Radon Level :	<b>N/C pCi/L</b>	Analyzed:	12/12/2017 @ 13:25
Canister ID# :	2570782	Test Start :	11/29/2017 @ 05:58
Canister Type :	Charcoal Canister 3 inch	Test Stop :	12/01/2017 @ 06:09
Location :	1st FL-Rm 13	Received:	12/11/2017 @ 14:14
Radon Level :	<b>N/C pCi/L</b>	Analyzed:	12/12/2017 @ 16:44
Canister ID# :	2570833	Test Start :	11/29/2017 @ 06:22
Canister Type :	Charcoal Canister 3 inch	Test Stop :	12/01/2017 @ 06:22
Location :	1st FL-Rm 24	Received:	12/11/2017 @ 14:14
Radon Level :	<b>N/C pCi/L</b>	Analyzed:	12/12/2017 @ 13:25
Canister ID# :	2570776	Test Start :	11/29/2017 @ 06:20
Canister Type :	Charcoal Canister 3 inch	Test Stop :	12/01/2017 @ 06:20
Location :	1st FL-Rm 25	Received:	12/11/2017 @ 14:14
Radon Level :	<b>N/C pCi/L</b>	Analyzed:	12/12/2017 @ 14:10
Canister ID# :	2570780	Test Start :	11/29/2017 @ 05:57
Canister Type :	Charcoal Canister 3 inch	Test Stop :	12/01/2017 @ 05:58
Location :	1st FL-Rm 6	Received:	12/11/2017 @ 14:14
Radon Level :	<b>N/C pCi/L</b>	Analyzed:	12/12/2017 @ 16:23
Canister ID# :	2570810	Test Start :	11/29/2017 @ 06:02
Canister Type :	Charcoal Canister 3 inch	Test Stop :	12/01/2017 @ 06:02
Location :	1st FL-Rm 5	Received:	12/11/2017 @ 14:14
Radon Level :	<b>N/C pCi/L</b>	Analyzed:	12/12/2017 @ 15:52
Canister ID# :	2570819	Test Start :	11/29/2017 @ 05:41
Canister Type :	Charcoal Canister 3 inch	Test Stop :	12/01/2017 @ 05:44
Location :	1st FL-Rm 16	Received:	12/11/2017 @ 14:14
Radon Level :	<b>N/C pCi/L</b>	Analyzed:	12/12/2017 @ 16:23
Canister ID# :	2570840	Test Start :	11/29/2017 @ 06:06
Canister Type :	Charcoal Canister 3 inch	Test Stop :	12/01/2017 @ 06:06
Location :	1st FL-Rm 31	Received:	12/11/2017 @ 14:14
Radon Level :	<b>N/C pCi/L</b>	Analyzed:	12/12/2017 @ 13:24
Canister ID# :	2570800	Test Start :	11/29/2017 @ 06:22
Canister Type :	Charcoal Canister 3 inch	Test Stop :	12/01/2017 @ 06:22
Location :	1st FL-Rm 8	Received:	12/11/2017 @ 14:14
Radon Level :	<b>N/C pCi/L</b>	Analyzed:	12/12/2017 @ 16:23



*Andreas C. George*

Andreas C. George  
Radon Measurement Specialist  
NJ MES 11089

*Dante Galan*

Dante Galan  
Laboratory Director

NRSB ARL0001  
NYS ELAP ID: 10806  
PADEP ID: 0346  
NJDEP ID: NY933  
NJ MEB 90036  
FL DOH RB1609  
IL RNL2000201

Site Radon Inspection Report

Date : 12/11/2017

Canister ID# :	2570789	Test Start :	11/29/2017 @ 06:10
Canister Type :	Charcoal Canister 3 inch	Test Stop :	12/01/2017 @ 06:10
Location :	1st FL-Rm 28- Blank	Received:	12/11/2017 @ 14:14
Radon Level :	<b>N/C pCi/L</b>	Analyzed:	12/12/2017 @ 16:23
Canister ID# :	2570827	Test Start :	11/29/2017 @ 05:47
Canister Type :	Charcoal Canister 3 inch	Test Stop :	12/01/2017 @ 05:49
Location :	1st FL-Rm 14	Received:	12/11/2017 @ 14:14
Radon Level :	<b>N/C pCi/L</b>	Analyzed:	12/12/2017 @ 15:22
Canister ID# :	2570843	Test Start :	11/29/2017 @ 06:18
Canister Type :	Charcoal Canister 3 inch	Test Stop :	12/01/2017 @ 06:19
Location :	1st FL-Resource Rm "B4"	Received:	12/11/2017 @ 14:14
Radon Level :	<b>N/C pCi/L</b>	Analyzed:	12/12/2017 @ 14:10
Canister ID# :	2570864	Test Start :	11/29/2017 @ 06:06
Canister Type :	Charcoal Canister 3 inch	Test Stop :	12/01/2017 @ 06:15
Location :	1st FL-Rm 11	Received:	12/11/2017 @ 14:14
Radon Level :	<b>N/C pCi/L</b>	Analyzed:	12/12/2017 @ 16:23
Canister ID# :	2570764	Test Start :	11/29/2017 @ 06:08
Canister Type :	Charcoal Canister 3 inch	Test Stop :	12/01/2017 @ 06:09
Location :	1st FL-Computer Rm	Received:	12/11/2017 @ 14:14
Radon Level :	<b>N/C pCi/L</b>	Analyzed:	12/12/2017 @ 13:25
Canister ID# :	2570830	Test Start :	11/29/2017 @ 06:22
Canister Type :	Charcoal Canister 3 inch	Test Stop :	12/01/2017 @ 06:22
Location :	1st FL-Rm 24-Blank	Received:	12/11/2017 @ 14:14
Radon Level :	<b>N/C pCi/L</b>	Analyzed:	12/12/2017 @ 15:37
Canister ID# :	2570845	Test Start :	11/29/2017 @ 06:16
Canister Type :	Charcoal Canister 3 inch	Test Stop :	12/01/2017 @ 06:17
Location :	1st FL-Rm 157/156	Received:	12/11/2017 @ 14:14
Radon Level :	<b>N/C pCi/L</b>	Analyzed:	12/12/2017 @ 15:52
Canister ID# :	2570851	Test Start :	11/29/2017 @ 06:00
Canister Type :	Charcoal Canister 3 inch	Test Stop :	12/01/2017 @ 06:01
Location :	1st FL-Media 1	Received:	12/11/2017 @ 14:14
Radon Level :	<b>N/C pCi/L</b>	Analyzed:	12/12/2017 @ 14:10



*Andreas C. George*

Andreas C. George  
Radon Measurement Specialist  
NJ MES 11089

*Dante Galan*

Dante Galan  
Laboratory Director

NRSB ARL0001  
NYS ELAP ID: 10806  
PADEP ID: 0346  
NJDEP ID: NY933  
NJ MEB 90036  
FL DOH RB1609  
IL RNL2000201



Site Radon Inspection Report

Date : 12/11/2017

The results indicate that at least one testing device registered at or above the United States Environmental Protection Agency (EPA) action level of 4.0 picoCuries per liter of air (pCi/L). The EPA recommends mitigation if the average of two short-term tests taken in the lowest level of the building suitable for occupancy show radon levels that are equal to or greater than 4.0 pCi/L.

For information on how to reduce radon levels in the building, please review the EPA booklet: Consumer's Guide to Radon Reduction ([www.epa.gov/radon/pdfs/consguid.pdf](http://www.epa.gov/radon/pdfs/consguid.pdf)) and contact your state health department. The EPA maintains a radon information website, including copies of its publications, at [www.epa.gov/iaq/radon](http://www.epa.gov/iaq/radon).

**For New Jersey clients:** Please see the attached guidance document entitled Radon Testing and Mitigation: The Basics for further information.

**For New York clients:** If the radon level of one or more testing devices is equal to or exceeds 20 pCi/L please contact the New York State Department of Health, Bureau of Environmental Radiation Protection, for technical advice and assistance at 518-402-7556 or toll free 1-800-458-1158.

---

**PLEDGE OF ASSURED QUALITY**

All procedures used for generating this report are in complete accordance with the current EPA protocols for the analysis of radon in air (EPA 402-R-92-004). The analytical results relate only to the samples tested, in the condition received by the lab, and that calculations were based upon the information supplied by client. RTCA and its personnel do not assume responsibility or liability, collectively and individually, for analysis results when detectors have been improperly handled or placed by the consumer, nor does RTCA and its personnel accept responsibility for any financial or health consequences of subsequent action or lack of action, taken by the customer or its consultants based on RTCA-provided results.



Andreas C. George  
Radon Measurement Specialist  
NJ MES 11089

Dante Galan  
Laboratory Director

NRSB ARL0001  
NYS ELAP ID: 10806  
PADEP ID: 0346  
NJDEP ID: NY933  
NJ MEB 90036  
FL DOH RB1609  
IL RNL2000201