

Site Radon Inspection Report

Date : 11/12/2018

Mr. Bryan Hogan
MEDFORD SCHOOL DISTRICT
815 South Oakdale Avenue
Medford, OR 97501-

Client: Jackson E.S.
Test Location: 713 Summit Avenue
Medford, OR 97501-

Individual Canister Results

Canister ID# : 2612019
Canister Type : Charcoal Canister 3 inch
Location : 1st FL=Media Ctr. 130A
Radon Level : 0.1 pCi/L
Error for Measurement is: \pm 0.5 pCi/L

Test Start : 11/05/2018 @ 06:01
Test Stop : 11/07/2018 @ 06:05
Received: 11/12/2018 @ 11:12
Analyzed: 11/12/2018 @ 10:57

Canister ID# : 2612025
Canister Type : Charcoal Canister 3 inch
Location : 1st FL=Principal's Off.
Radon Level : 0.7 pCi/L
Error for Measurement is: \pm 0.4 pCi/L

Test Start : 11/05/2018 @ 05:19
Test Stop : 11/07/2018 @ 05:24
Received: 11/12/2018 @ 11:12
Analyzed: 11/12/2018 @ 10:56

Canister ID# : 2612072
Canister Type : Charcoal Canister 3 inch
Location : 1st FL=Rm 141
Radon Level : 15.4 pCi/L
Error for Measurement is: \pm 0.7 pCi/L

Test Start : 11/05/2018 @ 11:00
Test Stop : 11/07/2018 @ 11:15
Received: 11/12/2018 @ 11:12
Analyzed: 11/12/2018 @ 11:30

This is a quality control test known as a spike. This canister has never been on the school site.

Canister ID# : 2612073
Canister Type : Charcoal Canister 3 inch
Location : 1st FL=Staff Break Rm
Radon Level : 0.1 pCi/L
Error for Measurement is: \pm 0.4 pCi/L

Test Start : 11/05/2018 @ 05:23
Test Stop : 11/07/2018 @ 05:26
Received: 11/12/2018 @ 11:12
Analyzed: 11/12/2018 @ 10:56

Canister ID# : 2612118
Canister Type : Charcoal Canister 3 inch
Location : 1st FL=Health Rm D
Radon Level : 0.1 pCi/L
Error for Measurement is: \pm 0.3 pCi/L

Test Start : 11/05/2018 @ 06:06
Test Stop : 11/07/2018 @ 06:12
Received: 11/12/2018 @ 11:12
Analyzed: 11/12/2018 @ 10:56

Canister ID# : 2612137
Canister Type : Charcoal Canister 3 inch
Location : 1st FL=Main Office
Radon Level : 1.3 pCi/L
Error for Measurement is: \pm 0.5 pCi/L

Test Start : 11/05/2018 @ 05:18
Test Stop : 11/07/2018 @ 05:23
Received: 11/12/2018 @ 11:12
Analyzed: 11/12/2018 @ 10:54



Andreas C. George

Andreas C. George
Radon Measurement Specialist
NJ MES 11089

Dante Galan

Dante Galan
Laboratory Director

NRSB ARL0001
NYS ELAP ID: 10806
PADEP ID: 0346
NJDEP ID: NY933
NJ MEB 90036
FL DOH RB1609
IL RNL2000201

Site Radon Inspection Report

Date : 11/12/2018

Mr. Bryan Hogan
MEDFORD SCHOOL DISTRICT
815 South Oakdale Avenue
Medford, OR 97501-

Client: Jackson E.S.
Test Location: 713 Summit Avenue
Medford, OR 97501-

Individual Canister Results

Canister ID# : 2612147 Test Start : 11/05/2018 @ 06:07
Canister Type : Charcoal Canister 3 inch Test Stop : 11/07/2018 @ 06:13
Location : 1st FL=Rm 141 Received: 11/12/2018 @ 11:12
Radon Level : 0.8 pCi/L Analyzed: 11/12/2018 @ 11:30
Error for Measurement is: \pm 0.4 pCi/L

Canister ID# : 2612148 Test Start : 11/05/2018 @ 06:08
Canister Type : Charcoal Canister 3 inch Test Stop : 11/07/2018 @ 06:11
Location : 1st FL=Rm 122 BL Received: 11/12/2018 @ 11:12
Radon Level : 0.1 pCi/L Analyzed: 11/12/2018 @ 10:54
Error for Measurement is: \pm 0.2 pCi/L

Canister ID# : 2619337 Test Start : 11/05/2018 @ 05:41
Canister Type : Charcoal Canister 3 inch Test Stop : 11/07/2018 @ 05:41
Location : 1st FL=Rm 145 DP Received: 11/12/2018 @ 11:12
Radon Level : 0.3 pCi/L Analyzed: 11/12/2018 @ 10:56
Error for Measurement is: \pm 0.4 pCi/L

Canister ID# : 2619338 Test Start : 11/05/2018 @ 05:38
Canister Type : Charcoal Canister 3 inch Test Stop : 11/07/2018 @ 05:38
Location : 1st FL=Rm 144 BL Received: 11/12/2018 @ 11:12
Radon Level : 0.2 pCi/L Analyzed: 11/12/2018 @ 10:56
Error for Measurement is: \pm 0.4 pCi/L

Canister ID# : 2619355 Test Start : 11/05/2018 @ 05:41
Canister Type : Charcoal Canister 3 inch Test Stop : 11/07/2018 @ 05:41
Location : 1st FL=Rm 145 Received: 11/12/2018 @ 11:12
Radon Level : 0.1 pCi/L Analyzed: 11/12/2018 @ 10:56
Error for Measurement is: \pm 0.6 pCi/L

Canister ID# : 2619406 Test Start : 11/05/2018 @ 06:11
Canister Type : Charcoal Canister 3 inch Test Stop : 11/07/2018 @ 06:15
Location : 1st FL=Health Rm G Received: 11/12/2018 @ 11:12
Radon Level : 0.1 pCi/L Analyzed: 11/12/2018 @ 10:54
Error for Measurement is: \pm 0.5 pCi/L



Andreas C. George

Andreas C. George
Radon Measurement Specialist
NJ MES 11089

Dante Galan

Dante Galan
Laboratory Director

NRSB ARL0001
NYS ELAP ID: 10806
PADEP ID: 0346
NJDEP ID: NY933
NJ MEB 90036
FL DOH RB1609
IL RNL2000201

Site Radon Inspection Report

Date : 11/12/2018

Mr. Bryan Hogan
MEDFORD SCHOOL DISTRICT
815 South Oakdale Avenue
Medford, OR 97501-

Client: Jackson E.S.
Test Location: 713 Summit Avenue
Medford, OR 97501-

Individual Canister Results

Canister ID# : 2619433 Test Start : 11/05/2018 @ 06:14
Canister Type : Charcoal Canister 3 inch Test Stop : 11/07/2018 @ 06:21
Location : 1st FL=Gym 2 Received: 11/12/2018 @ 11:12
Radon Level : 0.1 pCi/L Analyzed: 11/12/2018 @ 10:54
Error for Measurement is: ± 0.5 pCi/L

Canister ID# : 2619434 Test Start : 11/05/2018 @ 05:59
Canister Type : Charcoal Canister 3 inch Test Stop : 11/07/2018 @ 06:04
Location : 1st FL=Media Ctr. 2 Received: 11/12/2018 @ 11:12
Radon Level : 0.1 pCi/L Analyzed: 11/12/2018 @ 10:56
Error for Measurement is: ± 0.8 pCi/L

Canister ID# : 2619448 Test Start : 11/05/2018 @ 06:09
Canister Type : Charcoal Canister 3 inch Test Stop : 11/07/2018 @ 06:14
Location : 1st FL=Health Rm F Received: 11/12/2018 @ 11:12
Radon Level : 0.3 pCi/L Analyzed: 11/12/2018 @ 10:54
Error for Measurement is: ± 0.5 pCi/L

Canister ID# : 2619455 Test Start : 11/05/2018 @ 06:03
Canister Type : Charcoal Canister 3 inch Test Stop : 11/07/2018 @ 06:09
Location : 1st FL=Cafeteria DP Received: 11/12/2018 @ 11:12
Radon Level : 0.4 pCi/L Analyzed: 11/12/2018 @ 11:30
Error for Measurement is: ± 0.4 pCi/L

Canister ID# : 2619457 Test Start : 11/05/2018 @ 06:12
Canister Type : Charcoal Canister 3 inch Test Stop : 11/07/2018 @ 06:15
Location : 1st FL=Rm 113 Received: 11/12/2018 @ 11:12
Radon Level : 0.2 pCi/L Analyzed: 11/12/2018 @ 11:30
Error for Measurement is: ± 0.3 pCi/L

Canister ID# : 2619467 Test Start : 11/05/2018 @ 11:00
Canister Type : Charcoal Canister 3 inch Test Stop : 11/07/2018 @ 11:15
Location : 1st FL=Rm 140 Received: 11/12/2018 @ 11:12
Radon Level : 15.3 pCi/L Analyzed: 11/12/2018 @ 11:27
Error for Measurement is: ± 0.8 pCi/L

This is a quality control test known as a spike. This canister has never been on the school site.



Andreas C. George

Andreas C. George
Radon Measurement Specialist
NJ MES 11089

Dante Galan

Dante Galan
Laboratory Director

NRSB ARL0001
NYS ELAP ID: 10806
PADEP ID: 0346
NJDEP ID: NY933
NJ MEB 90036
FL DOH RB1609
IL RNL2000201

Site Radon Inspection Report

Date : 11/12/2018

Mr. Bryan Hogan
MEDFORD SCHOOL DISTRICT
815 South Oakdale Avenue
Medford, OR 97501-

Client: Jackson E.S.
Test Location: 713 Summit Avenue
Medford, OR 97501-

Individual Canister Results

Canister ID# : 2679159 Test Start : 11/05/2018 @ 06:02
Canister Type : Charcoal Canister 3 inch Test Stop : 11/07/2018 @ 06:06
Location : 1st FL=Media Ctr. 130B Received: 11/12/2018 @ 11:12
Radon Level : 0.1 pCi/L Analyzed: 11/12/2018 @ 13:30
Error for Measurement is: ± 0.6 pCi/L

Canister ID# : 2679169 Test Start : 11/05/2018 @ 06:02
Canister Type : Charcoal Canister 3 inch Test Stop : 11/07/2018 @ 06:07
Location : 1st FL=Health Rm A Received: 11/12/2018 @ 11:12
Radon Level : 0.1 pCi/L Analyzed: 11/12/2018 @ 14:08
Error for Measurement is: ± 0.8 pCi/L

Canister ID# : 2679222 Test Start : 11/05/2018 @ 06:11
Canister Type : Charcoal Canister 3 inch Test Stop : 11/07/2018 @ 06:15
Location : 1st FL=Rm 110 Received: 11/12/2018 @ 11:12
Radon Level : 0.2 pCi/L Analyzed: 11/12/2018 @ 12:29
Error for Measurement is: ± 0.5 pCi/L

Canister ID# : 2679241 Test Start : 11/05/2018 @ 06:03
Canister Type : Charcoal Canister 3 inch Test Stop : 11/07/2018 @ 06:09
Location : 1st FL=Health Rm B Received: 11/12/2018 @ 11:12
Radon Level : 0.1 pCi/L Analyzed: 11/12/2018 @ 10:38
Error for Measurement is: ± 0.2 pCi/L

Canister ID# : 2679250 Test Start : 11/05/2018 @ 06:04
Canister Type : Charcoal Canister 3 inch Test Stop : 11/07/2018 @ 06:08
Location : 1st FL=Rm 120 B Received: 11/12/2018 @ 11:12
Radon Level : 0.3 pCi/L Analyzed: 11/12/2018 @ 14:08
Error for Measurement is: ± 0.5 pCi/L

Canister ID# : 2679255 Test Start : 11/05/2018 @ 06:04
Canister Type : Charcoal Canister 3 inch Test Stop : 11/07/2018 @ 06:07
Location : 1st FL=Media Ctr. 132 Received: 11/12/2018 @ 11:12
Radon Level : 0.1 pCi/L Analyzed: 11/12/2018 @ 13:52
Error for Measurement is: ± 0.4 pCi/L



Andreas C. George

Andreas C. George
Radon Measurement Specialist
NJ MES 11089

Dante Galan

Dante Galan
Laboratory Director

NRSB ARL0001
NYS ELAP ID: 10806
PADEP ID: 0346
NJDEP ID: NY933
NJ MEB 90036
FL DOH RB1609
IL RNL2000201

Site Radon Inspection Report

Date : 11/12/2018

Mr. Bryan Hogan
MEDFORD SCHOOL DISTRICT
815 South Oakdale Avenue
Medford, OR 97501-

Client: Jackson E.S.
Test Location: 713 Summit Avenue
Medford, OR 97501-

Individual Canister Results

Canister ID# : 2679261 Test Start : 11/05/2018 @ 05:57
Canister Type : Charcoal Canister 3 inch Test Stop : 11/07/2018 @ 06:03
Location : 1st FL=Media Ctr. 1 Received: 11/12/2018 @ 11:12
Radon Level : 0.1 pCi/L Analyzed: 11/12/2018 @ 14:10
Error for Measurement is: ± 0.3 pCi/L

Canister ID# : 2679266 Test Start : 11/05/2018 @ 06:06
Canister Type : Charcoal Canister 3 inch Test Stop : 11/07/2018 @ 06:12
Location : 1st FL=Health Rm D DP Received: 11/12/2018 @ 11:12
Radon Level : 0.6 pCi/L Analyzed: 11/12/2018 @ 13:50
Error for Measurement is: ± 0.4 pCi/L

Canister ID# : 2679275 Test Start : 11/05/2018 @ 06:00
Canister Type : Charcoal Canister 3 inch Test Stop : 11/07/2018 @ 06:08
Location : 1st FL=Rm 143 Received: 11/12/2018 @ 11:12
Radon Level : 0.8 pCi/L Analyzed: 11/12/2018 @ 11:28
Error for Measurement is: ± 0.5 pCi/L

Canister ID# : 2679283 Test Start : 11/05/2018 @ 06:08
Canister Type : Charcoal Canister 3 inch Test Stop : 11/07/2018 @ 06:13
Location : 1st FL=Health Rm E Received: 11/12/2018 @ 11:12
Radon Level : 0.1 pCi/L Analyzed: 11/12/2018 @ 10:38
Error for Measurement is: ± 0.4 pCi/L

Canister ID# : 2679290 Test Start : 11/05/2018 @ 06:16
Canister Type : Charcoal Canister 3 inch Test Stop : 11/07/2018 @ 06:21
Location : 1st FL=Gym DP Received: 11/12/2018 @ 11:12
Radon Level : 0.1 pCi/L Analyzed: 11/12/2018 @ 10:37
Error for Measurement is: ± 0.2 pCi/L

Canister ID# : 2680924 Test Start : 11/05/2018 @ 06:16
Canister Type : Charcoal Canister 3 inch Test Stop : 11/07/2018 @ 06:17
Location : 1st FL=Rm 112 Received: 11/12/2018 @ 11:12
Radon Level : 0.1 pCi/L Analyzed: 11/12/2018 @ 13:31
Error for Measurement is: ± 0.6 pCi/L



Andreas C. George

Dante Galan

Andreas C. George
Radon Measurement Specialist
NJ MES 11089

Dante Galan
Laboratory Director

NRSB ARL0001
NYS ELAP ID: 10806
PADEP ID: 0346
NJDEP ID: NY933
NJ MEB 90036
FL DOH RB1609
IL RNL2000201

Site Radon Inspection Report

Date : 11/12/2018

Mr. Bryan Hogan
MEDFORD SCHOOL DISTRICT
815 South Oakdale Avenue
Medford, OR 97501-

Client: Jackson E.S.
Test Location: 713 Summit Avenue
Medford, OR 97501-

Individual Canister Results

Canister ID# : 2680940 Test Start : 11/05/2018 @ 05:31
Canister Type : Charcoal Canister 3 inch Test Stop : 11/07/2018 @ 05:28
Location : 1st FL=Commons 2 Received: 11/12/2018 @ 11:12
Radon Level : 0.2 pCi/L Analyzed: 11/12/2018 @ 14:11
Error for Measurement is: ± 0.5 pCi/L

Canister ID# : 2681389 Test Start : 11/05/2018 @ 06:00
Canister Type : Charcoal Canister 3 inch Test Stop : 11/07/2018 @ 06:08
Location : 1st FL=Cafeteria Received: 11/12/2018 @ 11:12
Radon Level : 0.2 pCi/L Analyzed: 11/12/2018 @ 12:45
Error for Measurement is: ± 0.4 pCi/L

Canister ID# : 2681497 Test Start : 11/05/2018 @ 06:07
Canister Type : Charcoal Canister 3 inch Test Stop : 11/07/2018 @ 06:10
Location : 1st FL=Rm 122 Received: 11/12/2018 @ 11:12
Radon Level : 0.3 pCi/L Analyzed: 11/12/2018 @ 13:33
Error for Measurement is: ± 0.4 pCi/L

Canister ID# : 2681511 Test Start : 11/05/2018 @ 05:38
Canister Type : Charcoal Canister 3 inch Test Stop : 11/07/2018 @ 05:38
Location : 1st FL=Rm 144 Received: 11/12/2018 @ 11:12
Radon Level : 0.1 pCi/L Analyzed: 11/12/2018 @ 13:50
Error for Measurement is: ± 0.3 pCi/L

Canister ID# : 2681517 Test Start : 11/05/2018 @ 06:21
Canister Type : Charcoal Canister 3 inch Test Stop : 11/07/2018 @ 06:21
Location : 1st FL=Rm 110B Received: 11/12/2018 @ 11:12
Radon Level : 0.5 pCi/L Analyzed: 11/12/2018 @ 13:50
Error for Measurement is: ± 0.5 pCi/L

Canister ID# : 2681588 Test Start : 11/05/2018 @ 06:02
Canister Type : Charcoal Canister 3 inch Test Stop : 11/07/2018 @ 06:07
Location : 1st FL=Rm 120 Received: 11/12/2018 @ 11:12
Radon Level : 0.3 pCi/L Analyzed: 11/12/2018 @ 14:10
Error for Measurement is: ± 0.4 pCi/L



Andreas C. George

Andreas C. George
Radon Measurement Specialist
NJ MES 11089

Dante Galan

Dante Galan
Laboratory Director

NRSB ARL0001
NYS ELAP ID: 10806
PADEP ID: 0346
NJDEP ID: NY933
NJ MEB 90036
FL DOH RB1609
IL RNL2000201

Site Radon Inspection Report

Date : 11/12/2018

Mr. Bryan Hogan
MEDFORD SCHOOL DISTRICT
815 South Oakdale Avenue
Medford, OR 97501-

Client: Jackson E.S.
Test Location: 713 Summit Avenue
Medford, OR 97501-

Individual Canister Results

Canister ID# : 2681590 Test Start : 11/05/2018 @ 05:59
Canister Type : Charcoal Canister 3 inch Test Stop : 11/07/2018 @ 06:04
Location : 1st FL=Media Ctr. DP Received: 11/12/2018 @ 11:12
Radon Level : 0.2 pCi/L Analyzed: 11/12/2018 @ 14:10
Error for Measurement is: ± 0.4 pCi/L

Canister ID# : 2681598 Test Start : 11/05/2018 @ 06:04
Canister Type : Charcoal Canister 3 inch Test Stop : 11/07/2018 @ 06:11
Location : 1st FL=Rm 142 Received: 11/12/2018 @ 11:12
Radon Level : 0.6 pCi/L Analyzed: 11/12/2018 @ 14:25
Error for Measurement is: ± 0.5 pCi/L

Canister ID# : 2681603 Test Start : 11/05/2018 @ 06:15
Canister Type : Charcoal Canister 3 inch Test Stop : 11/07/2018 @ 06:18
Location : 1st FL=Rm 111 Received: 11/12/2018 @ 11:12
Radon Level : 0.2 pCi/L Analyzed: 11/12/2018 @ 14:10
Error for Measurement is: ± 0.3 pCi/L

Canister ID# : 2681615 Test Start : 11/05/2018 @ 06:12
Canister Type : Charcoal Canister 3 inch Test Stop : 11/07/2018 @ 06:13
Location : 1st FL=Rm 121 Received: 11/12/2018 @ 11:12
Radon Level : 0.3 pCi/L Analyzed: 11/12/2018 @ 14:10
Error for Measurement is: ± 0.4 pCi/L

Canister ID# : 2681627 Test Start : 11/05/2018 @ 06:00
Canister Type : Charcoal Canister 3 inch Test Stop : 11/07/2018 @ 06:05
Location : 1st FL=Rm 123 Received: 11/12/2018 @ 11:12
Radon Level : 0.4 pCi/L Analyzed: 11/12/2018 @ 14:08
Error for Measurement is: ± 0.4 pCi/L

Canister ID# : 2681628 Test Start : 11/05/2018 @ 06:11
Canister Type : Charcoal Canister 3 inch Test Stop : 11/07/2018 @ 06:20
Location : 1st FL=Gym 1 Received: 11/12/2018 @ 11:12
Radon Level : 0.1 pCi/L Analyzed: 11/12/2018 @ 11:30
Error for Measurement is: ± 0.3 pCi/L



Andreas C. George

Andreas C. George
Radon Measurement Specialist
NJ MES 11089

Dante Galan

Dante Galan
Laboratory Director

NRSB ARL0001
NYS ELAP ID: 10806
PADEP ID: 0346
NJDEP ID: NY933
NJ MEB 90036
FL DOH RB1609
IL RNL2000201

Site Radon Inspection Report

Date : 11/12/2018

Mr. Bryan Hogan
MEDFORD SCHOOL DISTRICT
815 South Oakdale Avenue
Medford, OR 97501-

Client: Jackson E.S.
Test Location: 713 Summit Avenue
Medford, OR 97501-

Individual Canister Results

Canister ID# : 2681640 Test Start : 11/05/2018 @ 06:02
Canister Type : Charcoal Canister 3 inch Test Stop : 11/07/2018 @ 06:08
Location : 1st FL=Health Rm A BL Received: 11/12/2018 @ 11:12
Radon Level : 0.1 pCi/L Analyzed: 11/12/2018 @ 14:10
Error for Measurement is: ± 0.2 pCi/L

Canister ID# : 2681649 Test Start : 11/05/2018 @ 05:21
Canister Type : Charcoal Canister 3 inch Test Stop : 11/07/2018 @ 05:25
Location : 1st FL=Health Rm Received: 11/12/2018 @ 11:12
Radon Level : 0.3 pCi/L Analyzed: 11/12/2018 @ 12:27
Error for Measurement is: ± 0.5 pCi/L

Canister ID# : 2681651 Test Start : 11/05/2018 @ 06:04
Canister Type : Charcoal Canister 3 inch Test Stop : 11/07/2018 @ 06:04
Location : 1st FL=Cafeteria BL Received: 11/12/2018 @ 11:12
Radon Level : 0.1 pCi/L Analyzed: 11/12/2018 @ 14:08
Error for Measurement is: ± 0.3 pCi/L

Canister ID# : 2681652 Test Start : 11/05/2018 @ 05:26
Canister Type : Charcoal Canister 3 inch Test Stop : 11/07/2018 @ 05:27
Location : 1st FL=Commons 1 Received: 11/12/2018 @ 11:12
Radon Level : 0.5 pCi/L Analyzed: 11/12/2018 @ 12:45
Error for Measurement is: ± 0.5 pCi/L

Canister ID# : 2681653 Test Start : 11/05/2018 @ 06:25
Canister Type : Charcoal Canister 3 inch Test Stop : 11/07/2018 @ 06:25
Location : 1st FL=Rm 105 Received: 11/12/2018 @ 11:12
Radon Level : 0.3 pCi/L Analyzed: 11/12/2018 @ 10:35
Error for Measurement is: ± 0.4 pCi/L

Canister ID# : 2681665 Test Start : 11/05/2018 @ 06:12
Canister Type : Charcoal Canister 3 inch Test Stop : 11/07/2018 @ 06:16
Location : 1st FL=Health Rm H Received: 11/12/2018 @ 11:12
Radon Level : 0.1 pCi/L Analyzed: 11/12/2018 @ 12:45
Error for Measurement is: ± 0.4 pCi/L



Andreas C. George

Andreas C. George
Radon Measurement Specialist
NJ MES 11089

Dante Galan

Dante Galan
Laboratory Director

NRSB ARL0001
NYS ELAP ID: 10806
PADEP ID: 0346
NJDEP ID: NY933
NJ MEB 90036
FL DOH RB1609
IL RNL2000201

Site Radon Inspection Report

Date : 11/12/2018

Mr. Bryan Hogan
MEDFORD SCHOOL DISTRICT
815 South Oakdale Avenue
Medford, OR 97501-

Client: Jackson E.S.
Test Location: 713 Summit Avenue
Medford, OR 97501-
Individual Canister Results

PLEDGE OF ASSURED QUALITY

All procedures used for generating this report are in complete accordance with the current EPA protocols for the analysis of radon in air (EPA 402-R-92-004). The analytical results relate only to the samples tested, in the condition received by the lab, and that calculations were based upon the information supplied by client. RTCA and its personnel do not assume responsibility or liability, collectively and individually, for analysis results when detectors have been improperly handled or placed by the consumer, nor does RTCA and its personnel accept responsibility for any financial or health consequences of subsequent action or lack of action, taken by the customer or its consultants based on RTCA-provided results.



Andreas C. George

Andreas C. George
Radon Measurement Specialist
NJ MES 11089

Dante Galan

Dante Galan
Laboratory Director

NRSB ARL0001
NYS ELAP ID: 10806
PADEP ID: 0346
NJDEP ID: NY933
NJ MEB 90036
FL DOH RB1609
IL RNL2000201