

Site Radon Inspection Report

Date : 11/11/2019

Bryan Hogan / Ron Havnear
MEDFORD SCHOOL DISTRICT
815 South Oakdale Avenue
Medford, OR 97501-

Client: Oak Grove E.S.
Test Location: 2838 West Main Street
Medford, OR 97501-

Individual Canister Results

Canister ID# :	2679226	Test Start :	11/04/2019 @ 05:49
Canister Type :	Charcoal Canister 3 inch	Test Stop :	11/06/2019 @ 05:59
Location :	1st FL=Staff Work Rm	Received:	11/11/2019 @ 09:45
Radon Level :	0.9 pCi/L	Analyzed:	11/12/2019 @ 10:19
Error for Measurement is: ±	0.5 pCi/L		

Canister ID# :	2704119	Test Start :	11/04/2019 @ 06:13
Canister Type :	Charcoal Canister 3 inch	Test Stop :	11/06/2019 @ 06:15
Location :	1st FL = Rm 07	Received:	11/11/2019 @ 09:45
Radon Level :	0.4 pCi/L	Analyzed:	11/12/2019 @ 10:22
Error for Measurement is: ±	0.6 pCi/L		

Canister ID# :	2704122	Test Start :	11/04/2019 @ 05:32
Canister Type :	Charcoal Canister 3 inch	Test Stop :	11/06/2019 @ 05:38
Location :	1st FL=Main Office	Received:	11/11/2019 @ 09:45
Radon Level :	0.5 pCi/L	Analyzed:	11/11/2019 @ 11:22
Error for Measurement is: ±	0.5 pCi/L		

Canister ID# :	2704124	Test Start :	11/04/2019 @ 05:56
Canister Type :	Charcoal Canister 3 inch	Test Stop :	11/06/2019 @ 06:02
Location :	1st FL = Rm 17	Received:	11/11/2019 @ 09:45
Radon Level :	0.6 pCi/L	Analyzed:	11/12/2019 @ 10:06
Error for Measurement is: ±	0.5 pCi/L		

Canister ID# :	2704125	Test Start :	11/04/2019 @ 06:00
Canister Type :	Charcoal Canister 3 inch	Test Stop :	11/06/2019 @ 06:05
Location :	1st FL = Rm 18	Received:	11/11/2019 @ 09:45
Radon Level :	1.0 pCi/L	Analyzed:	11/11/2019 @ 15:38
Error for Measurement is: ±	0.4 pCi/L		

Canister ID# :	2704128	Test Start :	11/04/2019 @ 05:47
Canister Type :	Charcoal Canister 3 inch	Test Stop :	11/06/2019 @ 05:52
Location :	1st FL=Principal's Off.	Received:	11/11/2019 @ 09:45
Radon Level :	0.3 pCi/L	Analyzed:	11/12/2019 @ 10:06
Error for Measurement is: ±	0.4 pCi/L		



Andreas C. George

Andreas C. George
Radon Measurement Specialist
NJ MES 11089

Dante Galan

Dante Galan
Laboratory Director

NRSB ARL0001
NYS ELAP ID: 10806
PADEP ID: 0346
NJDEP ID: NY933
NJ MEB 90036
FL DOH RB1609
IL RNL2000201

Site Radon Inspection Report

Date : 11/11/2019

Bryan Hogan / Ron Havnear
 MEDFORD SCHOOL DISTRICT
 815 South Oakdale Avenue
 Medford, OR 97501-

Client: Oak Grove E.S.
 Test Location: 2838 West Main Street
 Medford, OR 97501-

Individual Canister Results

Canister ID# :	2704139	Test Start :	11/04/2019 @ 05:59
Canister Type :	Charcoal Canister 3 inch	Test Stop :	11/06/2019 @ 06:01
Location :	1st FL=Clinica 2	Received:	11/11/2019 @ 09:45
Radon Level :	0.2 pCi/L	Analyzed:	11/11/2019 @ 11:44
Error for Measurement is: ±	0.6 pCi/L		


Canister ID# :	2704141	Test Start :	11/04/2019 @ 06:05
Canister Type :	Charcoal Canister 3 inch	Test Stop :	11/06/2019 @ 06:08
Location :	1st FL = Rm 19	Received:	11/11/2019 @ 09:45
Radon Level :	1.4 pCi/L	Analyzed:	11/11/2019 @ 15:54
Error for Measurement is: ±	0.5 pCi/L		

Canister ID# :	2704146	Test Start :	11/04/2019 @ 06:18
Canister Type :	Charcoal Canister 3 inch	Test Stop :	11/06/2019 @ 06:19
Location :	1st FL = Rm 09 DP	Received:	11/11/2019 @ 09:45
Radon Level :	0.1 pCi/L	Analyzed:	11/11/2019 @ 15:38
Error for Measurement is: ±	0.8 pCi/L		

Canister ID# :	2704148	Test Start :	11/04/2019 @ 06:26
Canister Type :	Charcoal Canister 3 inch	Test Stop :	11/06/2019 @ 06:26
Location :	1st FL = Rm 26	Received:	11/11/2019 @ 09:45
Radon Level :	1.9 pCi/L	Analyzed:	11/12/2019 @ 10:19
Error for Measurement is: ±	0.6 pCi/L		

Canister ID# :	2704149	Test Start :	11/04/2019 @ 05:47
Canister Type :	Charcoal Canister 3 inch	Test Stop :	11/06/2019 @ 05:56
Location :	1st FL = Rm 15 BL	Received:	11/11/2019 @ 09:45
Radon Level :	0.1 pCi/L	Analyzed:	11/12/2019 @ 10:22
Error for Measurement is: ±	0.9 pCi/L		

Canister ID# :	2704150	Test Start :	11/04/2019 @ 06:08
Canister Type :	Charcoal Canister 3 inch	Test Stop :	11/06/2019 @ 06:09
Location :	1st FL=Gym 1	Received:	11/11/2019 @ 09:45
Radon Level :	0.4 pCi/L	Analyzed:	11/11/2019 @ 15:38
Error for Measurement is: ±	0.5 pCi/L		

Andreas C. George
 Radon Measurement Specialist

NJ MES 11089



Dante Galan
 Laboratory Director

NRSB ARL0001
 NYS ELAP ID: 10806
 PADEP ID: 0346
 NJDEP ID: NY933
 NJ MEB 90036
 FL DOH RB1609
 IL RNL2000201

Site Radon Inspection Report

Date : 11/11/2019

Bryan Hogan / Ron Havnear
MEDFORD SCHOOL DISTRICT
815 South Oakdale Avenue
Medford, OR 97501-

Client: Oak Grove E.S.
Test Location: 2838 West Main Street
Medford, OR 97501-

Individual Canister Results

Canister ID# : 2704182 Test Start : 11/04/2019 @ 06:11
Canister Type : Charcoal Canister 3 inch Test Stop : 11/06/2019 @ 06:13
Location : 1st FL = Rm 06 BL Received: 11/11/2019 @ 09:45
Radon Level : 0.1 pCi/L Analyzed: 11/12/2019 @ 10:24
Error for Measurement is: ± 0.8 pCi/L

Canister ID# : 2704194 Test Start : 11/04/2019 @ 06:10
Canister Type : Charcoal Canister 3 inch Test Stop : 11/06/2019 @ 06:10
Location : 1st FL=Gym 2 Received: 11/11/2019 @ 09:45
Radon Level : 0.3 pCi/L Analyzed: 11/12/2019 @ 10:06
Error for Measurement is: ± 0.5 pCi/L

Canister ID# : 2704204 Test Start : 11/04/2019 @ 05:46
Canister Type : Charcoal Canister 3 inch Test Stop : 11/06/2019 @ 05:56
Location : 1st FL = Rm 15 Received: 11/11/2019 @ 09:45
Radon Level : 1.0 pCi/L Analyzed: 11/11/2019 @ 15:38
Error for Measurement is: ± 0.4 pCi/L

Canister ID# : 2704205 Test Start : 11/04/2019 @ 05:44
Canister Type : Charcoal Canister 3 inch Test Stop : 11/06/2019 @ 05:44
Location : 1st FL=Conf. Rm 1 Received: 11/11/2019 @ 09:45
Radon Level : 0.2 pCi/L Analyzed: 11/11/2019 @ 15:57
Error for Measurement is: ± 0.4 pCi/L

Canister ID# : 2704212 Test Start : 11/04/2019 @ 05:43
Canister Type : Charcoal Canister 3 inch Test Stop : 11/06/2019 @ 05:57
Location : 2nd FL=Media Ctr. DP Received: 11/11/2019 @ 09:45
Radon Level : 0.5 pCi/L Analyzed: 11/12/2019 @ 10:01
Error for Measurement is: ± 0.5 pCi/L

Canister ID# : 2704214 Test Start : 11/04/2019 @ 10:00
Canister Type : Charcoal Canister 3 inch Test Stop : 11/06/2019 @ 10:00
Location : 1st FL = Rm 42 Received: 11/11/2019 @ 09:45
Radon Level : 14.6 pCi/L Analyzed: 11/12/2019 @ 10:01
Error for Measurement is: ± 0.8 pCi/L

This is a quality control test known as a spike. This canister has never been on the school site.



Andreas C. George

Andreas C. George
Radon Measurement Specialist
NJ MES 11089

Dante Galan

Dante Galan
Laboratory Director

NRSB ARL0001
NYS ELAP ID: 10806
PADEP ID: 0346
NJDEP ID: NY933
NJ MEB 90036
FL DOH RB1609
IL RNL2000201

Site Radon Inspection Report

Date : 11/11/2019

Bryan Hogan / Ron Havnear
MEDFORD SCHOOL DISTRICT
815 South Oakdale Avenue
Medford, OR 97501-

Client: Oak Grove E.S.
Test Location: 2838 West Main Street
Medford, OR 97501-

Individual Canister Results

Canister ID# : 2704215
Canister Type : Charcoal Canister 3 inch
Location : 1st FL = Rm 41
Radon Level : 14.7 pCi/L
Error for Measurement is: \pm 0.7 pCi/L

Test Start : 11/04/2019 @ 10:00
Test Stop : 11/06/2019 @ 10:00
Received: 11/11/2019 @ 09:45
Analyzed: 11/11/2019 @ 11:28

This is a quality control test known as a spike. This canister has never been on the school site.

Canister ID# : 2704238
Canister Type : Charcoal Canister 3 inch
Location : 1st FL = Rm 25
Radon Level : 1.0 pCi/L
Error for Measurement is: \pm 0.5 pCi/L

Test Start : 11/04/2019 @ 06:23
Test Stop : 11/06/2019 @ 06:24
Received: 11/11/2019 @ 09:45
Analyzed: 11/11/2019 @ 15:33

Canister ID# : 2704253
Canister Type : Charcoal Canister 3 inch
Location : 1st FL = Rm 12 DP
Radon Level : 0.6 pCi/L
Error for Measurement is: \pm 0.7 pCi/L

Test Start : 11/04/2019 @ 05:48
Test Stop : 11/06/2019 @ 05:56
Received: 11/11/2019 @ 09:45
Analyzed: 11/12/2019 @ 10:01

Canister ID# : 2704254
Canister Type : Charcoal Canister 3 inch
Location : 2nd FL=Media Ctr. 1
Radon Level : 0.3 pCi/L
Error for Measurement is: \pm 0.6 pCi/L

Test Start : 11/04/2019 @ 05:43
Test Stop : 11/06/2019 @ 05:56
Received: 11/11/2019 @ 09:45
Analyzed: 11/12/2019 @ 10:24

Canister ID# : 2704257
Canister Type : Charcoal Canister 3 inch
Location : 1st FL = Rm 24
Radon Level : 1.2 pCi/L
Error for Measurement is: \pm 0.6 pCi/L

Test Start : 11/04/2019 @ 06:20
Test Stop : 11/06/2019 @ 06:22
Received: 11/11/2019 @ 09:45
Analyzed: 11/11/2019 @ 15:54

Canister ID# : 2704482
Canister Type : Charcoal Canister 3 inch
Location : 1st FL=Office B-2
Radon Level : 1.7 pCi/L
Error for Measurement is: \pm 0.5 pCi/L

Test Start : 11/04/2019 @ 05:50
Test Stop : 11/06/2019 @ 06:00
Received: 11/11/2019 @ 09:45
Analyzed: 11/11/2019 @ 11:23



Andreas C. George

Andreas C. George
Radon Measurement Specialist
NJ MES 11089

Dante Galan

Dante Galan
Laboratory Director

NRSB ARL0001
NYS ELAP ID: 10806
PADEP ID: 0346
NJDEP ID: NY933
NJ MEB 90036
FL DOH RB1609
IL RNL2000201

Site Radon Inspection Report

Date : 11/11/2019

Bryan Hogan / Ron Havnear
MEDFORD SCHOOL DISTRICT
815 South Oakdale Avenue
Medford, OR 97501-

Client: Oak Grove E.S.
Test Location: 2838 West Main Street
Medford, OR 97501-

Individual Canister Results

Canister ID# : 2704495 Test Start : 11/04/2019 @ 05:44
Canister Type : Charcoal Canister 3 inch Test Stop : 11/06/2019 @ 05:58
Location : 1st FL = Rm 11 Received: 11/11/2019 @ 09:45
Radon Level : 1.6 pCi/L Analyzed: 11/12/2019 @ 10:01
Error for Measurement is: ± 0.6 pCi/L

Canister ID# : 2704508 Test Start : 11/04/2019 @ 05:45
Canister Type : Charcoal Canister 3 inch Test Stop : 11/06/2019 @ 05:57
Location : 2nd FL=Media Comp. Received: 11/11/2019 @ 09:45
Radon Level : 0.4 pCi/L Analyzed: 11/11/2019 @ 16:13
Error for Measurement is: ± 0.5 pCi/L

Canister ID# : 2704512 Test Start : 11/04/2019 @ 06:15
Canister Type : Charcoal Canister 3 inch Test Stop : 11/06/2019 @ 06:16
Location : 1st FL = Rm 08 Received: 11/11/2019 @ 09:45
Radon Level : 0.5 pCi/L Analyzed: 11/11/2019 @ 15:57
Error for Measurement is: ± 0.4 pCi/L

Canister ID# : 2704522 Test Start : 11/04/2019 @ 06:15
Canister Type : Charcoal Canister 3 inch Test Stop : 11/06/2019 @ 06:16
Location : 1st FL = Rm 22 DP Received: 11/11/2019 @ 09:45
Radon Level : 0.9 pCi/L Analyzed: 11/11/2019 @ 15:33
Error for Measurement is: ± 0.5 pCi/L

Canister ID# : 2704537 Test Start : 11/04/2019 @ 06:07
Canister Type : Charcoal Canister 3 inch Test Stop : 11/06/2019 @ 06:10
Location : 1st FL = Rm 20 Received: 11/11/2019 @ 09:45
Radon Level : 1.0 pCi/L Analyzed: 11/11/2019 @ 15:57
Error for Measurement is: ± 0.4 pCi/L

Canister ID# : 2704542 Test Start : 11/04/2019 @ 05:50
Canister Type : Charcoal Canister 3 inch Test Stop : 11/06/2019 @ 05:52
Location : 1st FL=Staff Break Rm Received: 11/11/2019 @ 09:45
Radon Level : 0.8 pCi/L Analyzed: 11/11/2019 @ 11:28
Error for Measurement is: ± 0.4 pCi/L



Andreas C. George

Andreas C. George
Radon Measurement Specialist
NJ MES 11089

Dante Galan

Dante Galan
Laboratory Director

NRSB ARL0001
NYS ELAP ID: 10806
PADEP ID: 0346
NJDEP ID: NY933
NJ MEB 90036
FL DOH RB1609
IL RNL2000201

Site Radon Inspection Report

Date : 11/11/2019

Bryan Hogan / Ron Havnear
 MEDFORD SCHOOL DISTRICT
 815 South Oakdale Avenue
 Medford, OR 97501-

Client: Oak Grove E.S.
 Test Location: 2838 West Main Street
 Medford, OR 97501-

Individual Canister Results

Canister ID# :	2704567	Test Start :	11/04/2019 @ 06:16
Canister Type :	Charcoal Canister 3 inch	Test Stop :	11/06/2019 @ 06:19
Location :	1st FL = Rm 09	Received:	11/11/2019 @ 09:45
Radon Level :	0.1 pCi/L	Analyzed:	11/11/2019 @ 15:52
Error for Measurement is: ±	0.3 pCi/L		


Canister ID# :	2704568	Test Start :	11/04/2019 @ 06:02
Canister Type :	Charcoal Canister 3 inch	Test Stop :	11/06/2019 @ 06:05
Location :	1st FL=Clinica 6	Received:	11/11/2019 @ 09:45
Radon Level :	0.3 pCi/L	Analyzed:	11/11/2019 @ 10:50
Error for Measurement is: ±	0.4 pCi/L		

Canister ID# :	2707268	Test Start :	11/04/2019 @ 05:57
Canister Type :	Charcoal Canister 3 inch	Test Stop :	11/06/2019 @ 06:06
Location :	1st FL = Rm 01	Received:	11/11/2019 @ 09:45
Radon Level :	1.0 pCi/L	Analyzed:	11/11/2019 @ 15:52
Error for Measurement is: ±	0.5 pCi/L		

Canister ID# :	2707314	Test Start :	11/04/2019 @ 06:05
Canister Type :	Charcoal Canister 3 inch	Test Stop :	11/06/2019 @ 06:10
Location :	1st FL = Rm 04	Received:	11/11/2019 @ 09:45
Radon Level :	1.2 pCi/L	Analyzed:	11/11/2019 @ 11:28
Error for Measurement is: ±	0.4 pCi/L		

Canister ID# :	2707325	Test Start :	11/04/2019 @ 06:03
Canister Type :	Charcoal Canister 3 inch	Test Stop :	11/06/2019 @ 06:06
Location :	1st FL=Clinica 7	Received:	11/11/2019 @ 09:45
Radon Level :	1.0 pCi/L	Analyzed:	11/12/2019 @ 10:22
Error for Measurement is: ±	0.7 pCi/L		

Canister ID# :	2707337	Test Start :	11/04/2019 @ 06:00
Canister Type :	Charcoal Canister 3 inch	Test Stop :	11/06/2019 @ 06:04
Location :	1st FL=Cafe 2	Received:	11/11/2019 @ 09:45
Radon Level :	0.2 pCi/L	Analyzed:	11/11/2019 @ 11:44
Error for Measurement is: ±	0.6 pCi/L		

Andreas C. George
 Radon Measurement Specialist

NJ MES 11089



Dante Galan
 Laboratory Director

NRSB ARL0001
 NYS ELAP ID: 10806
 PADEP ID: 0346
 NJDEP ID: NY933
 NJ MEB 90036
 FL DOH RB1609
 IL RNL2000201

Site Radon Inspection Report

Date : 11/11/2019

Bryan Hogan / Ron Havnear
MEDFORD SCHOOL DISTRICT
815 South Oakdale Avenue
Medford, OR 97501-

Client: Oak Grove E.S.
Test Location: 2838 West Main Street
Medford, OR 97501-

Individual Canister Results

Canister ID# : 2707347 Test Start : 11/04/2019 @ 06:11
Canister Type : Charcoal Canister 3 inch Test Stop : 11/06/2019 @ 06:13
Location : 1st FL = Rm 06 Received: 11/11/2019 @ 09:45
Radon Level : 0.4 pCi/L Analyzed: 11/11/2019 @ 10:50
Error for Measurement is: ± 0.4 pCi/L

Canister ID# : 2707348 Test Start : 11/04/2019 @ 05:48
Canister Type : Charcoal Canister 3 inch Test Stop : 11/06/2019 @ 05:56
Location : 1st FL = Rm 12 Received: 11/11/2019 @ 09:45
Radon Level : 1.1 pCi/L Analyzed: 11/11/2019 @ 15:57
Error for Measurement is: ± 0.5 pCi/L

Canister ID# : 2707349 Test Start : 11/04/2019 @ 05:49
Canister Type : Charcoal Canister 3 inch Test Stop : 11/06/2019 @ 05:59
Location : 1st FL=Office B-1 Received: 11/11/2019 @ 09:45
Radon Level : 1.3 pCi/L Analyzed: 11/11/2019 @ 16:13
Error for Measurement is: ± 0.6 pCi/L

Canister ID# : 2707378 Test Start : 11/04/2019 @ 06:17
Canister Type : Charcoal Canister 3 inch Test Stop : 11/06/2019 @ 06:19
Location : 1st FL = Rm 23 Received: 11/11/2019 @ 09:45
Radon Level : 0.7 pCi/L Analyzed: 11/11/2019 @ 15:57
Error for Measurement is: ± 0.4 pCi/L

Canister ID# : 2707384 Test Start : 11/04/2019 @ 06:00
Canister Type : Charcoal Canister 3 inch Test Stop : 11/06/2019 @ 06:03
Location : 1st FL=Clinica 4 Received: 11/11/2019 @ 09:45
Radon Level : 1.0 pCi/L Analyzed: 11/12/2019 @ 10:01
Error for Measurement is: ± 0.6 pCi/L

Canister ID# : 2707385 Test Start : 11/04/2019 @ 05:53
Canister Type : Charcoal Canister 3 inch Test Stop : 11/06/2019 @ 06:00
Location : 1st FL = Rm 16 DP Received: 11/11/2019 @ 09:45
Radon Level : 0.8 pCi/L Analyzed: 11/11/2019 @ 16:13
Error for Measurement is: ± 0.6 pCi/L



Andreas C. George

Andreas C. George
Radon Measurement Specialist
NJ MES 11089

Dante Galan

Dante Galan
Laboratory Director

NRSB ARL0001
NYS ELAP ID: 10806
PADEP ID: 0346
NJDEP ID: NY933
NJ MEB 90036
FL DOH RB1609
IL RNL2000201

Site Radon Inspection Report

Date : 11/11/2019

Bryan Hogan / Ron Havnear
MEDFORD SCHOOL DISTRICT
815 South Oakdale Avenue
Medford, OR 97501-

Client: Oak Grove E.S.
Test Location: 2838 West Main Street
Medford, OR 97501-

Individual Canister Results

Canister ID# : 2707402 Test Start : 11/04/2019 @ 05:44
Canister Type : Charcoal Canister 3 inch Test Stop : 11/06/2019 @ 06:00
Location : 1st FL=Conf. Rm 2 Received: 11/11/2019 @ 09:45
Radon Level : 0.7 pCi/L Analyzed: 11/12/2019 @ 10:06
Error for Measurement is: ± 0.5 pCi/L

Canister ID# : 2707411 Test Start : 11/04/2019 @ 05:51
Canister Type : Charcoal Canister 3 inch Test Stop : 11/06/2019 @ 05:53
Location : 1st FL = Rm 13 Received: 11/11/2019 @ 09:45
Radon Level : 0.9 pCi/L Analyzed: 11/11/2019 @ 15:57
Error for Measurement is: ± 0.4 pCi/L

Canister ID# : 2707415 Test Start : 11/04/2019 @ 05:54
Canister Type : Charcoal Canister 3 inch Test Stop : 11/06/2019 @ 06:02
Location : 1st FL=Cafe 1 Received: 11/11/2019 @ 09:45
Radon Level : 0.5 pCi/L Analyzed: 11/12/2019 @ 10:06
Error for Measurement is: ± 0.5 pCi/L

Canister ID# : 2707421 Test Start : 11/04/2019 @ 06:08
Canister Type : Charcoal Canister 3 inch Test Stop : 11/06/2019 @ 06:11
Location : 1st FL = Rm 05 Received: 11/11/2019 @ 09:45
Radon Level : 1.1 pCi/L Analyzed: 11/12/2019 @ 10:06
Error for Measurement is: ± 0.6 pCi/L

Canister ID# : 2707426 Test Start : 11/04/2019 @ 05:44
Canister Type : Charcoal Canister 3 inch Test Stop : 11/06/2019 @ 05:44
Location : 1st FL = Rm 11 BL Received: 11/11/2019 @ 09:45
Radon Level : 0.2 pCi/L Analyzed: 11/11/2019 @ 15:54
Error for Measurement is: ± 0.5 pCi/L

Canister ID# : 2708106 Test Start : 11/04/2019 @ 06:01
Canister Type : Charcoal Canister 3 inch Test Stop : 11/06/2019 @ 06:04
Location : 1st FL=Clinica 5 Received: 11/11/2019 @ 09:45
Radon Level : 0.5 pCi/L Analyzed: 11/11/2019 @ 15:38
Error for Measurement is: ± 0.5 pCi/L



Andreas C. George

Andreas C. George
Radon Measurement Specialist
NJ MES 11089

Dante Galan

Dante Galan
Laboratory Director

NRSB ARL0001
NYS ELAP ID: 10806
PADEP ID: 0346
NJDEP ID: NY933
NJ MEB 90036
FL DOH RB1609
IL RNL2000201

Site Radon Inspection Report

Date : 11/11/2019

Bryan Hogan / Ron Havnear
 MEDFORD SCHOOL DISTRICT
 815 South Oakdale Avenue
 Medford, OR 97501-

Client: Oak Grove E.S.
 Test Location: 2838 West Main Street
 Medford, OR 97501-

Individual Canister Results

Canister ID# :	2708547	Test Start :	11/04/2019 @ 05:35
Canister Type :	Charcoal Canister 3 inch	Test Stop :	11/06/2019 @ 05:40
Location :	1st FL=Health Rm	Received:	11/11/2019 @ 09:45
Radon Level :	0.4 pCi/L	Analyzed:	11/11/2019 @ 11:28
Error for Measurement is: ±	0.4 pCi/L		


Canister ID# :	2708549	Test Start :	11/04/2019 @ 06:00
Canister Type :	Charcoal Canister 3 inch	Test Stop :	11/06/2019 @ 06:07
Location :	1st FL = Rm 02	Received:	11/11/2019 @ 09:45
Radon Level :	1.2 pCi/L	Analyzed:	11/12/2019 @ 10:22
Error for Measurement is: ±	0.6 pCi/L		

Canister ID# :	2708578	Test Start :	11/04/2019 @ 05:52
Canister Type :	Charcoal Canister 3 inch	Test Stop :	11/06/2019 @ 06:01
Location :	1st FL=Office B-3	Received:	11/11/2019 @ 09:45
Radon Level :	0.7 pCi/L	Analyzed:	11/11/2019 @ 11:23
Error for Measurement is: ±	0.5 pCi/L		

Canister ID# :	2708579	Test Start :	11/04/2019 @ 06:03
Canister Type :	Charcoal Canister 3 inch	Test Stop :	11/06/2019 @ 06:09
Location :	1st FL = Rm 03	Received:	11/11/2019 @ 09:45
Radon Level :	0.6 pCi/L	Analyzed:	11/11/2019 @ 16:13
Error for Measurement is: ±	0.6 pCi/L		

Canister ID# :	2708596	Test Start :	11/04/2019 @ 06:11
Canister Type :	Charcoal Canister 3 inch	Test Stop :	11/06/2019 @ 06:12
Location :	1st FL = Rm 21	Received:	11/11/2019 @ 09:45
Radon Level :	1.0 pCi/L	Analyzed:	11/11/2019 @ 15:52
Error for Measurement is: ±	0.5 pCi/L		

Canister ID# :	2708597	Test Start :	11/04/2019 @ 05:43
Canister Type :	Charcoal Canister 3 inch	Test Stop :	11/06/2019 @ 05:56
Location :	2nd FL=Media Ctr. 2	Received:	11/11/2019 @ 09:45
Radon Level :	0.4 pCi/L	Analyzed:	11/11/2019 @ 11:44
Error for Measurement is: ±	0.6 pCi/L		

Andreas C. George
 Radon Measurement Specialist
 NJ MES 11089



Dante Galan
 Laboratory Director

NRSB ARL0001
 NYS ELAP ID: 10806
 PADEP ID: 0346
 NJDEP ID: NY933
 NJ MEB 90036
 FL DOH RB1609
 IL RNL2000201

Site Radon Inspection Report

Date : 11/11/2019

Bryan Hogan / Ron Havniar
 MEDFORD SCHOOL DISTRICT
 815 South Oakdale Avenue
 Medford, OR 97501-

Client: Oak Grove E.S.
 Test Location: 2838 West Main Street
 Medford, OR 97501-

Individual Canister Results

Canister ID# : 2708608	Test Start : 11/04/2019 @ 05:55
Canister Type : Charcoal Canister 3 inch	Test Stop : 11/06/2019 @ 06:01
Location : 1st FL=Clinica 1 DP	Received: 11/11/2019 @ 09:45
Radon Level : 0.1 pCi/L	Analyzed: 11/11/2019 @ 15:33
Error for Measurement is: ± 0.6 pCi/L	

Canister ID# : 2708616	Test Start : 11/04/2019 @ 06:20
Canister Type : Charcoal Canister 3 inch	Test Stop : 11/06/2019 @ 06:21
Location : 1st FL = Rm 10	Received: 11/11/2019 @ 09:45
Radon Level : 0.4 pCi/L	Analyzed: 11/12/2019 @ 10:06
Error for Measurement is: ± 0.5 pCi/L	

Canister ID# : 2708628	Test Start : 11/04/2019 @ 05:43
Canister Type : Charcoal Canister 3 inch	Test Stop : 11/06/2019 @ 05:53
Location : 1st FL = Rm 14	Received: 11/11/2019 @ 09:45
Radon Level : 0.5 pCi/L	Analyzed: 11/11/2019 @ 15:52
Error for Measurement is: ± 0.5 pCi/L	

Canister ID# : 2708637	Test Start : 11/04/2019 @ 06:01
Canister Type : Charcoal Canister 3 inch	Test Stop : 11/06/2019 @ 06:05
Location : 1st FL = Rm 18 BL	Received: 11/11/2019 @ 09:45
Radon Level : 0.3 pCi/L	Analyzed: 11/12/2019 @ 10:01
Error for Measurement is: ± 0.5 pCi/L	

Canister ID# : 2708645	Test Start : 11/04/2019 @ 05:52
Canister Type : Charcoal Canister 3 inch	Test Stop : 11/06/2019 @ 05:59
Location : 1st FL = Rm 16	Received: 11/11/2019 @ 09:45
Radon Level : 0.6 pCi/L	Analyzed: 11/12/2019 @ 10:19
Error for Measurement is: ± 0.5 pCi/L	

Canister ID# : 2708931	Test Start : 11/04/2019 @ 06:01
Canister Type : Charcoal Canister 3 inch	Test Stop : 11/06/2019 @ 06:05
Location : 1st FL=Cafe Off. C	Received: 11/11/2019 @ 09:45
Radon Level : 0.4 pCi/L	Analyzed: 11/11/2019 @ 15:54
Error for Measurement is: ± 0.5 pCi/L	



Andreas C. George

Dante Galan

Andreas C. George
 Radon Measurement Specialist

Dante Galan
 Laboratory Director

NRSB ARL0001
 NYS ELAP ID: 10806
 PADEP ID: 0346
 NJDEP ID: NY933
 NJ MEB 90036
 FL DOH RB1609
 IL RNL2000201

NJ MES 11089

Site Radon Inspection Report

Date : 11/11/2019

Bryan Hogan / Ron Havnear
 MEDFORD SCHOOL DISTRICT
 815 South Oakdale Avenue
 Medford, OR 97501-

Client: Oak Grove E.S.
 Test Location: 2838 West Main Street
 Medford, OR 97501-

Individual Canister Results

Canister ID# :	2708942	Test Start :	11/04/2019 @ 05:59
Canister Type :	Charcoal Canister 3 inch	Test Stop :	11/06/2019 @ 06:02
Location :	1st FL=Clinica 3	Received:	11/11/2019 @ 09:45
Radon Level :	0.3 pCi/L	Analyzed:	11/12/2019 @ 10:01
Error for Measurement is: ±	0.6 pCi/L		


Canister ID# :	2708948	Test Start :	11/04/2019 @ 06:14
Canister Type :	Charcoal Canister 3 inch	Test Stop :	11/06/2019 @ 06:15
Location :	1st FL = Rm 22	Received:	11/11/2019 @ 09:45
Radon Level :	0.8 pCi/L	Analyzed:	11/12/2019 @ 10:01
Error for Measurement is: ±	0.6 pCi/L		

Canister ID# :	2708953	Test Start :	11/04/2019 @ 05:59
Canister Type :	Charcoal Canister 3 inch	Test Stop :	11/06/2019 @ 05:59
Location :	1st FL=Clinica 3 BL	Received:	11/11/2019 @ 09:45
Radon Level :	0.1 pCi/L	Analyzed:	11/11/2019 @ 15:33
Error for Measurement is: ±	0.6 pCi/L		

Canister ID# :	2708955	Test Start :	11/04/2019 @ 05:55
Canister Type :	Charcoal Canister 3 inch	Test Stop :	11/06/2019 @ 06:01
Location :	1st FL=Clinica 1	Received:	11/11/2019 @ 09:45
Radon Level :	0.5 pCi/L	Analyzed:	11/12/2019 @ 10:06
Error for Measurement is: ±	0.5 pCi/L		

Canister ID# :	2710002	Test Start :	11/04/2019 @ 06:15
Canister Type :	Charcoal Canister 3 inch	Test Stop :	11/06/2019 @ 06:15
Location :	1st FL=Gym 3	Received:	11/11/2019 @ 09:45
Radon Level :	0.7 pCi/L	Analyzed:	11/11/2019 @ 15:57
Error for Measurement is: ±	0.4 pCi/L		

Canister ID# :	2710041	Test Start :	11/04/2019 @ 05:41
Canister Type :	Charcoal Canister 3 inch	Test Stop :	11/06/2019 @ 05:55
Location :	2nd FL=Media Ctr. Off.	Received:	11/11/2019 @ 09:45
Radon Level :	0.7 pCi/L	Analyzed:	11/11/2019 @ 11:44
Error for Measurement is: ±	0.5 pCi/L		

Andreas C. George
 Radon Measurement Specialist
 NJ MES 11089



Dante Galan
 Laboratory Director

NRSB ARL0001
 NYS ELAP ID: 10806
 PADEP ID: 0346
 NJDEP ID: NY933
 NJ MEB 90036
 FL DOH RB1609
 IL RNL2000201



Site Radon Inspection Report

Date : 11/11/2019

Bryan Hogan / Ron Havnear
MEDFORD SCHOOL DISTRICT
815 South Oakdale Avenue
Medford, OR 97501-

Client: Oak Grove E.S.
Test Location: 2838 West Main Street
Medford, OR 97501-

Individual Canister Results

Canister ID# :	2710050	Test Start :	11/04/2019 @ 05:53
Canister Type :	Charcoal Canister 3 inch	Test Stop :	11/06/2019 @ 06:02
Location :	1st FL=Cust. Off.	Received:	11/11/2019 @ 09:45
Radon Level :	1.2 pCi/L	Analyzed:	11/11/2019 @ 11:22
Error for Measurement is: ±	0.5 pCi/L		

Canister ID# :	2710052	Test Start :	11/04/2019 @ 06:03
Canister Type :	Charcoal Canister 3 inch	Test Stop :	11/06/2019 @ 06:07
Location :	1st FL=Multi Purp. Rm	Received:	11/11/2019 @ 09:45
Radon Level :	0.8 pCi/L	Analyzed:	11/12/2019 @ 10:19
Error for Measurement is: ±	0.6 pCi/L		

The results indicate that at least one testing device registered at or above the United States Environmental Protection Agency (EPA) action level of 4.0 picoCuries per liter of air (pCi/L). The EPA recommends mitigation if the average of two short-term tests taken in the lowest level of the building suitable for occupancy show radon levels that are equal to or greater than 4.0 pCi/L.

For information on how to reduce radon levels in your home, please review the EPA booklet: Consumer's Guide to Radon Reduction (www.epa.gov/radon/pdfs/consguid.pdf) and contact your state health department. The EPA maintains a radon information website, including copies of its publications, at www.epa.gov/iaq/radon.

For New Jersey clients: Please see the attached guidance document entitled Radon Testing and Mitigation: The Basics for further information.

For New York clients: If the radon level of one or more testing devices is equal to or exceeds 20 pCi/L please contact the New York State Department of Health, Bureau of Environmental Radiation Protection, for technical advice and assistance at 518-402-7556 or toll free 1-800-458-1158.

PLEDGE OF ASSURED QUALITY

All procedures used for generating this report are in complete accordance with the current EPA protocols for the analysis of radon in air (EPA 402-R-92-004). The analytical results relate only to the samples tested, in the condition received by the lab, and that calculations were based upon the information supplied by client. RTCA and its personnel do not assume responsibility or liability, collectively and individually, for analysis results when detectors have been improperly handled or placed by the consumer, nor does RTCA and its personnel accept responsibility for any financial or health consequences of subsequent action or lack of action, taken by the customer or its consultants based on RTCA-provided results.



Andreas C. George

Andreas C. George
Radon Measurement Specialist
NJ MES 11089

Dante Galan

Dante Galan
Laboratory Director

NRSB ARL0001
NYS ELAP ID: 10806
PADEP ID: 0346
NJDEP ID: NY933
NJ MEB 90036
FL DOH RB1609
IL RNL2000201