

**Oak Grove Elementary School**

Radon Tests - Oak Grove Elementary School									
#	Location/Type	Placement Description	Serial #	Dated Opened	Time Opened	Date Closed	Time Closed	Radon Test Results	Remarks
1	Main Office	Southeast Counter	2704122	4-Nov-19	5:32 AM	6-Nov-19	5:38 AM	0.5	None
2	Health Room	South Counter	2708547	4-Nov-19	5:35 AM	6-Nov-19	5:40 AM	0.4	None
3	Principal's Office	East Bookshelf	2704128	4-Nov-19	5:47 AM	6-Nov-19	5:52 AM	0.2	None
4	Conference Room # 1	South Counter	2704205	4-Nov-19	5:44 AM	6-Nov-19	5:44 AM	0.3	None
5	Conference Room # 2	South Counter	2707402	4-Nov-19	5:44 AM	6-Nov-19	6:00 AM	0.7	None
6	Staff Work Room	Southeast Counter	2679226	4-Nov-19	5:49 AM	6-Nov-19	5:59 AM	0.9	None
7	Staff Break Room	East Table	2704542	4-Nov-19	5:50 AM	6-Nov-19	5:52 AM	0.8	None
8	Cafeteria # 1	Northeast Wall	2707415	4-Nov-19	5:54 AM	6-Nov-19	6:02 AM	0.5	None
9	Cafeteria # 2	Northwest Wall	2707337	4-Nov-19	6:00 AM	6-Nov-19	6:04 AM	0.2	None
10	Cafeteria Office 'C'	Northeast Counter	2708931	4-Nov-19	6:01 AM	6-Nov-19	6:05 AM	0.4	None
11	Multi Purpose Room	Northeast Counter	2710052	4-Nov-19	6:03 AM	6-Nov-19	6:07 AM	0.8	None
12	Gymnasium # 1	Northeast Column	2704150	4-Nov-19	6:08 AM	6-Nov-19	6:09 AM	0.4	None
13	Gymnasium # 2	Southeast Column	2704194	4-Nov-19	6:10 AM	6-Nov-19	6:10 AM	0.3	None
14	Gymnasium # 3	West Column	2710002	4-Nov-19	6:15 AM	6-Nov-19	6:15 AM	0.7	None
15	Media Center - Office	Corner File Cabinet	2710041	4-Nov-19	5:41 AM	6-Nov-19	5:55 AM	0.7	None
16	Media Center # 1	Island Countertop	2704254	4-Nov-19	5:43 AM	6-Nov-19	5:56 AM	0.3	None
17	Media Center # 2	Island Countertop	2708597	4-Nov-19	5:43 AM	6-Nov-19	5:56 AM	0.4	None
18	Media Center - Duplicate	Island Countertop	2704212	4-Nov-19	5:45 AM	6-Nov-19	5:57 AM	0.5	None
19	Media Center - Computer Room	Desktop	2704508	4-Nov-19	5:46 AM	6-Nov-19	5:57 AM	0.4	None
20	Office B-1	Filing Cabinet	2707349	4-Nov-19	5:48 AM	6-Nov-19	5:59 AM	1.3	None
21	Office B-2	Filing Cabinet	2704482	4-Nov-19	5:50 AM	6-Nov-19	6:00 AM	1.7	None
22	Office B-3	Bookshelf	2708578	4-Nov-19	5:51 AM	6-Nov-19	6:01 AM	0.7	None
23	Custodial Office/Storage Area	Filing Cabinet	2710050	4-Nov-19	5:53 AM	6-Nov-19	6:02 AM	1.2	None
24	Room 1	Bookshelf	2707268	4-Nov-19	5:56 AM	6-Nov-19	6:06 AM	1.0	None
25	Room 2	Sink Countertop	2708549	4-Nov-19	6:00 AM	6-Nov-19	6:07 AM	1.2	None
26	Room 3	Filing Cabinet	2708579	4-Nov-19	6:02 AM	6-Nov-19	6:09 AM	0.6	None
27	Room 4	Left Corner Bookshelf	2707314	4-Nov-19	6:05 AM	6-Nov-19	6:10 AM	1.2	None
28	Room 5	Countertop	2707421	4-Nov-19	6:08 AM	6-Nov-19	6:11 AM	1.1	None
29	Room 6	Computer Counter	2707347	4-Nov-19	6:10 AM	6-Nov-19	6:12 AM	0.4	None
30	Room 6 - Blank	Computer Counter	2704182	4-Nov-19	6:11 AM	4-Nov-19	6:13 AM	0.1	None
31	Room 7	By Sink	2704119	4-Nov-19	6:13 AM	6-Nov-19	6:15 AM	0.4	None
32	Room 8	Counter Top	2704512	4-Nov-19	6:15 AM	6-Nov-19	6:16 AM	0.5	None
33	Room 9	West Countertop	2704567	4-Nov-19	6:16 AM	6-Nov-19	6:18 AM	0.1	None
34	Room 9 - Duplicate	West Countertop	2708616	4-Nov-19	6:17 AM	6-Nov-19	6:18 AM	0.1	None
35	Room 10	Bookshelf	2708516	4-Nov-19	6:19 AM	6-Nov-19	6:20 AM	0.4	None
36	Room 14	North Bookcase	2708628	4-Nov-19	5:43 AM	6-Nov-19	5:53 AM	0.5	None
37	Room 15	Center File Cabinet	2704204	4-Nov-19	5:46 AM	6-Nov-19	5:56 AM	1.0	None
38	Room 15 - Blank	Center File Cabinet	2704149	4-Nov-19	5:47 AM	4-Nov-19	5:56 AM	0.1	None
39	Room 16	Teachers Countertop	2718645	4-Nov-19	5:52 AM	6-Nov-19	5:59 AM	0.6	None
40	Room 16 - Duplicate	Teachers Countertop	2707385	4-Nov-19	5:53 AM	6-Nov-19	6:00 AM	0.8	None
41	Room 17	Counter By Sink	2704124	4-Nov-19	5:56 AM	6-Nov-19	6:02 AM	0.6	None
42	Room 18	South Counter	2704125	4-Nov-19	6:00 AM	6-Nov-19	6:05 AM	1.0	None
43	Room 18 - Blank	South Counter	2708637	4-Nov-19	6:01 AM	4-Nov-19	6:01 AM	0.3	None
44	Room 19	North Counter	2704141	4-Nov-19	6:05 AM	6-Nov-19	6:08 AM	1.4	None
45	Room 20	East Wall	2704537	4-Nov-19	6:07 AM	6-Nov-19	6:10 AM	1.0	None
46	Room 21	East Wall - Shelf	2708596	4-Nov-19	6:11 AM	6-Nov-19	6:12 AM	1.0	None
47	Room 22	West Filing Cabinet	2708948	4-Nov-19	6:14 AM	6-Nov-19	6:15 AM	0.8	None
48	Room 22 - Duplicate	West Filing Cabinet	2704522	4-Nov-19	6:15 AM	6-Nov-19	6:16 AM	0.9	None
49	Room 23	East Bookshelf	2707378	4-Nov-19	6:17 AM	6-Nov-19	6:19 AM	0.7	None
50	Room 24	East Wall	2704257	4-Nov-19	6:20 AM	6-Nov-19	6:22 AM	1.2	None
51	Room 25	West Wall	2704238	4-Nov-19	6:23 AM	6-Nov-19	6:24 AM	1.0	None
52	Room 26	Teacher's Desk	2704148	4-Nov-19	6:26 AM	6-Nov-19	6:26 AM	1.9	None
53	Room 11	Filing Cabinet	2704495	4-Nov-19	5:44 AM	6-Nov-19	5:57 AM	1.6	None
54	Room 11 - Blank	Filing Cabinet	2707426	4-Nov-19	5:44 AM	4-Nov-19	5:44 AM	0.2	None
55	Room 12	South Counter	2707348	4-Nov-19	5:48 AM	6-Nov-19	5:56 AM	1.1	None
56	Room 12 - Duplicate	South Counter	2704253	4-Nov-19	5:48 AM	6-Nov-19	5:56 AM	0.6	None
57	Room 13	North Filing Cabinet	2707411	4-Nov-19	5:51 AM	6-Nov-19	5:53 AM	0.9	None
58	La Clinica # 1	West Bookshelf	2708955	4-Nov-19	5:55 AM	6-Nov-19	6:01 AM	0.5	None
59	La Clinica # 1 - Duplicate	West Bookshelf	2708608	4-Nov-19	5:55 AM	6-Nov-19	6:01 AM	0.1	None
60	La Clinica # 2	Southeast Counter	2704139	4-Nov-19	5:58 AM	6-Nov-19	6:02 AM	0.2	None
61	La Clinica # 3	South Printer Shelf	2708942	4-Nov-19	5:59 AM	6-Nov-19	6:02 AM	0.3	None
62	La Clinica # 3 - Blank	South Printer Shelf	2708953	4-Nov-19	5:59 AM	4-Nov-19	5:59 AM	0.1	None
63	La Clinica # 4	Southeast Countertop	2707384	4-Nov-19	6:00 AM	6-Nov-19	6:03 AM	1.0	None
64	La Clinica # 5	Northwest Filing Cabinet	2708106	4-Nov-19	6:01 AM	6-Nov-19	6:04 AM	0.5	None
65	La Clinica # 6	Refrigerator	2704568	4-Nov-19	6:02 AM	6-Nov-19	6:05 AM	0.3	None
66	La Clinica # 7	South Filing Cabinet	2707325	4-Nov-19	6:03 AM	6-Nov-19	6:06 AM	1.0	None

#	Type	Description	Serial #	Dated Opened	Time Opened	Date Closed	Time Closed	Radon Test Results	Remarks
67	Spikes #1 (Room 41)	KSU Radon Chamber Pike to 21.3	2704215	4-Nov-19	10:00 AM	6-Nov-19	10:00 AM	14.7	None
68	Spikes #2 (Room 42)	KSU Radon Chamber Pike to 21.3	2704214	4-Nov-19	10:00 AM	6-Nov-19	10:00 AM	14.6	None

#	Type	Description	Serial #	Dated Opened	Time Opened	Date Closed	Time Closed	EPA Average	Remarks
1	CRM-1	Main Office - SE Counter	238515017	4-Nov-19	7:19 AM	6-Nov-19	6:19 AM	0.8	Radon Monitor/District Control
2	CRM-2	Laundry Storage - East Bookshelf	238515009	4-Nov-19	7:20 AM	6-Nov-19	6:20 AM	0.8	Radon Monitor/District Control
3	CRM-3	Workroom - Northeast Counter	238515015	4-Nov-19	7:19 AM	6-Nov-19	6:19 AM	0.8	Radon Monitor/District Control

\*The E.P.A.'s recommended action level for radon is 4.0 pCi/L.  
 \*This is not a health based number.  
 \*Outdoor radon levels across the country average 0.4 pCi/L.  
 \*If an RPD test result over 4.0 pCi/L differs by 28% or more, the data quality should be questioned.  
 \*A trend in RPE values that are more than ± 30% should be investigated