

Site Radon Inspection Report

Date : 11/01/2021

Mr. Seth Barry
MEDFORD SCHOOL DISTRICT
815 South Oakdale Avenue
Medford, OR 97501-

Client: Washington Elementary School
Test Location: 610 South Peach Street
Medford, OR 97501-

Individual Canister Results

Canister ID# : 2756606 Test Start : 10/26/2021 @ 06:15
Canister Type : Charcoal Canister 3 inch Test Stop : 10/28/2021 @ 06:32
Location : 1st FL=Rm 42 Received: 11/01/2021 @ 14:54
Radon Level : 25.4 pCi/L Analyzed: 11/02/2021 @ 11:11
Error for Measurement is: \pm 0.9 pCi/L

Canister ID# : 2765194 Test Start : 10/26/2021 @ 06:01
Canister Type : Charcoal Canister 3 inch Test Stop : 10/28/2021 @ 06:23
Location : 1st FL=Health Rm Received: 11/01/2021 @ 14:53
Radon Level : 0.2 pCi/L Analyzed: 11/02/2021 @ 11:11
Error for Measurement is: \pm 0.4 pCi/L

Canister ID# : 2765198 Test Start : 10/26/2021 @ 06:13
Canister Type : Charcoal Canister 3 inch Test Stop : 10/28/2021 @ 06:29
Location : 1st FL=Rm 3 N. Wall DP Received: 11/01/2021 @ 14:53
Radon Level : 0.4 pCi/L Analyzed: 11/02/2021 @ 12:05
Error for Measurement is: \pm 0.4 pCi/L

Canister ID# : 2765213 Test Start : 10/26/2021 @ 05:59
Canister Type : Charcoal Canister 3 inch Test Stop : 10/28/2021 @ 06:21
Location : 1st FL=Gym 2 DP Received: 11/01/2021 @ 14:53
Radon Level : 0.6 pCi/L Analyzed: 11/02/2021 @ 12:19
Error for Measurement is: \pm 0.5 pCi/L

Canister ID# : 2765644 Test Start : 10/26/2021 @ 06:02
Canister Type : Charcoal Canister 3 inch Test Stop : 10/28/2021 @ 06:24
Location : 1st FL=Rm 10 S. Wall Received: 11/01/2021 @ 14:54
Radon Level : 0.3 pCi/L Analyzed: 11/02/2021 @ 10:58
Error for Measurement is: \pm 0.3 pCi/L

Canister ID# : 2816033 Test Start : 10/26/2021 @ 06:07
Canister Type : Charcoal Canister 3 inch Test Stop : 10/28/2021 @ 06:26
Location : 1st FL=Comp. Rm Off. Received: 11/01/2021 @ 14:54
Radon Level : 0.8 pCi/L Analyzed: 11/02/2021 @ 10:13
Error for Measurement is: \pm 0.4 pCi/L



Andreas C. George

Andreas C. George
Radon Measurement Specialist
NJ MES 11089

Dante Galan

Dante Galan
Laboratory Director

NRSB ARL0001
NYS ELAP ID: 10806
PADEP ID: 0346
NJDEP ID: NY933
NJ MEB 90036
FL DOH RB1609
IL RNL2000201

Site Radon Inspection Report

Date : 11/01/2021

Mr. Seth Barry
MEDFORD SCHOOL DISTRICT
815 South Oakdale Avenue
Medford, OR 97501-

Client: Washington Elementary School
Test Location: 610 South Peach Street
Medford, OR 97501-

Individual Canister Results

Canister ID# : 2817999 Test Start : 10/26/2021 @ 06:20
Canister Type : Charcoal Canister 3 inch Test Stop : 10/28/2021 @ 06:35
Location : 1st FL=Room 41 Received: 11/01/2021 @ 14:54
Radon Level : 29.4 pCi/L Analyzed: 11/02/2021 @ 11:11
Error for Measurement is: ± 0.9 pCi/L

Canister ID# : 2913376 Test Start : 10/26/2021 @ 06:09
Canister Type : Charcoal Canister 3 inch Test Stop : 10/28/2021 @ 06:26
Location : 1st FL=Rm 9 Received: 11/01/2021 @ 14:54
Radon Level : 0.1 pCi/L Analyzed: 11/02/2021 @ 09:57
Error for Measurement is: ± 0.2 pCi/L

Canister ID# : 2913658 Test Start : 10/26/2021 @ 06:09
Canister Type : Charcoal Canister 3 inch Test Stop : 10/28/2021 @ 06:24
Location : 1st FL=La Clinica Off. 1 Received: 11/01/2021 @ 14:53
Radon Level : 0.3 pCi/L Analyzed: 11/02/2021 @ 09:42
Error for Measurement is: ± 0.4 pCi/L

Canister ID# : 2913678 Test Start : 10/26/2021 @ 06:06
Canister Type : Charcoal Canister 3 inch Test Stop : 10/28/2021 @ 06:23
Location : 1st FL=La Clinica 1 Received: 11/01/2021 @ 14:53
Radon Level : 0.2 pCi/L Analyzed: 11/02/2021 @ 10:15
Error for Measurement is: ± 0.5 pCi/L

Canister ID# : 2913769 Test Start : 10/26/2021 @ 06:11
Canister Type : Charcoal Canister 3 inch Test Stop : 10/28/2021 @ 06:29
Location : 1st FL=Media Ctr 2 DP Received: 11/01/2021 @ 14:54
Radon Level : 0.4 pCi/L Analyzed: 11/02/2021 @ 11:11
Error for Measurement is: ± 0.4 pCi/L

Canister ID# : 2916001 Test Start : 10/26/2021 @ 06:05
Canister Type : Charcoal Canister 3 inch Test Stop : 10/28/2021 @ 06:24
Location : 1st FL=Custodial Off. Received: 11/01/2021 @ 14:53
Radon Level : 0.1 pCi/L Analyzed: 11/02/2021 @ 09:57
Error for Measurement is: ± 0.3 pCi/L



Andreas C. George

Andreas C. George
Radon Measurement Specialist
NJ MES 11089

Dante Galan

Dante Galan
Laboratory Director

NRSB ARL0001
NYS ELAP ID: 10806
PADEP ID: 0346
NJDEP ID: NY933
NJ MEB 90036
FL DOH RB1609
IL RNL2000201

Site Radon Inspection Report

Date : 11/01/2021

Mr. Seth Barry
MEDFORD SCHOOL DISTRICT
815 South Oakdale Avenue
Medford, OR 97501-

Client: Washington Elementary School
Test Location: 610 South Peach Street
Medford, OR 97501-

Individual Canister Results

Canister ID# : 2916008 Test Start : 10/26/2021 @ 06:18
Canister Type : Charcoal Canister 3 inch Test Stop : 10/28/2021 @ 06:30
Location : 1st FL=Staff Break Rm DP Received: 11/01/2021 @ 14:54
Radon Level : 0.2 pCi/L Analyzed: 11/02/2021 @ 12:19
Error for Measurement is: ± 0.4 pCi/L

Canister ID# : 2916009 Test Start : 10/26/2021 @ 06:02
Canister Type : Charcoal Canister 3 inch Test Stop : 10/28/2021 @ 06:22
Location : 1st FL=Rm 7 Received: 11/01/2021 @ 14:54
Radon Level : 0.5 pCi/L Analyzed: 11/02/2021 @ 10:13
Error for Measurement is: ± 0.5 pCi/L

Canister ID# : 2916012 Test Start : 10/26/2021 @ 06:07
Canister Type : Charcoal Canister 3 inch Test Stop : 10/28/2021 @ 06:25
Location : 1st FL=Rm 8 Received: 11/01/2021 @ 14:54
Radon Level : 0.2 pCi/L Analyzed: 11/02/2021 @ 12:05
Error for Measurement is: ± 0.4 pCi/L

Canister ID# : 2916022 Test Start : 10/26/2021 @ 06:15
Canister Type : Charcoal Canister 3 inch Test Stop : 10/28/2021 @ 06:28
Location : 1st FL=Cafeteria 1 Received: 11/01/2021 @ 14:53
Radon Level : 0.4 pCi/L Analyzed: 11/02/2021 @ 12:06
Error for Measurement is: ± 0.5 pCi/L

Canister ID# : 2916033 Test Start : 10/26/2021 @ 06:00
Canister Type : Charcoal Canister 3 inch Test Stop : 10/28/2021 @ 06:22
Location : 1st FL=Principal's Off. Received: 11/01/2021 @ 14:53
Radon Level : 0.2 pCi/L Analyzed: 11/02/2021 @ 10:28
Error for Measurement is: ± 0.4 pCi/L

Canister ID# : 2916034 Test Start : 10/26/2021 @ 06:23
Canister Type : Charcoal Canister 3 inch Test Stop : 10/28/2021 @ 06:35
Location : 1st FL=Gym SE Received: 11/01/2021 @ 14:53
Radon Level : 0.8 pCi/L Analyzed: 11/02/2021 @ 09:57
Error for Measurement is: ± 0.5 pCi/L



Andreas C. George

Andreas C. George
Radon Measurement Specialist
NJ MES 11089

Dante Galan

Dante Galan
Laboratory Director

NRSB ARL0001
NYS ELAP ID: 10806
PADEP ID: 0346
NJDEP ID: NY933
NJ MEB 90036
FL DOH RB1609
IL RNL2000201

Site Radon Inspection Report

Date : 11/01/2021

Mr. Seth Barry
MEDFORD SCHOOL DISTRICT
815 South Oakdale Avenue
Medford, OR 97501-

Client: Washington Elementary School
Test Location: 610 South Peach Street
Medford, OR 97501-

Individual Canister Results

Canister ID# : 2916047 Test Start : 10/26/2021 @ 05:58
Canister Type : Charcoal Canister 3 inch Test Stop : 10/28/2021 @ 06:20
Location : 1st FL=Office Received: 11/01/2021 @ 14:53
Radon Level : 0.2 pCi/L Analyzed: 11/02/2021 @ 10:28
UNDER MEAL SLOTS

Error for Measurement is: \pm 0.3 pCi/L

Canister ID# : 2916922 Test Start : 10/26/2021 @ 06:13
Canister Type : Charcoal Canister 3 inch Test Stop : 10/28/2021 @ 06:29
Location : 1st FL=Rm 3 N. Wall DP Received: 11/01/2021 @ 14:53
Radon Level : 0.8 pCi/L Analyzed: 11/02/2021 @ 10:58
Error for Measurement is: \pm 0.4 pCi/L

Canister ID# : 2916924 Test Start : 10/26/2021 @ 06:12
Canister Type : Charcoal Canister 3 inch Test Stop : 10/28/2021 @ 06:27
Location : 1st FL=La Clinica Exam 2 Received: 11/01/2021 @ 14:53
Radon Level : 0.2 pCi/L Analyzed: 11/02/2021 @ 12:19
Error for Measurement is: \pm 0.4 pCi/L

Canister ID# : 2916950 Test Start : 10/26/2021 @ 05:56
Canister Type : Charcoal Canister 3 inch Test Stop : 10/28/2021 @ 06:20
Location : 1st FL=Rm 5 Received: 11/01/2021 @ 14:54
Radon Level : 0.2 pCi/L Analyzed: 11/02/2021 @ 12:05
Error for Measurement is: \pm 0.3 pCi/L

Canister ID# : 2916956 Test Start : 10/26/2021 @ 06:00
Canister Type : Charcoal Canister 3 inch Test Stop : 10/28/2021 @ 06:23
Location : 1st FL=Rm 11 N. Wall BL Received: 11/01/2021 @ 14:54
Radon Level : 0.1 pCi/L Analyzed: 11/02/2021 @ 10:15
Error for Measurement is: \pm 0.7 pCi/L

Canister ID# : 2916958 Test Start : 10/26/2021 @ 06:18
Canister Type : Charcoal Canister 3 inch Test Stop : 10/28/2021 @ 06:30
Location : 1st FL=Staff Break Rm DP Received: 11/01/2021 @ 14:54
Radon Level : 0.6 pCi/L Analyzed: 11/02/2021 @ 12:06



Andreas C. George

Andreas C. George
Radon Measurement Specialist
NJ MES 11089

Dante Galan

Dante Galan
Laboratory Director

NRSB ARL0001
NYS ELAP ID: 10806
PADEP ID: 0346
NJDEP ID: NY933
NJ MEB 90036
FL DOH RB1609
IL RNL2000201

Site Radon Inspection Report

Date : 11/01/2021

Mr. Seth Barry
MEDFORD SCHOOL DISTRICT
815 South Oakdale Avenue
Medford, OR 97501-

Client: Washington Elementary School
Test Location: 610 South Peach Street
Medford, OR 97501-

Individual Canister Results

Error for Measurement is: \pm 0.4 pCi/L

Canister ID# :	2916964	Test Start :	10/26/2021 @ 06:11
Canister Type :	Charcoal Canister 3 inch	Test Stop :	10/28/2021 @ 06:29
Location :	1st FL=Media Ctr 2 DP	Received:	11/01/2021 @ 14:54
Radon Level :	0.9 pCi/L	Analyzed:	11/02/2021 @ 10:13
Error for Measurement is:	\pm 0.5 pCi/L		

Canister ID# :	2916966	Test Start :	10/26/2021 @ 06:03
Canister Type :	Charcoal Canister 3 inch	Test Stop :	10/28/2021 @ 06:22
Location :	1st FL=Stage	Received:	11/01/2021 @ 14:53
Radon Level :	0.4 pCi/L	Analyzed:	11/02/2021 @ 12:06
Error for Measurement is:	\pm 0.4 pCi/L		

Canister ID# :	2917608	Test Start :	10/26/2021 @ 06:10
Canister Type :	Charcoal Canister 3 inch	Test Stop :	10/28/2021 @ 06:26
Location :	1st FL=La Clinica Exam 1	Received:	11/01/2021 @ 14:53
Radon Level :	0.3 pCi/L	Analyzed:	11/02/2021 @ 12:19
Error for Measurement is:	\pm 0.4 pCi/L		

Canister ID# :	2917615	Test Start :	10/26/2021 @ 06:10
Canister Type :	Charcoal Canister 3 inch	Test Stop :	10/28/2021 @ 06:28
Location :	1st FL=Media Ctr 1	Received:	11/01/2021 @ 14:54
Radon Level :	0.3 pCi/L	Analyzed:	11/02/2021 @ 09:56
Error for Measurement is:	\pm 0.4 pCi/L		

Canister ID# :	2917619	Test Start :	10/26/2021 @ 06:20
Canister Type :	Charcoal Canister 3 inch	Test Stop :	10/28/2021 @ 06:33
Location :	1st FL=Rm 1 N. Wall BL	Received:	11/01/2021 @ 14:53
Radon Level :	0.1 pCi/L	Analyzed:	11/02/2021 @ 10:28
Error for Measurement is:	\pm 0.8 pCi/L		

Canister ID# :	2917621	Test Start :	10/26/2021 @ 06:08
Canister Type :	Charcoal Canister 3 inch	Test Stop :	10/28/2021 @ 06:27
Location :	1st FL=Staff Work Rm	Received:	11/01/2021 @ 14:54
Radon Level :	0.1 pCi/L	Analyzed:	11/02/2021 @ 10:15
Error for Measurement is:	\pm 0.8 pCi/L		



Andreas C. George

Andreas C. George
Radon Measurement Specialist
NJ MES 11089

Dante Galan

Dante Galan
Laboratory Director

NRSB ARL0001
NYS ELAP ID: 10806
PADEP ID: 0346
NJDEP ID: NY933
NJ MEB 90036
FL DOH RB1609
IL RNL2000201

Site Radon Inspection Report

Date : 11/01/2021

Mr. Seth Barry
MEDFORD SCHOOL DISTRICT
815 South Oakdale Avenue
Medford, OR 97501-

Client: Washington Elementary School
Test Location: 610 South Peach Street
Medford, OR 97501-

Individual Canister Results

Canister ID# : 2918258 Test Start : 10/26/2021 @ 06:20
Canister Type : Charcoal Canister 3 inch Test Stop : 10/28/2021 @ 06:33
Location : 1st FL=Rm 1 N. Wall Received: 11/01/2021 @ 14:53
Radon Level : 0.4 pCi/L Analyzed: 11/02/2021 @ 09:42
Error for Measurement is: \pm 0.4 pCi/L

Canister ID# : 2918262 Test Start : 10/26/2021 @ 06:12
Canister Type : Charcoal Canister 3 inch Test Stop : 10/28/2021 @ 06:30
Location : 1st FL=Media Ctr W.Rm Received: 11/01/2021 @ 14:54
Radon Level : 0.2 pCi/L Analyzed: 11/02/2021 @ 10:58
Error for Measurement is: \pm 0.4 pCi/L

Canister ID# : 2918284 Test Start : 10/26/2021 @ 06:00
Canister Type : Charcoal Canister 3 inch Test Stop : 10/28/2021 @ 06:21
Location : 1st FL=Rm 6 Received: 11/01/2021 @ 14:54
Radon Level : 0.8 pCi/L Analyzed: 11/02/2021 @ 12:06
Error for Measurement is: \pm 0.4 pCi/L

Canister ID# : 2918297 Test Start : 10/26/2021 @ 06:10
Canister Type : Charcoal Canister 3 inch Test Stop : 10/28/2021 @ 06:27
Location : 1st FL=Akita's Off. Received: 11/01/2021 @ 14:53
Radon Level : 0.4 pCi/L Analyzed: 11/02/2021 @ 09:57
Error for Measurement is: \pm 0.4 pCi/L

Canister ID# : 2918309 Test Start : 10/26/2021 @ 05:57
Canister Type : Charcoal Canister 3 inch Test Stop : 10/28/2021 @ 06:22
Location : 1st FL=Rm 10 Received: 11/01/2021 @ 14:54
Radon Level : 0.3 pCi/L Analyzed: 11/02/2021 @ 10:15
Error for Measurement is: \pm 0.5 pCi/L



Andreas C. George

Andreas C. George
Radon Measurement Specialist
NJ MES 11089

Dante Galan

Dante Galan
Laboratory Director

NRSB ARL0001
NYS ELAP ID: 10806
PADEP ID: 0346
NJDEP ID: NY933
NJ MEB 90036
FL DOH RB1609
IL RNL2000201

Site Radon Inspection Report

Date : 11/01/2021

Mr. Seth Barry
MEDFORD SCHOOL DISTRICT
815 South Oakdale Avenue
Medford, OR 97501-

Client: Washington Elementary School
Test Location: 610 South Peach Street
Medford, OR 97501-

Individual Canister Results

The results indicate that at least one testing device registered at or above the United States Environmental Protection Agency (EPA) action level of 4.0 picoCuries per liter of air (pCi/L). The EPA recommends mitigation if the average of two short-term tests taken in the lowest level of the building suitable for occupancy show radon levels that are equal to or greater than 4.0 pCi/L.

For information on how to reduce radon levels in your home, please review the EPA booklet: Consumer's Guide to Radon Reduction (www.epa.gov/radon/pdfs/consguid.pdf) and contact your state health department. The EPA maintains a radon information website, including copies of its publications, at www.epa.gov/iaq/radon.

For New Jersey clients: Please see the attached guidance document entitled Radon Testing and Mitigation: The Basics for further information.

For New York clients: If the radon level of one or more testing devices is equal to or exceeds 20 pCi/L please contact the New York State Department of Health, Bureau of Environmental Radiation Protection, for technical advice and assistance at 518-402-7556 or toll free 1-800-458-1158.

PLEDGE OF ASSURED QUALITY

All procedures used for generating this report are in complete accordance with the current EPA protocols for the analysis of radon in air (EPA 402-R-92-004). The analytical results relate only to the samples tested, in the condition received by the lab, and that calculations were based upon the information supplied by client. RTCA and its personnel do not assume responsibility or liability, collectively and individually, for analysis results when detectors have been improperly handled or placed by the consumer, nor does RTCA and its personnel accept responsibility for any financial or health consequences of subsequent action or lack of action, taken by the customer or its consultants based on RTCA-provided results.



Andreas C. George

Andreas C. George
Radon Measurement Specialist
NJ MES 11089

Dante Galan

Dante Galan
Laboratory Director

NRSB ARL0001
NYS ELAP ID: 10806
PADEP ID: 0346
NJDEP ID: NY933
NJ MEB 90036
FL DOH RB1609
IL RNL2000201