

Site Radon Inspection Report

Date : 12/20/2016

Ron Havnear or Bryan Cid-Hogan  
MEDFORD SCHOOL DISTRICT  
815 South Oakdale Avenue  
Medford, OR 97501-

Client: Wilson Elementary School-Code#549C  
Test Location: 1400 Johnson Street  
Medford, OR 97504-

Individual Canister Results

Canister ID# : 2503068                      Test Start : 12/13/2016 @ 06:40  
Canister Type : Charcoal Canister 3 inch      Test Stop : 12/15/2016 @ 08:18  
Location : 1st FI-Rm11                      Received: 12/20/2016 @ 12:54  
Radon Level : 6.7 pCi/L                      Analyzed: 12/21/2016 @ 15:36  
Error for Measurement is:  $\pm$  0.7 pCi/L

Canister ID# : 2503070                      Test Start : 12/13/2016 @ 06:15  
Canister Type : Charcoal Canister 3 inch      Test Stop : 12/15/2016 @ 08:10  
Location : 1st FI-Rm15                      Received: 12/20/2016 @ 12:54  
Radon Level : 2.4 pCi/L                      Analyzed: 12/21/2016 @ 15:36  
Error for Measurement is:  $\pm$  0.6 pCi/L

Canister ID# : 2503071                      Test Start : 12/13/2016 @ 06:33  
Canister Type : Charcoal Canister 3 inch      Test Stop : 12/15/2016 @ 08:02  
Location : 1st FI-Rm18                      Received: 12/20/2016 @ 12:54  
Radon Level : 2.5 pCi/L                      Analyzed: 12/21/2016 @ 15:06  
Error for Measurement is:  $\pm$  0.6 pCi/L

Canister ID# : 2503072                      Test Start : 12/13/2016 @ 06:15  
Canister Type : Charcoal Canister 3 inch      Test Stop : 12/15/2016 @ 07:56  
Location : 1st FI-Rm 6                      Received: 12/20/2016 @ 12:54  
Radon Level : 0.3 pCi/L                      Analyzed: 12/21/2016 @ 15:21  
Error for Measurement is:  $\pm$  0.6 pCi/L

Canister ID# : 2503073                      Test Start : 12/13/2016 @ 06:15  
Canister Type : Charcoal Canister 3 inch      Test Stop : 12/15/2016 @ 07:59  
Location : 1st FI-Staff Rm                      Received: 12/20/2016 @ 12:54  
Radon Level : 0.1 pCi/L                      Analyzed: 12/21/2016 @ 15:06  
Error for Measurement is:  $\pm$  0.2 pCi/L

Canister ID# : 2505283                      Test Start : 12/13/2016 @ 06:36  
Canister Type : Charcoal Canister 3 inch      Test Stop : 12/15/2016 @ 08:09  
Location : Stage                              Received: 12/20/2016 @ 12:54  
Radon Level : 0.9 pCi/L                      Analyzed: 12/21/2016 @ 15:06  
Error for Measurement is:  $\pm$  0.5 pCi/L



*Andreas C. George*

Andreas C. George  
Radon Measurement Specialist  
NJ MES 11089

*Dante Galan*

Dante Galan  
Laboratory Director

NRSB ARL0001  
NYS ELAP ID: 10806  
PADEP ID: 0346  
NJDEP ID: NY933  
NJ MEB 90036  
FL DOH RB1609  
IL RNL2000201

Site Radon Inspection Report

Date : 12/20/2016

Ron Havnear or Bryan Cid-Hogan  
MEDFORD SCHOOL DISTRICT  
815 South Oakdale Avenue  
Medford, OR 97501-

Client: Wilson Elementary School-Code#549C  
Test Location: 1400 Johnson Street  
Medford, OR 97504-

Individual Canister Results

Canister ID# : 2505380                      Test Start : 12/13/2016 @ 06:30  
Canister Type : Charcoal Canister 3 inch      Test Stop : 12/15/2016 @ 08:02  
Location : Work Rm/Staff                      Received: 12/20/2016 @ 12:54  
Radon Level : 0.6 pCi/L                      Analyzed: 12/21/2016 @ 15:36  
Error for Measurement is:  $\pm$  0.5 pCi/L

Canister ID# : 2505383                      Test Start : 12/13/2016 @ 06:35  
Canister Type : Charcoal Canister 3 inch      Test Stop : 12/15/2016 @ 08:16  
Location : 1st FI-Rm12                      Received: 12/20/2016 @ 12:54  
Radon Level : 7.5 pCi/L                      Analyzed: 12/21/2016 @ 15:36  
Error for Measurement is:  $\pm$  0.7 pCi/L

Canister ID# : 2505386                      Test Start : 12/13/2016 @ 06:38  
Canister Type : Charcoal Canister 3 inch      Test Stop : 12/15/2016 @ 08:04  
Location : Ground FI-NE Wall on shelf      Received: 12/20/2016 @ 12:54  
Radon Level : 2.5 pCi/L                      Analyzed: 12/21/2016 @ 15:06  
Error for Measurement is:  $\pm$  0.7 pCi/L

Canister ID# : 2505387                      Test Start : 12/13/2016 @ 06:19  
Canister Type : Charcoal Canister 3 inch      Test Stop : 12/15/2016 @ 08:01  
Location : 1st FI-Media Cut#1                  Received: 12/20/2016 @ 12:54  
Radon Level : 0.1 pCi/L                      Analyzed: 12/21/2016 @ 15:36  
Error for Measurement is:  $\pm$  0.6 pCi/L

Canister ID# : 2505390                      Test Start : 12/13/2016 @ 06:57  
Canister Type : Charcoal Canister 3 inch      Test Stop : 12/15/2016 @ 08:20  
Location : Gym/Stage                      Received: 12/20/2016 @ 12:54  
Radon Level : 0.4 pCi/L                      Analyzed: 12/21/2016 @ 15:21  
Error for Measurement is:  $\pm$  0.4 pCi/L

Canister ID# : 2505392                      Test Start : 12/13/2016 @ 06:50  
Canister Type : Charcoal Canister 3 inch      Test Stop : 12/15/2016 @ 08:07  
Location : 1st FI-Cafeteria                  Received: 12/20/2016 @ 12:54  
Radon Level : 0.1 pCi/L                      Analyzed: 12/21/2016 @ 15:21  
Error for Measurement is:  $\pm$  0.4 pCi/L



*Andreas C. George*

Andreas C. George  
Radon Measurement Specialist  
NJ MES 11089

*Dante Galan*

Dante Galan  
Laboratory Director

NRSB ARL0001  
NYS ELAP ID: 10806  
PADEP ID: 0346  
NJDEP ID: NY933  
NJ MEB 90036  
FL DOH RB1609  
IL RNL2000201

Site Radon Inspection Report

Date : 12/20/2016

Ron Havnear or Bryan Cid-Hogan  
MEDFORD SCHOOL DISTRICT  
815 South Oakdale Avenue  
Medford, OR 97501-

Client: Wilson Elementary School-Code#549C  
Test Location: 1400 Johnson Street  
Medford, OR 97504-

Individual Canister Results

Canister ID# : 2505394                      Test Start : 12/13/2016 @ 06:15  
Canister Type : Charcoal Canister 3 inch      Test Stop : 12/15/2016 @ 07:59  
Location : BLANK-1st FI-Staff Rm              Received: 12/20/2016 @ 12:54  
Radon Level : 0.2 pCi/L                      Analyzed: 12/21/2016 @ 15:51  
Error for Measurement is:  $\pm$  0.4 pCi/L

Canister ID# : 2505395                      Test Start : 12/13/2016 @ 06:20  
Canister Type : Charcoal Canister 3 inch      Test Stop : 12/15/2016 @ 08:00  
Location : 1st FI-Conf. Rm 103                Received: 12/20/2016 @ 12:54  
Radon Level : 2.3 pCi/L                      Analyzed: 12/21/2016 @ 14:49  
Error for Measurement is:  $\pm$  0.7 pCi/L

Canister ID# : 2505397                      Test Start : 12/13/2016 @ 06:20  
Canister Type : Charcoal Canister 3 inch      Test Stop : 12/15/2016 @ 08:00  
Location : 1st FI-21                              Received: 12/20/2016 @ 12:54  
Radon Level : 1.7 pCi/L                      Analyzed: 12/21/2016 @ 15:21  
Error for Measurement is:  $\pm$  0.5 pCi/L

Canister ID# : 2505399                      Test Start : 12/13/2016 @ 06:57  
Canister Type : Charcoal Canister 3 inch      Test Stop : 12/15/2016 @ 08:08  
Location : BLANK-Ground FI-Rm5              Received: 12/20/2016 @ 12:54  
Radon Level : 0.1 pCi/L                      Analyzed: 12/21/2016 @ 15:21  
Error for Measurement is:  $\pm$  0.5 pCi/L

Canister ID# : 2505400                      Test Start : 12/13/2016 @ 06:25  
Canister Type : Charcoal Canister 3 inch      Test Stop : 12/15/2016 @ 08:00  
Location : 1st FI-7                                Received: 12/20/2016 @ 12:54  
Radon Level : 3.8 pCi/L                      Analyzed: 12/21/2016 @ 14:49  
Error for Measurement is:  $\pm$  0.7 pCi/L

Canister ID# : 2505402                      Test Start : 12/13/2016 @ 06:15  
Canister Type : Charcoal Canister 3 inch      Test Stop : 12/15/2016 @ 07:59  
Location : 1st FI-Staff Rm                      Received: 12/20/2016 @ 12:54  
Radon Level : 0.2 pCi/L                      Analyzed: 12/21/2016 @ 15:51  
Error for Measurement is:  $\pm$  0.6 pCi/L



*Andreas C. George*

Andreas C. George  
Radon Measurement Specialist  
NJ MES 11089

*Dante Galan*

Dante Galan  
Laboratory Director

NRSB ARL0001  
NYS ELAP ID: 10806  
PADEP ID: 0346  
NJDEP ID: NY933  
NJ MEB 90036  
FL DOH RB1609  
IL RNL2000201

Site Radon Inspection Report

Date : 12/20/2016

Ron Havnear or Bryan Cid-Hogan  
MEDFORD SCHOOL DISTRICT  
815 South Oakdale Avenue  
Medford, OR 97501-

Client: Wilson Elementary School-Code#549C  
Test Location: 1400 Johnson Street  
Medford, OR 97504-

Individual Canister Results

Canister ID# : 2505403                      Test Start : 12/13/2016 @ 06:35  
Canister Type : Charcoal Canister 3 inch      Test Stop : 12/15/2016 @ 08:16  
Location : 1st FI-Rm12                      Received: 12/20/2016 @ 12:54  
Radon Level : 7.6 pCi/L                      Analyzed: 12/21/2016 @ 15:51  
Error for Measurement is:  $\pm$  0.7 pCi/L

Canister ID# : 2505410                      Test Start : 12/13/2016 @ 06:31  
Canister Type : Charcoal Canister 3 inch      Test Stop : 12/15/2016 @ 06:31  
Location : BLANK-1st FI-Rm28                  Received: 12/20/2016 @ 12:54  
Radon Level : 0.1 pCi/L                      Analyzed: 12/21/2016 @ 15:21  
Error for Measurement is:  $\pm$  0.4 pCi/L

**Canister ID# :** 2505413                      Test Start : 12/13/2016 @ 05:45  
**Canister Type :** Charcoal Canister 3 inch      Test Stop : 12/15/2016 @ 07:45  
**Location :** 1st FI-29                          Received: 12/20/2016 @ 12:54  
**Radon Level :** 17.2 pCi/L                      Analyzed: 12/21/2016 @ 15:06  
Error for Measurement is:  $\pm$  0.9 pCi/L

This is a quality control test known as a spike. This canister has never been on the school site.

Canister ID# : 2505414                      Test Start : 12/13/2016 @ 06:33  
Canister Type : Charcoal Canister 3 inch      Test Stop : 12/15/2016 @ 08:08  
Location : 1st FI-Gym#2                      Received: 12/20/2016 @ 12:54  
Radon Level : 0.7 pCi/L                      Analyzed: 12/21/2016 @ 15:21  
Error for Measurement is:  $\pm$  0.5 pCi/L

Canister ID# : 2505415                      Test Start : 12/13/2016 @ 06:25  
Canister Type : Charcoal Canister 3 inch      Test Stop : 12/15/2016 @ 08:10  
Location : BLANK-Principal's                  Received: 12/20/2016 @ 12:54  
Radon Level : 0.1 pCi/L                      Analyzed: 12/21/2016 @ 15:21  
Error for Measurement is:  $\pm$  0.5 pCi/L

Canister ID# : 2505446                      Test Start : 12/13/2016 @ 06:19  
Canister Type : Charcoal Canister 3 inch      Test Stop : 12/15/2016 @ 07:58  
Location : 1st FI-Rm16                      Received: 12/20/2016 @ 12:54  
Radon Level : 1.3 pCi/L                      Analyzed: 12/21/2016 @ 15:36  
Error for Measurement is:  $\pm$  0.6 pCi/L



*Andreas C. George*

Andreas C. George  
Radon Measurement Specialist  
NJ MES 11089

*Dante Galan*

Dante Galan  
Laboratory Director

NRSB ARL0001  
NYS ELAP ID: 10806  
PADEP ID: 0346  
NJDEP ID: NY933  
NJ MEB 90036  
FL DOH RB1609  
IL RNL2000201

Site Radon Inspection Report

Date : 12/20/2016

Ron Havnear or Bryan Cid-Hogan  
MEDFORD SCHOOL DISTRICT  
815 South Oakdale Avenue  
Medford, OR 97501-

Client: Wilson Elementary School-Code#549C  
Test Location: 1400 Johnson Street  
Medford, OR 97504-

Individual Canister Results

Canister ID# : 2505695                      Test Start : 12/13/2016 @ 06:29  
Canister Type : Charcoal Canister 3 inch      Test Stop : 12/15/2016 @ 08:03  
Location : BLANK-1st FI-8                      Received: 12/20/2016 @ 12:54  
Radon Level : 0.1 pCi/L                      Analyzed: 12/21/2016 @ 15:51  
Error for Measurement is: ± 0.1 pCi/L

Canister ID# : 2505714                      Test Start : 12/13/2016 @ 06:30  
Canister Type : Charcoal Canister 3 inch      Test Stop : 12/15/2016 @ 08:02  
Location : Work Rm/Staff                      Received: 12/20/2016 @ 12:54  
Radon Level : 0.1 pCi/L                      Analyzed: 12/21/2016 @ 15:51  
Error for Measurement is: ± 0.6 pCi/L

Canister ID# : 2505719                      Test Start : 12/13/2016 @ 06:35  
Canister Type : Charcoal Canister 3 inch      Test Stop : 12/15/2016 @ 08:03  
Location : 1st FI-9                              Received: 12/20/2016 @ 12:54  
Radon Level : 1.8 pCi/L                      Analyzed: 12/21/2016 @ 15:21  
Error for Measurement is: ± 0.6 pCi/L

Canister ID# : 2505720                      Test Start : 12/13/2016 @ 06:40  
Canister Type : Charcoal Canister 3 inch      Test Stop : 12/15/2016 @ 08:12  
Location : 1st FI-Rm26                      Received: 12/20/2016 @ 12:54  
Radon Level : 0.2 pCi/L                      Analyzed: 12/21/2016 @ 15:51  
Error for Measurement is: ± 0.6 pCi/L

Canister ID# : 2505721                      Test Start : 12/13/2016 @ 06:23  
Canister Type : Charcoal Canister 3 inch      Test Stop : 12/15/2016 @ 08:13  
Location : 1st FI-Rm14                      Received: 12/20/2016 @ 12:54  
Radon Level : 2.9 pCi/L                      Analyzed: 12/21/2016 @ 15:51  
Error for Measurement is: ± 0.6 pCi/L

Canister ID# : 2505722                      Test Start : 12/13/2016 @ 06:47  
Canister Type : Charcoal Canister 3 inch      Test Stop : 12/15/2016 @ 08:06  
Location : Ground FI-Rm4 under desk      Received: 12/20/2016 @ 12:54  
Radon Level : 3.7 pCi/L                      Analyzed: 12/21/2016 @ 15:36  
Error for Measurement is: ± 0.6 pCi/L



*Andreas C. George*

Andreas C. George  
Radon Measurement Specialist  
NJ MES 11089

*Dante Galan*

Dante Galan  
Laboratory Director

NRSB ARL0001  
NYS ELAP ID: 10806  
PADEP ID: 0346  
NJDEP ID: NY933  
NJ MEB 90036  
FL DOH RB1609  
IL RNL2000201

Site Radon Inspection Report

Date : 12/20/2016

Ron Havnear or Bryan Cid-Hogan  
MEDFORD SCHOOL DISTRICT  
815 South Oakdale Avenue  
Medford, OR 97501-

Client: Wilson Elementary School-Code#549C  
Test Location: 1400 Johnson Street  
Medford, OR 97504-

Individual Canister Results

Canister ID# : 2505724                      Test Start : 12/13/2016 @ 06:30  
Canister Type : Charcoal Canister 3 inch      Test Stop : 12/15/2016 @ 08:01  
Location : 1st FI-8                      Received: 12/20/2016 @ 12:54  
Radon Level : 3.2 pCi/L                      Analyzed: 12/21/2016 @ 15:06  
Error for Measurement is:  $\pm$  0.6 pCi/L

Canister ID# : 2505725                      Test Start : 12/13/2016 @ 06:40  
Canister Type : Charcoal Canister 3 inch      Test Stop : 12/15/2016 @ 08:04  
Location : 1st FI-10                      Received: 12/20/2016 @ 12:54  
Radon Level : 2.9 pCi/L                      Analyzed: 12/21/2016 @ 15:36  
Error for Measurement is:  $\pm$  0.6 pCi/L

Canister ID# : 2505726                      Test Start : 12/13/2016 @ 06:15  
Canister Type : Charcoal Canister 3 inch      Test Stop : 12/15/2016 @ 07:59  
Location : 1st FI-Rm 107                      Received: 12/20/2016 @ 12:54  
Radon Level : 2.3 pCi/L                      Analyzed: 12/21/2016 @ 15:06  
Error for Measurement is:  $\pm$  0.6 pCi/L

Canister ID# : 2505728                      Test Start : 12/13/2016 @ 06:42  
Canister Type : Charcoal Canister 3 inch      Test Stop : 12/15/2016 @ 08:03  
Location : 1st FI-Rm19                      Received: 12/20/2016 @ 12:54  
Radon Level : 2.4 pCi/L                      Analyzed: 12/21/2016 @ 14:49  
Error for Measurement is:  $\pm$  0.6 pCi/L

Canister ID# : 2505736                      Test Start : 12/13/2016 @ 06:20  
Canister Type : Charcoal Canister 3 inch      Test Stop : 12/15/2016 @ 07:58  
Location : 1st FI-Rm16                      Received: 12/20/2016 @ 12:54  
Radon Level : 1.7 pCi/L                      Analyzed: 12/21/2016 @ 15:21  
Error for Measurement is:  $\pm$  0.6 pCi/L

Canister ID# : 2505751                      Test Start : 12/13/2016 @ 06:22  
Canister Type : Charcoal Canister 3 inch      Test Stop : 12/15/2016 @ 07:57  
Location : 1st FI-7                      Received: 12/20/2016 @ 12:54  
Radon Level : 4.4 pCi/L                      Analyzed: 12/21/2016 @ 15:36  
Error for Measurement is:  $\pm$  0.7 pCi/L



*Andreas C. George*

Andreas C. George  
Radon Measurement Specialist  
NJ MES 11089

*Dante Galan*

Dante Galan  
Laboratory Director

NRSB ARL0001  
NYS ELAP ID: 10806  
PADEP ID: 0346  
NJDEP ID: NY933  
NJ MEB 90036  
FL DOH RB1609  
IL RNL2000201



Site Radon Inspection Report

Date : 12/20/2016

Ron Havnear or Bryan Cid-Hogan  
MEDFORD SCHOOL DISTRICT  
815 South Oakdale Avenue  
Medford, OR 97501-

Client: Wilson Elementary School-Code#549C  
Test Location: 1400 Johnson Street  
Medford, OR 97504-

Individual Canister Results

Canister ID# : 2505754  
Canister Type : Charcoal Canister 3 inch  
Location : 1st FI-31  
Radon Level : 16.4 pCi/L  
Error for Measurement is: ± 0.8 pCi/L

Test Start : 12/13/2016 @ 05:55  
Test Stop : 12/15/2016 @ 07:48  
Received: 12/20/2016 @ 12:54  
Analyzed: 12/21/2016 @ 15:21

This is a quality control test known as a spike. This canister has never been on the school site.

Canister ID# : 2505758  
Canister Type : Charcoal Canister 3 inch  
Location : 1st FI-Rm17  
Radon Level : 3.0 pCi/L  
Error for Measurement is: ± 0.5 pCi/L

Test Start : 12/13/2016 @ 06:27  
Test Stop : 12/15/2016 @ 08:01  
Received: 12/20/2016 @ 12:54  
Analyzed: 12/21/2016 @ 15:06

Canister ID# : 2505786  
Canister Type : Charcoal Canister 3 inch  
Location : 1st FI-Rm27  
Radon Level : 0.1 pCi/L  
Error for Measurement is: ± 0.4 pCi/L

Test Start : 12/13/2016 @ 06:21  
Test Stop : 12/15/2016 @ 08:14  
Received: 12/20/2016 @ 12:54  
Analyzed: 12/21/2016 @ 14:49

Canister ID# : 2505789  
Canister Type : Charcoal Canister 3 inch  
Location : BLANK-1st FI-Rm14  
Radon Level : 0.1 pCi/L  
Error for Measurement is: ± 0.4 pCi/L

Test Start : 12/13/2016 @ 06:23  
Test Stop : 12/15/2016 @ 08:13  
Received: 12/20/2016 @ 12:54  
Analyzed: 12/21/2016 @ 15:06

Canister ID# : 2505790  
Canister Type : Charcoal Canister 3 inch  
Location : 1st FI-22  
Radon Level : 1.6 pCi/L  
Error for Measurement is: ± 0.6 pCi/L

Test Start : 12/13/2016 @ 06:20  
Test Stop : 12/15/2016 @ 08:02  
Received: 12/20/2016 @ 12:54  
Analyzed: 12/21/2016 @ 15:06

Canister ID# : 2505793  
Canister Type : Charcoal Canister 3 inch  
Location : 1st FI-25  
Radon Level : 2.2 pCi/L  
Error for Measurement is: ± 0.6 pCi/L

Test Start : 12/13/2016 @ 06:50  
Test Stop : 12/15/2016 @ 08:07  
Received: 12/20/2016 @ 12:54  
Analyzed: 12/21/2016 @ 15:21



*Andreas C. George*

Andreas C. George  
Radon Measurement Specialist  
NJ MES 11089

*Dante Galan*

Dante Galan  
Laboratory Director

NRSB ARL0001  
NYS ELAP ID: 10806  
PADEP ID: 0346  
NJDEP ID: NY933  
NJ MEB 90036  
FL DOH RB1609  
IL RNL2000201

Site Radon Inspection Report

Date : 12/20/2016

Ron Havnear or Bryan Cid-Hogan  
MEDFORD SCHOOL DISTRICT  
815 South Oakdale Avenue  
Medford, OR 97501-

Client: Wilson Elementary School-Code#549C  
Test Location: 1400 Johnson Street  
Medford, OR 97504-

Individual Canister Results

Canister ID# : 2505796                      Test Start : 12/13/2016 @ 06:26  
Canister Type : Charcoal Canister 3 inch      Test Stop : 12/15/2016 @ 08:15  
Location : 1st FI-Rm28                      Received: 12/20/2016 @ 12:54  
Radon Level : 0.1 pCi/L                      Analyzed: 12/21/2016 @ 14:49  
Error for Measurement is:  $\pm$  0.5 pCi/L

Canister ID# : 2529041                      Test Start : 12/13/2016 @ 06:46  
Canister Type : Charcoal Canister 3 inch      Test Stop : 12/15/2016 @ 08:06  
Location : Cafeteria                      Received: 12/20/2016 @ 12:54  
Radon Level : 1.2 pCi/L                      Analyzed: 12/21/2016 @ 15:21  
Error for Measurement is:  $\pm$  0.5 pCi/L

Canister ID# : 2529042                      Test Start : 12/13/2016 @ 05:50  
Canister Type : Charcoal Canister 3 inch      Test Stop : 12/15/2016 @ 07:47  
Location : 1st FI-30                      Received: 12/20/2016 @ 12:54  
Radon Level : 16.1 pCi/L                      Analyzed: 12/21/2016 @ 15:36  
Error for Measurement is:  $\pm$  0.8 pCi/L

This is a quality control test known as a spike. This canister has never been on the school site.

Canister ID# : 2529043                      Test Start : 12/13/2016 @ 06:07  
Canister Type : Charcoal Canister 3 inch      Test Stop : 12/15/2016 @ 07:58  
Location : 1st FI-Office                      Received: 12/20/2016 @ 12:54  
Radon Level : 1.8 pCi/L                      Analyzed: 12/21/2016 @ 15:36  
Error for Measurement is:  $\pm$  0.6 pCi/L

Canister ID# : 2529044                      Test Start : 12/13/2016 @ 06:40  
Canister Type : Charcoal Canister 3 inch      Test Stop : 12/15/2016 @ 08:05  
Location : 1st FI-24                      Received: 12/20/2016 @ 12:54  
Radon Level : 1.2 pCi/L                      Analyzed: 12/21/2016 @ 15:21  
Error for Measurement is:  $\pm$  0.6 pCi/L

Canister ID# : 2529045                      Test Start : 12/13/2016 @ 06:57  
Canister Type : Charcoal Canister 3 inch      Test Stop : 12/15/2016 @ 08:08  
Location : Ground FI-Rm5 SE corner      Received: 12/20/2016 @ 12:54  
Radon Level : 1.8 pCi/L                      Analyzed: 12/21/2016 @ 15:06  
Error for Measurement is:  $\pm$  0.6 pCi/L



*Andreas C. George*

*Dante Galan*

Andreas C. George  
Radon Measurement Specialist  
NJ MES 11089

Dante Galan  
Laboratory Director

NRSB ARL0001  
NYS ELAP ID: 10806  
PADEP ID: 0346  
NJDEP ID: NY933  
NJ MEB 90036  
FL DOH RB1609  
IL RNL2000201



Site Radon Inspection Report

Date : 12/20/2016

Ron Havnear or Bryan Cid-Hogan  
MEDFORD SCHOOL DISTRICT  
815 South Oakdale Avenue  
Medford, OR 97501-

Client: Wilson Elementary School-Code#549C  
Test Location: 1400 Johnson Street  
Medford, OR 97504-

Individual Canister Results

Canister ID# : 2529046                      Test Start : 12/13/2016 @ 06:40  
Canister Type : Charcoal Canister 3 inch      Test Stop : 12/15/2016 @ 08:05  
Location : BLANK-1st FI-24                      Received: 12/20/2016 @ 12:54  
Radon Level : 0.1 pCi/L                      Analyzed: 12/21/2016 @ 15:06  
Error for Measurement is:  $\pm$  0.2 pCi/L

Canister ID# : 2529048                      Test Start : 12/13/2016 @ 06:27  
Canister Type : Charcoal Canister 3 inch      Test Stop : 12/15/2016 @ 08:00  
Location : Ground FI-Rm2 NE Corner          Received: 12/20/2016 @ 12:54  
Radon Level : 2.8 pCi/L                      Analyzed: 12/21/2016 @ 15:06  
Error for Measurement is:  $\pm$  0.6 pCi/L

Canister ID# : 2529049                      Test Start : 12/13/2016 @ 06:57  
Canister Type : Charcoal Canister 3 inch      Test Stop : 12/15/2016 @ 08:06  
Location : 1st FI-Rm20                      Received: 12/20/2016 @ 12:54  
Radon Level : 1.1 pCi/L                      Analyzed: 12/21/2016 @ 15:51  
Error for Measurement is:  $\pm$  0.6 pCi/L

Canister ID# : 2529050                      Test Start : 12/13/2016 @ 06:46  
Canister Type : Charcoal Canister 3 inch      Test Stop : 12/15/2016 @ 08:03  
Location : BLANK-1st FI-Rm19                  Received: 12/20/2016 @ 12:54  
Radon Level : 0.1 pCi/L                      Analyzed: 12/21/2016 @ 15:51  
Error for Measurement is:  $\pm$  0.3 pCi/L

Canister ID# : 2529052                      Test Start : 12/13/2016 @ 06:17  
Canister Type : Charcoal Canister 3 inch      Test Stop : 12/15/2016 @ 08:14  
Location : 1st FI-Rm27                      Received: 12/20/2016 @ 12:54  
Radon Level : 0.3 pCi/L                      Analyzed: 12/21/2016 @ 15:51  
Error for Measurement is:  $\pm$  0.6 pCi/L

Canister ID# : 2529053                      Test Start : 12/13/2016 @ 06:33  
Canister Type : Charcoal Canister 3 inch      Test Stop : 12/15/2016 @ 08:04  
Location : 1st FI-23                      Received: 12/20/2016 @ 12:54  
Radon Level : 5.9 pCi/L                      Analyzed: 12/21/2016 @ 15:21  
Error for Measurement is:  $\pm$  0.7 pCi/L



*Andreas C. George*

Andreas C. George  
Radon Measurement Specialist  
NJ MES 11089

*Dante Galan*

Dante Galan  
Laboratory Director

NRSB ARL0001  
NYS ELAP ID: 10806  
PADEP ID: 0346  
NJDEP ID: NY933  
NJ MEB 90036  
FL DOH RB1609  
IL RNL2000201

Site Radon Inspection Report

Date : 12/20/2016

Ron Havnear or Bryan Cid-Hogan  
MEDFORD SCHOOL DISTRICT  
815 South Oakdale Avenue  
Medford, OR 97501-

Client: Wilson Elementary School-Code#549C  
Test Location: 1400 Johnson Street  
Medford, OR 97504-

Individual Canister Results

Canister ID# : 2529054                      Test Start : 12/13/2016 @ 06:29  
Canister Type : Charcoal Canister 3 inch      Test Stop : 12/15/2016 @ 08:14  
Location : 1st FI-Rm13                      Received: 12/20/2016 @ 12:54  
Radon Level : 5.9 pCi/L                      Analyzed: 12/21/2016 @ 15:06  
Error for Measurement is:  $\pm$  0.7 pCi/L

Canister ID# : 2529055                      Test Start : 12/13/2016 @ 06:25  
Canister Type : Charcoal Canister 3 inch      Test Stop : 12/15/2016 @ 08:00  
Location : Ground FI-Rm2 NE Corner      Received: 12/20/2016 @ 12:54  
Radon Level : 2.8 pCi/L                      Analyzed: 12/21/2016 @ 15:06  
Error for Measurement is:  $\pm$  0.6 pCi/L

Canister ID# : 2529058                      Test Start : 12/13/2016 @ 06:28  
Canister Type : Charcoal Canister 3 inch      Test Stop : 12/15/2016 @ 08:07  
Location : 1st FI-Gym#1                      Received: 12/20/2016 @ 12:54  
Radon Level : 0.5 pCi/L                      Analyzed: 12/21/2016 @ 15:51  
Error for Measurement is:  $\pm$  0.5 pCi/L

Canister ID# : 2529059                      Test Start : 12/13/2016 @ 06:20  
Canister Type : Charcoal Canister 3 inch      Test Stop : 12/15/2016 @ 08:00  
Location : 1st FI-21                          Received: 12/20/2016 @ 12:54  
Radon Level : 1.6 pCi/L                      Analyzed: 12/21/2016 @ 15:36  
Error for Measurement is:  $\pm$  0.6 pCi/L

Canister ID# : 2529060                      Test Start : 12/13/2016 @ 06:25  
Canister Type : Charcoal Canister 3 inch      Test Stop : 12/15/2016 @ 08:10  
Location : Principal                          Received: 12/20/2016 @ 12:54  
Radon Level : 0.7 pCi/L                      Analyzed: 12/21/2016 @ 15:06  
Error for Measurement is:  $\pm$  0.5 pCi/L

Canister ID# : 2529063                      Test Start : 12/13/2016 @ 06:23  
Canister Type : Charcoal Canister 3 inch      Test Stop : 12/15/2016 @ 08:03  
Location : 1st FI-Comp. Rm                  Received: 12/20/2016 @ 12:54  
Radon Level : 0.6 pCi/L                      Analyzed: 12/21/2016 @ 15:51  
Error for Measurement is:  $\pm$  0.5 pCi/L



*Andreas C. George*

Andreas C. George  
Radon Measurement Specialist  
NJ MES 11089

*Dante Galan*

Dante Galan  
Laboratory Director

NRSB ARL0001  
NYS ELAP ID: 10806  
PADEP ID: 0346  
NJDEP ID: NY933  
NJ MEB 90036  
FL DOH RB1609  
IL RNL2000201



Site Radon Inspection Report

Date : 12/20/2016

Ron Havniear or Bryan Cid-Hogan  
MEDFORD SCHOOL DISTRICT  
815 South Oakdale Avenue  
Medford, OR 97501-

Client: Wilson Elementary School-Code#549C  
Test Location: 1400 Johnson Street  
Medford, OR 97504-  
Individual Canister Results

---

**PLEDGE OF ASSURED QUALITY**

All procedures used for generating this report are in complete accordance with the current EPA protocols for the analysis of radon in air (EPA 402-R-92-004). The analytical results relate only to the samples tested, in the condition received by the lab, and that calculations were based upon the information supplied by client. RTCA and its personnel do not assume responsibility or liability, collectively and individually, for analysis results when detectors have been improperly handled or placed by the consumer, nor does RTCA and its personnel accept responsibility for any financial or health consequences of subsequent action or lack of action, taken by the customer or its consultants based on RTCA-provided results.



*Andreas C. George*

Andreas C. George  
Radon Measurement Specialist  
NJ MES 11089

*Dante Galan*

Dante Galan  
Laboratory Director

NRSB ARL0001  
NYS ELAP ID: 10806  
PADEP ID: 0346  
NJDEP ID: NY933  
NJ MEB 90036  
FL DOH RB1609  
IL RNL2000201