

Site Radon Inspection Report

Date : 10/17/2018

Mr. Bryan Hogan
MEDFORD SCHOOL DISTRICT
815 South Oakdale Avenue
Medford, OR 97501-

Client: McLoughlin Middle School
Test Location: 320 West 2nd Street
Medford, OR 97501-

Individual Canister Results

Canister ID# : 2612014 Test Start : 10/09/2018 @ 06:17
Canister Type : Charcoal Canister 3 inch Test Stop : 10/11/2018 @ 06:26
Location : 1st FL=Rm 110 DP Received: 10/15/2018 @ 10:40
Radon Level : **0.3 pCi/L** Analyzed: 10/16/2018 @ 16:06
Error for Measurement is: ± 0.4 pCi/L

Canister ID# : 2612020 Test Start : 10/09/2018 @ 06:05
Canister Type : Charcoal Canister 3 inch Test Stop : 10/11/2018 @ 06:17
Location : 1st FL=Band Rm #1 Received: 10/15/2018 @ 10:40
Radon Level : **0.2 pCi/L** Analyzed: 10/16/2018 @ 15:48
Error for Measurement is: ± 0.5 pCi/L

Canister ID# : 2612027 Test Start : 10/09/2018 @ 05:27
Canister Type : Charcoal Canister 3 inch Test Stop : 10/11/2018 @ 05:27
Location : 1st FL=SRO Office Received: 10/15/2018 @ 10:40
Radon Level : **0.1 pCi/L** Analyzed: 10/16/2018 @ 15:14
Error for Measurement is: ± 0.4 pCi/L

Canister ID# : 2612040 Test Start : 10/09/2018 @ 06:34
Canister Type : Charcoal Canister 3 inch Test Stop : 10/11/2018 @ 06:37
Location : 1st FL=Wrestling Rm #2 Received: 10/15/2018 @ 10:40
Radon Level : **0.1 pCi/L** Analyzed: 10/16/2018 @ 16:20
Error for Measurement is: ± 0.4 pCi/L

Canister ID# : 2612043 Test Start : 10/09/2018 @ 06:06
Canister Type : Charcoal Canister 3 inch Test Stop : 10/11/2018 @ 06:19
Location : 1st FL=Band Rm #2 Received: 10/15/2018 @ 10:40
Radon Level : **0.1 pCi/L** Analyzed: 10/16/2018 @ 16:06
Error for Measurement is: ± 0.4 pCi/L

Canister ID# : 2612046 Test Start : 10/09/2018 @ 06:07
Canister Type : Charcoal Canister 3 inch Test Stop : 10/11/2018 @ 06:07
Location : 1st FL=Rm 112 Received: 10/15/2018 @ 10:40
Radon Level : **0.2 pCi/L** Analyzed: 10/16/2018 @ 15:17



Andreas C. George

Dante Galan

Andreas C. George
Radon Measurement Specialist
NJ MES 11089

Dante Galan
Laboratory Director

NRSB ARL0001
NYS ELAP ID: 10806
PADEP ID: 0346
NJDEP ID: NY933
NJ MEB 90036
FL DOH RB1609
IL RNL2000201

Site Radon Inspection Report

Date : 10/17/2018

Error for Measurement is: \pm 0.4 pCi/L

Canister ID# : 2612049
Canister Type : Charcoal Canister 3 inch
Location : 1st FL=Wrestling Rm #1
Radon Level : **0.1 pCi/L**
Error for Measurement is: \pm 0.5 pCi/L

Test Start : 10/09/2018 @ 06:33
Test Stop : 10/11/2018 @ 06:35
Received: 10/15/2018 @ 10:40
Analyzed: 10/16/2018 @ 16:04

Canister ID# : 2612052
Canister Type : Charcoal Canister 3 inch
Location : 1st FL=Main Off.
Radon Level : **0.4 pCi/L**
Error for Measurement is: \pm 0.6 pCi/L

Test Start : 10/09/2018 @ 05:12
Test Stop : 10/11/2018 @ 05:17
Received: 10/15/2018 @ 10:40
Analyzed: 10/16/2018 @ 15:48

Canister ID# : 2612053
Canister Type : Charcoal Canister 3 inch
Location : 1st FL=Gold Gym #4
Radon Level : **0.4 pCi/L**
Error for Measurement is: \pm 0.5 pCi/L

Test Start : 10/09/2018 @ 06:15
Test Stop : 10/11/2018 @ 06:19
Received: 10/15/2018 @ 10:40
Analyzed: 10/16/2018 @ 15:15

Canister ID# : 2612057
Canister Type : Charcoal Canister 3 inch
Location : 1st FL=Rm 108
Radon Level : **0.1 pCi/L**
Error for Measurement is: \pm 0.5 pCi/L

Test Start : 10/09/2018 @ 06:13
Test Stop : 10/11/2018 @ 06:14
Received: 10/15/2018 @ 10:40
Analyzed: 10/16/2018 @ 16:22

Canister ID# : 2612064
Canister Type : Charcoal Canister 3 inch
Location : 1st FL=Custodial Off.
Radon Level : **0.8 pCi/L**
Error for Measurement is: \pm 0.4 pCi/L

Test Start : 10/09/2018 @ 06:24
Test Stop : 10/11/2018 @ 06:24
Received: 10/15/2018 @ 10:40
Analyzed: 10/16/2018 @ 15:33

Canister ID# : 2612067
Canister Type : Charcoal Canister 3 inch
Location : 1st FL=Media Off. B
Radon Level : **0.1 pCi/L**
Error for Measurement is: \pm 0.6 pCi/L

Test Start : 10/09/2018 @ 06:10
Test Stop : 10/11/2018 @ 06:12
Received: 10/15/2018 @ 10:40
Analyzed: 10/16/2018 @ 16:20

Canister ID# : 2612068
Canister Type : Charcoal Canister 3 inch
Location : 1st FL=Rm 111
Radon Level : **0.1 pCi/L**
Error for Measurement is: \pm 0.6 pCi/L

Test Start : 10/09/2018 @ 06:26
Test Stop : 10/11/2018 @ 06:32
Received: 10/15/2018 @ 10:40
Analyzed: 10/16/2018 @ 15:50



Andreas C. George

Andreas C. George
Radon Measurement Specialist
NJ MES 11089

Dante Galan

Dante Galan
Laboratory Director

NRSB ARL0001
NYS ELAP ID: 10806
PADEP ID: 0346
NJDEP ID: NY933
NJ MEB 90036
FL DOH RB1609
IL RNL2000201

Site Radon Inspection Report

Date : 10/17/2018

Canister ID# : 2612069 Test Start : 10/09/2018 @ 06:17
Canister Type : Charcoal Canister 3 inch Test Stop : 10/11/2018 @ 06:26
Location : 1st FL=Rm 110 Received: 10/15/2018 @ 10:40
Radon Level : **0.4 pCi/L** Analyzed: 10/16/2018 @ 16:06
Error for Measurement is: ± 0.5 pCi/L

Canister ID# : 2612074 Test Start : 10/09/2018 @ 06:06
Canister Type : Charcoal Canister 3 inch Test Stop : 10/11/2018 @ 06:08
Location : 1st FL=Rm 106 Received: 10/15/2018 @ 10:40
Radon Level : **0.1 pCi/L** Analyzed: 10/16/2018 @ 15:33
Error for Measurement is: ± 0.2 pCi/L

Canister ID# : 2612091 Test Start : 10/09/2018 @ 06:12
Canister Type : Charcoal Canister 3 inch Test Stop : 10/11/2018 @ 06:24
Location : 1st FL=Band Off. B Received: 10/15/2018 @ 10:40
Radon Level : **0.4 pCi/L** Analyzed: 10/16/2018 @ 16:22
Error for Measurement is: ± 0.5 pCi/L

Canister ID# : 2612105 Test Start : 10/09/2018 @ 06:12
Canister Type : Charcoal Canister 3 inch Test Stop : 10/11/2018 @ 06:12
Location : 1st FL=LG Group Rm #1 Received: 10/15/2018 @ 10:40
Radon Level : **0.4 pCi/L** Analyzed: 10/16/2018 @ 16:20
Error for Measurement is: ± 0.4 pCi/L

Canister ID# : 2612107 Test Start : 10/09/2018 @ 06:09
Canister Type : Charcoal Canister 3 inch Test Stop : 10/11/2018 @ 06:09
Location : 1st FL=Rm 113 Received: 10/15/2018 @ 10:40
Radon Level : **0.1 pCi/L** Analyzed: 10/16/2018 @ 16:04
Error for Measurement is: ± 0.2 pCi/L

Canister ID# : 2612120 Test Start : 10/09/2018 @ 06:24
Canister Type : Charcoal Canister 3 inch Test Stop : 10/11/2018 @ 06:30
Location : 1st FL=Black Gym #1 Received: 10/15/2018 @ 10:40
Radon Level : **0.1 pCi/L** Analyzed: 10/16/2018 @ 15:31
Error for Measurement is: ± 0.4 pCi/L

Canister ID# : 2612133 Test Start : 10/09/2018 @ 05:41
Canister Type : Charcoal Canister 3 inch Test Stop : 10/11/2018 @ 05:41
Location : 1st FL=Dean #2 Received: 10/15/2018 @ 10:40
Radon Level : **0.3 pCi/L** Analyzed: 10/16/2018 @ 15:48
Error for Measurement is: ± 0.5 pCi/L

Canister ID# : 2612139 Test Start : 10/09/2018 @ 06:17
Canister Type : Charcoal Canister 3 inch Test Stop : 10/11/2018 @ 06:21
Location : 1st FL=Weight Rm Received: 10/15/2018 @ 10:40
Radon Level : **0.2 pCi/L** Analyzed: 10/16/2018 @ 16:04



Andreas C. George

Andreas C. George
Radon Measurement Specialist
NJ MES 11089

Dante Galan

Dante Galan
Laboratory Director

NRSB ARL0001
NYS ELAP ID: 10806
PADEP ID: 0346
NJDEP ID: NY933
NJ MEB 90036
FL DOH RB1609
IL RNL2000201

Site Radon Inspection Report

Date : 10/17/2018

Error for Measurement is: \pm 0.4 pCi/L

Canister ID# : 2612144
Canister Type : Charcoal Canister 3 inch
Location : 1st FL=Black Gym #4
Radon Level : **0.3 pCi/L**
Error for Measurement is: \pm 0.5 pCi/L

Test Start : 10/09/2018 @ 06:28
Test Stop : 10/11/2018 @ 06:34
Received: 10/15/2018 @ 10:40
Analyzed: 10/16/2018 @ 16:06

Canister ID# : 2612467
Canister Type : Charcoal Canister 3 inch
Location : 1st FL=Rm 100
Radon Level : **0.7 pCi/L**
Error for Measurement is: \pm 0.5 pCi/L

Test Start : 10/09/2018 @ 06:00
Test Stop : 10/11/2018 @ 06:11
Received: 10/15/2018 @ 10:40
Analyzed: 10/16/2018 @ 16:22

Canister ID# : 2612469
Canister Type : Charcoal Canister 3 inch
Location : 1st FL=Rm 103 DP
Radon Level : **0.1 pCi/L**
Error for Measurement is: \pm 0.5 pCi/L

Test Start : 10/09/2018 @ 06:17
Test Stop : 10/11/2018 @ 06:19
Received: 10/15/2018 @ 10:40
Analyzed: 10/16/2018 @ 16:04

Canister ID# : 2612472
Canister Type : Charcoal Canister 3 inch
Location : 1st FL=Dean #1
Radon Level : **0.7 pCi/L**
Error for Measurement is: \pm 0.5 pCi/L

Test Start : 10/09/2018 @ 05:40
Test Stop : 10/11/2018 @ 05:40
Received: 10/15/2018 @ 10:40
Analyzed: 10/16/2018 @ 15:50

Canister ID# : 2612480
Canister Type : Charcoal Canister 3 inch
Location : 1st FL=LG Group Rm DP
Radon Level : **0.1 pCi/L**
Error for Measurement is: \pm 0.2 pCi/L

Test Start : 10/09/2018 @ 06:12
Test Stop : 10/11/2018 @ 06:12
Received: 10/15/2018 @ 10:40
Analyzed: 10/16/2018 @ 15:15

Canister ID# : 2612488
Canister Type : Charcoal Canister 3 inch
Location : 1st FL=Black Gym #2
Radon Level : **0.3 pCi/L**
Error for Measurement is: \pm 0.4 pCi/L

Test Start : 10/09/2018 @ 06:26
Test Stop : 10/11/2018 @ 06:31
Received: 10/15/2018 @ 10:40
Analyzed: 10/16/2018 @ 15:50

Canister ID# : 2612489
Canister Type : Charcoal Canister 3 inch
Location : 1st FL=Cafeteria #1
Radon Level : **0.1 pCi/L**
Error for Measurement is: \pm 0.2 pCi/L

Test Start : 10/09/2018 @ 06:22
Test Stop : 10/11/2018 @ 06:22
Received: 10/15/2018 @ 10:40
Analyzed: 10/16/2018 @ 15:15



Andreas C. George

Andreas C. George
Radon Measurement Specialist
NJ MES 11089

Dante Galan

Dante Galan
Laboratory Director

NRSB ARL0001
NYS ELAP ID: 10806
PADEP ID: 0346
NJDEP ID: NY933
NJ MEB 90036
FL DOH RB1609
IL RNL2000201

Site Radon Inspection Report

Date : 10/17/2018

Canister ID# : 2612557 Test Start : 10/09/2018 @ 06:05
Canister Type : Charcoal Canister 3 inch Test Stop : 10/11/2018 @ 06:10
Location : 1st FL=Media Ctr #2 Received: 10/15/2018 @ 10:40
Radon Level : **0.1 pCi/L** Analyzed: 10/16/2018 @ 15:50
Error for Measurement is: ± 0.8 pCi/L

Canister ID# : 2612558 Test Start : 10/09/2018 @ 06:08
Canister Type : Charcoal Canister 3 inch Test Stop : 10/11/2018 @ 06:22
Location : 1st FL=Band Off. A Received: 10/15/2018 @ 10:40
Radon Level : **0.4 pCi/L** Analyzed: 10/16/2018 @ 15:31
Error for Measurement is: ± 0.6 pCi/L

Canister ID# : 2612560 Test Start : 10/09/2018 @ 06:08
Canister Type : Charcoal Canister 3 inch Test Stop : 10/11/2018 @ 06:15
Location : 1st FL=Gold Gym #1 Received: 10/15/2018 @ 10:40
Radon Level : **0.1 pCi/L** Analyzed: 10/16/2018 @ 16:20
Error for Measurement is: ± 0.6 pCi/L

Canister ID# : 2612563 Test Start : 10/09/2018 @ 06:34
Canister Type : Charcoal Canister 3 inch Test Stop : 10/11/2018 @ 06:37
Location : 1st FL=Wrestling DP Received: 10/15/2018 @ 10:40
Radon Level : **0.1 pCi/L** Analyzed: 10/16/2018 @ 15:31
Error for Measurement is: ± 0.2 pCi/L

Canister ID# : 2619267 Test Start : 10/09/2018 @ 06:25
Canister Type : Charcoal Canister 3 inch Test Stop : 10/11/2018 @ 06:26
Location : 1st FL=Cafeteria #3 Received: 10/15/2018 @ 10:40
Radon Level : **0.3 pCi/L** Analyzed: 10/16/2018 @ 15:17
Error for Measurement is: ± 0.4 pCi/L

Canister ID# : 2619292 Test Start : 10/09/2018 @ 06:17
Canister Type : Charcoal Canister 3 inch Test Stop : 10/11/2018 @ 06:19
Location : 1st FL=Rm 103 Received: 10/15/2018 @ 10:40
Radon Level : **0.1 pCi/L** Analyzed: 10/16/2018 @ 15:50
Error for Measurement is: ± 0.3 pCi/L

Canister ID# : 2619293 Test Start : 10/09/2018 @ 06:13
Canister Type : Charcoal Canister 3 inch Test Stop : 10/11/2018 @ 06:17
Location : 1st FL=Gold Gym #3 Received: 10/15/2018 @ 10:40
Radon Level : **0.1 pCi/L** Analyzed: 10/16/2018 @ 15:48
Error for Measurement is: ± 0.7 pCi/L

Canister ID# : 2619310 Test Start : 10/09/2018 @ 05:35
Canister Type : Charcoal Canister 3 inch Test Stop : 10/11/2018 @ 05:36
Location : 1st FL=V.P. Office Received: 10/15/2018 @ 10:40
Radon Level : **0.1 pCi/L** Analyzed: 10/16/2018 @ 16:06



Andreas C. George

Andreas C. George
Radon Measurement Specialist
NJ MES 11089

Dante Galan

Dante Galan
Laboratory Director

NRSB ARL0001
NYS ELAP ID: 10806
PADEP ID: 0346
NJDEP ID: NY933
NJ MEB 90036
FL DOH RB1609
IL RNL2000201

Site Radon Inspection Report

Date : 10/17/2018

Error for Measurement is: \pm 0.5 pCi/L

Canister ID# : 2619311
Canister Type : Charcoal Canister 3 inch
Location : 1st FL=Staff Mgt. Off.
Radon Level : **0.1 pCi/L**
Error for Measurement is: \pm 0.1 pCi/L

Test Start : 10/09/2018 @ 06:18
Test Stop : 10/11/2018 @ 06:18
Received: 10/15/2018 @ 10:40
Analyzed: 10/16/2018 @ 15:50

Canister ID# : 2619312
Canister Type : Charcoal Canister 3 inch
Location : 1st FL=Rm 108 BL
Radon Level : **0.1 pCi/L**
Error for Measurement is: \pm 0.1 pCi/L

Test Start : 10/09/2018 @ 06:15
Test Stop : 10/11/2018 @ 06:15
Received: 10/15/2018 @ 10:40
Analyzed: 10/16/2018 @ 15:33

Canister ID# : 2619335
Canister Type : Charcoal Canister 3 inch
Location : 1st FL=Gold Gym #2
Radon Level : **0.2 pCi/L**
Error for Measurement is: \pm 0.4 pCi/L

Test Start : 10/09/2018 @ 06:11
Test Stop : 10/11/2018 @ 06:16
Received: 10/15/2018 @ 10:40
Analyzed: 10/16/2018 @ 15:50

Canister ID# : 2619346
Canister Type : Charcoal Canister 3 inch
Location : 1st FL=Conf. Rm A
Radon Level : **0.3 pCi/L**
Error for Measurement is: \pm 0.5 pCi/L

Test Start : 10/09/2018 @ 05:19
Test Stop : 10/11/2018 @ 05:23
Received: 10/15/2018 @ 10:40
Analyzed: 10/16/2018 @ 15:48

Canister ID# : 2619347
Canister Type : Charcoal Canister 3 inch
Location : 1st FL=Rm 111 BLANK
Radon Level : **0.1 pCi/L**
Error for Measurement is: \pm 0.1 pCi/L

Test Start : 10/09/2018 @ 06:26
Test Stop : 10/11/2018 @ 06:32
Received: 10/15/2018 @ 10:40
Analyzed: 10/16/2018 @ 15:31

Canister ID# : 2619350
Canister Type : Charcoal Canister 3 inch
Location : 1st FL=Main Off. DP
Radon Level : **0.6 pCi/L**
Error for Measurement is: \pm 0.4 pCi/L

Test Start : 10/09/2018 @ 05:12
Test Stop : 10/11/2018 @ 05:17
Received: 10/15/2018 @ 10:40
Analyzed: 10/16/2018 @ 15:48

Canister ID# : 2619353
Canister Type : Charcoal Canister 3 inch
Location : 1st FL=Media Ctr #1
Radon Level : **0.3 pCi/L**
Error for Measurement is: \pm 0.5 pCi/L

Test Start : 10/09/2018 @ 06:00
Test Stop : 10/11/2018 @ 06:08
Received: 10/15/2018 @ 10:40
Analyzed: 10/16/2018 @ 15:33



Andreas C. George

Andreas C. George
Radon Measurement Specialist
NJ MES 11089

Dante Galan

Dante Galan
Laboratory Director

NRSB ARL0001
NYS ELAP ID: 10806
PADEP ID: 0346
NJDEP ID: NY933
NJ MEB 90036
FL DOH RB1609
IL RNL2000201

Site Radon Inspection Report

Date : 10/17/2018

Canister ID# : 2619357 Test Start : 10/09/2018 @ 05:15
Canister Type : Charcoal Canister 3 inch Test Stop : 10/11/2018 @ 05:19
Location : 1st FL=NTS Office Received: 10/15/2018 @ 10:40
Radon Level : **0.4 pCi/L** Analyzed: 10/16/2018 @ 15:31
Error for Measurement is: ± 0.4 pCi/L

Canister ID# : 2619402 Test Start : 10/09/2018 @ 05:18
Canister Type : Charcoal Canister 3 inch Test Stop : 10/11/2018 @ 05:21
Location : 1st FL=Fam Outreach Off. Received: 10/15/2018 @ 10:40
Radon Level : **0.1 pCi/L** Analyzed: 10/16/2018 @ 16:22
Error for Measurement is: ± 0.3 pCi/L

Canister ID# : 2619403 Test Start : 10/09/2018 @ 06:22
Canister Type : Charcoal Canister 3 inch Test Stop : 10/11/2018 @ 06:22
Location : 1st FL=Staff Library Received: 10/15/2018 @ 10:40
Radon Level : **0.2 pCi/L** Analyzed: 10/16/2018 @ 15:50
Error for Measurement is: ± 0.4 pCi/L

Canister ID# : 2619404 Test Start : 10/09/2018 @ 06:24
Canister Type : Charcoal Canister 3 inch Test Stop : 10/11/2018 @ 06:26
Location : 1st FL=Rm 104 Received: 10/15/2018 @ 10:40
Radon Level : **0.2 pCi/L** Analyzed: 10/16/2018 @ 15:17
Error for Measurement is: ± 0.5 pCi/L

Canister ID# : 2619409 Test Start : 10/09/2018 @ 05:15
Canister Type : Charcoal Canister 3 inch Test Stop : 10/11/2018 @ 05:20
Location : 1st FL=Health Rm Received: 10/15/2018 @ 10:40
Radon Level : **0.4 pCi/L** Analyzed: 10/16/2018 @ 15:33
Error for Measurement is: ± 0.4 pCi/L

Canister ID# : 2619411 Test Start : 10/09/2018 @ 06:24
Canister Type : Charcoal Canister 3 inch Test Stop : 10/11/2018 @ 06:29
Location : 1st FL=Rm 110 Office Received: 10/15/2018 @ 10:40
Radon Level : **0.1 pCi/L** Analyzed: 10/16/2018 @ 16:04
Error for Measurement is: ± 0.3 pCi/L

Canister ID# : 2619412 Test Start : 10/09/2018 @ 06:09
Canister Type : Charcoal Canister 3 inch Test Stop : 10/11/2018 @ 06:11
Location : 1st FL=Rm 107 Received: 10/15/2018 @ 10:40
Radon Level : **0.1 pCi/L** Analyzed: 10/16/2018 @ 16:20
Error for Measurement is: ± 0.5 pCi/L

Canister ID# : 2619416 Test Start : 10/09/2018 @ 05:38
Canister Type : Charcoal Canister 3 inch Test Stop : 10/11/2018 @ 05:38
Location : 1st FL=Main Conf. Rm. Received: 10/15/2018 @ 10:40
Radon Level : **0.2 pCi/L** Analyzed: 10/16/2018 @ 15:48



Andreas C. George

Andreas C. George
Radon Measurement Specialist
NJ MES 11089

Dante Galan

Dante Galan
Laboratory Director

NRSB ARL0001
NYS ELAP ID: 10806
PADEP ID: 0346
NJDEP ID: NY933
NJ MEB 90036
FL DOH RB1609
IL RNL2000201

Site Radon Inspection Report

Date : 10/17/2018

Error for Measurement is: ± 0.6 pCi/L

Canister ID# : 2619424
Canister Type : Charcoal Canister 3 inch
Location : 1st FL=Counselor Off.
Radon Level : **0.2 pCi/L**
Error for Measurement is: ± 0.4 pCi/L

Test Start : 10/09/2018 @ 05:29
Test Stop : 10/11/2018 @ 05:29
Received: 10/15/2018 @ 10:40
Analyzed: 10/16/2018 @ 16:20

Canister ID# : 2619428
Canister Type : Charcoal Canister 3 inch
Location : 1st FL=Rm 120A
Radon Level : **17.0 pCi/L**
Error for Measurement is: ± 0.8 pCi/L

Test Start : 10/09/2018 @ 06:00
Test Stop : 10/11/2018 @ 06:00
Received: 10/15/2018 @ 10:40
Analyzed: 10/16/2018 @ 16:22

This is a quality control test known as a spike. This canister has never been on the school site.

Canister ID# : 2619432
Canister Type : Charcoal Canister 3 inch
Location : 1st FL=Rm 105
Radon Level : **0.3 pCi/L**
Error for Measurement is: ± 0.5 pCi/L

Test Start : 10/09/2018 @ 06:28
Test Stop : 10/11/2018 @ 06:30
Received: 10/15/2018 @ 10:40
Analyzed: 10/16/2018 @ 15:31

Canister ID# : 2619436
Canister Type : Charcoal Canister 3 inch
Location : 1st FL=Rm 102
Radon Level : **0.5 pCi/L**
Error for Measurement is: ± 0.4 pCi/L

Test Start : 10/09/2018 @ 06:13
Test Stop : 10/11/2018 @ 06:17
Received: 10/15/2018 @ 10:40
Analyzed: 10/16/2018 @ 15:33

Canister ID# : 2619437
Canister Type : Charcoal Canister 3 inch
Location : 1st FL=Rm 100 BLANK
Radon Level : **0.1 pCi/L**
Error for Measurement is: ± 0.3 pCi/L

Test Start : 10/09/2018 @ 06:00
Test Stop : 10/11/2018 @ 06:11
Received: 10/15/2018 @ 10:40
Analyzed: 10/16/2018 @ 16:06

Canister ID# : 2619438
Canister Type : Charcoal Canister 3 inch
Location : 1st FL=Staff Work Rm
Radon Level : **0.5 pCi/L**
Error for Measurement is: ± 0.5 pCi/L

Test Start : 10/09/2018 @ 06:20
Test Stop : 10/11/2018 @ 06:20
Received: 10/15/2018 @ 10:40
Analyzed: 10/16/2018 @ 15:33

Canister ID# : 2619439
Canister Type : Charcoal Canister 3 inch
Location : 1st FL=Black Gym #3
Radon Level : **0.2 pCi/L**
Error for Measurement is: ± 0.6 pCi/L

Test Start : 10/09/2018 @ 06:27
Test Stop : 10/11/2018 @ 06:33
Received: 10/15/2018 @ 10:40
Analyzed: 10/16/2018 @ 15:33



Andreas C. George

Andreas C. George
Radon Measurement Specialist
NJ MES 11089

Dante Galan

Dante Galan
Laboratory Director

NRSB ARL0001
NYS ELAP ID: 10806
PADEP ID: 0346
NJDEP ID: NY933
NJ MEB 90036
FL DOH RB1609
IL RNL2000201

Site Radon Inspection Report

Date : 10/17/2018

Canister ID# : 2619441
Canister Type : Charcoal Canister 3 inch
Location : 1st FL=Rm 101
Radon Level : **0.4 pCi/L**
Error for Measurement is: ± 0.6 pCi/L

Test Start : 10/09/2018 @ 06:09
Test Stop : 10/11/2018 @ 06:13
Received: 10/15/2018 @ 10:40
Analyzed: 10/16/2018 @ 15:48

Canister ID# : 2619442
Canister Type : Charcoal Canister 3 inch
Location : 1st FL=Rm 120B
Radon Level : **19.1 pCi/L**
Error for Measurement is: ± 0.8 pCi/L

Test Start : 10/09/2018 @ 06:01
Test Stop : 10/11/2018 @ 06:01
Received: 10/15/2018 @ 10:40
Analyzed: 10/16/2018 @ 15:17

This is a quality control test known as a spike. This canister has never been on the school site.

Canister ID# : 2619447
Canister Type : Charcoal Canister 3 inch
Location : 1st FL=Principals Off.
Radon Level : **0.3 pCi/L**
Error for Measurement is: ± 0.4 pCi/L

Test Start : 10/09/2018 @ 05:30
Test Stop : 10/11/2018 @ 05:30
Received: 10/15/2018 @ 10:40
Analyzed: 10/16/2018 @ 16:22

Canister ID# : 2619449
Canister Type : Charcoal Canister 3 inch
Location : 1st FL=Media Off. A
Radon Level : **0.1 pCi/L**
Error for Measurement is: ± 0.5 pCi/L

Test Start : 10/09/2018 @ 06:15
Test Stop : 10/11/2018 @ 06:15
Received: 10/15/2018 @ 10:40
Analyzed: 10/16/2018 @ 16:06

Canister ID# : 2619451
Canister Type : Charcoal Canister 3 inch
Location : 1st FL=Cafeteria #2
Radon Level : **0.2 pCi/L**
Error for Measurement is: ± 0.4 pCi/L

Test Start : 10/09/2018 @ 06:23
Test Stop : 10/11/2018 @ 06:24
Received: 10/15/2018 @ 10:40
Analyzed: 10/16/2018 @ 16:06

Canister ID# : 2619452
Canister Type : Charcoal Canister 3 inch
Location : 1st FL=Student Mgt.
Radon Level : **0.2 pCi/L**
Error for Measurement is: ± 0.4 pCi/L

Test Start : 10/09/2018 @ 06:17
Test Stop : 10/11/2018 @ 06:17
Received: 10/15/2018 @ 10:40
Analyzed: 10/16/2018 @ 15:16

Canister ID# : 2619459
Canister Type : Charcoal Canister 3 inch
Location : 1st FL=Media Ctr. Video
Radon Level : **0.4 pCi/L**
Error for Measurement is: ± 0.5 pCi/L

Test Start : 10/09/2018 @ 06:13
Test Stop : 10/11/2018 @ 06:14
Received: 10/15/2018 @ 10:40
Analyzed: 10/16/2018 @ 16:20

Canister ID# : 2619468
Canister Type : Charcoal Canister 3 inch
Location : 1st FL=Rm 107 DP
Radon Level : **0.3 pCi/L**

Test Start : 10/09/2018 @ 06:10
Test Stop : 10/11/2018 @ 06:10
Received: 10/15/2018 @ 10:40
Analyzed: 10/16/2018 @ 16:04



Andreas C. George

Andreas C. George
Radon Measurement Specialist
NJ MES 11089

Dante Galan

Dante Galan
Laboratory Director

NRSB ARL0001
NYS ELAP ID: 10806
PADEP ID: 0346
NJDEP ID: NY933
NJ MEB 90036
FL DOH RB1609
IL RNL2000201

Site Radon Inspection Report

Date : 10/17/2018

Error for Measurement is: \pm 0.5 pCi/L

Canister ID# : 2619469
Canister Type : Charcoal Canister 3 inch
Location : 1st FL=Conf. Rm B
Radon Level : **0.1 pCi/L**
Error for Measurement is: \pm 0.8 pCi/L

Test Start : 10/09/2018 @ 05:25
Test Stop : 10/11/2018 @ 05:25
Received: 10/15/2018 @ 10:40
Analyzed: 10/16/2018 @ 16:22

Canister ID# : 2619470
Canister Type : Charcoal Canister 3 inch
Location : 1st FL=Managers Off.
Radon Level : **0.1 pCi/L**
Error for Measurement is: \pm 0.7 pCi/L

Test Start : 10/09/2018 @ 05:34
Test Stop : 10/11/2018 @ 05:35
Received: 10/15/2018 @ 10:40
Analyzed: 10/16/2018 @ 16:22

Canister ID# : 2619472
Canister Type : Charcoal Canister 3 inch
Location : 1st FL=Staff Break Rm
Radon Level : **0.1 pCi/L**
Error for Measurement is: \pm 0.5 pCi/L

Test Start : 10/09/2018 @ 06:20
Test Stop : 10/11/2018 @ 06:29
Received: 10/15/2018 @ 10:40
Analyzed: 10/16/2018 @ 16:04

Canister ID# : 2619473
Canister Type : Charcoal Canister 3 inch
Location : 1st FL=LG Group Rm #2
Radon Level : **0.5 pCi/L**
Error for Measurement is: \pm 0.5 pCi/L

Test Start : 10/09/2018 @ 06:14
Test Stop : 10/11/2018 @ 06:14
Received: 10/15/2018 @ 10:40
Analyzed: 10/16/2018 @ 16:04

The results indicate that at least one testing device registered at or above the United States Environmental Protection Agency (EPA) action level of 4.0 picoCuries per liter of air (pCi/L). The EPA recommends mitigation if the average of two short-term tests taken in the lowest level of the building suitable for occupancy show radon levels that are equal to or greater than 4.0 pCi/L.

For information on how to reduce radon levels in your home, please review the EPA booklet: Consumer's Guide to Radon Reduction (www.epa.gov/radon/pdfs/consguid.pdf) and contact your state health department. The EPA maintains a radon information website, including copies of its publications, at www.epa.gov/iaq/radon.

For New Jersey clients: Please see the attached guidance document entitled Radon Testing and Mitigation: The Basics for further information.

For New York clients: If the radon level of one or more testing devices is equal to or exceeds 20 pCi/L please contact the New York State Department of Health, Bureau of Environmental Radiation Protection, for technical advice and assistance at 518-402-7556 or toll free 1-800-458-1158.

PLEDGE OF ASSURED QUALITY

All procedures used for generating this report are in complete accordance with the current EPA protocols for the analysis of radon in air (EPA 402-R-92-004). The analytical results relate only to the samples tested, in the condition received by the lab, and that calculations were based upon the information supplied by client. RTCA and its personnel do not assume responsibility or liability, collectively and individually, for analysis results when detectors have been improperly handled or placed by the consumer, nor does RTCA and its personnel accept responsibility for any financial or health consequences of subsequent action or lack of action, taken by the customer or its consultants based on RTCA-provided results.

*Andreas C. George*

Andreas C. George
Radon Measurement Specialist
NJ MES 11089

Dante Galan

Dante Galan
Laboratory Director

NRSB ARL0001
NYS ELAP ID: 10806
PADEP ID: 0346
NJDEP ID: NY933
NJ MEB 90036
FL DOH RB1609
IL RNL2000201

Site Radon Inspection Report

Date : 10/17/2018



Andreas C. George

Andreas C. George
Radon Measurement Specialist
NJ MES 11089

Dante Galan

Dante Galan
Laboratory Director

NRSB ARL0001
NYS ELAP ID: 10806
PADEP ID: 0346
NJDEP ID: NY933
NJ MEB 90036
FL DOH RB1609
IL RNL2000201