

North Elementary School

Radon Tests - North High School

Administration (A)

#	Location/Type	Placement Description	Serial #	Dated Opened	Time Opened	Date Closed	Time Closed	Radon Test Results	Remarks
1	Administration # 1	North Wall - Desk Behind Computer	2708112	21-Oct-19	5:21 AM	23-Oct-19	5:23 AM	0.8	None.
2	Administration # 2	North Wall - File Cabinet	2707252	21-Oct-19	7:08 AM	23-Oct-19	7:14 AM	1.6	None.
3	Administration # 3	North Wall - Desk	2708924	21-Oct-19	5:25 AM	23-Oct-19	5:28 AM	0.5	None.
4	Administration # 4	North Wall - Desk Behind Computer	2708118	21-Oct-19	5:27 AM	23-Oct-19	5:29 AM	0.6	None.
5	Administration # 5	South Wall - Desk	2708546	21-Oct-19	5:28 AM	23-Oct-19	5:30 AM	0.6	None.
6	Administration # 6	South Wall - Counter	2710003	21-Oct-19	5:30 AM	23-Oct-19	5:31 AM	0.8	None.
7	Administration # 7	South Wall - Table	2708940	21-Oct-19	5:32 AM	23-Oct-19	5:33 AM	0.4	None.
8	Administration # 7 - Blank	South Wall - Table	2704216	21-Oct-19	5:32 AM	21-Oct-19	5:32 AM	0.1	None.
9	Administration # 8	North Wall - Bookcase	2708935	21-Oct-19	5:34 AM	23-Oct-19	5:34 AM	0.7	None.
10	Administration # 9	West Wall - Bookcase	2708514	21-Oct-19	5:35 AM	23-Oct-19	5:35 AM	0.9	None.
11	Administration # 10	West Wall - Bookcase	2708543	21-Oct-19	5:37 AM	23-Oct-19	5:37 AM	0.3	None.
12	Administration # 11	East Wall - Desk	2708562	21-Oct-19	5:39 AM	23-Oct-19	5:39 AM	0.1	None.
13	Administration # 12	West Wall - Bookcase	2710005	21-Oct-19	5:41 AM	23-Oct-19	5:42 AM	0.9	None.
14	Administration # 13	West Wall - Bookcase	2707257	21-Oct-19	5:43 AM	23-Oct-19	5:44 AM	0.6	None.
15	Administration # 14	West Wall - Table	2707293	21-Oct-19	5:43 AM	23-Oct-19	5:45 AM	0.8	None.
16	Administration # 15	North Wall - Filing Cabinet	2708526	21-Oct-19	5:44 AM	23-Oct-19	5:49 AM	1.5	None.
17	Administration # 15 - Duplicate	North Wall - Filing Cabinet	2708946	21-Oct-19	5:44 AM	23-Oct-19	5:49 AM	1.4	None.
18	Administration # 16	North Wall - Desk	2710049	21-Oct-19	5:47 AM	23-Oct-19	5:50 AM	0.6	None.
19	Administration # 16 - Duplicate	North Wall - Desk	2708123	21-Oct-19	5:47 AM	23-Oct-19	5:50 AM	0.5	None.
20	Administration # 17	West Wall - Desk	2708538	21-Oct-19	5:48 AM	23-Oct-19	5:51 AM	0.5	None.
21	Administration # 18	Southwest Wall - Behind TV	2707263	21-Oct-19	5:50 AM	23-Oct-19	5:52 AM	1.0	None.
22	Administration # 19	East Wall - Counter	2708545	21-Oct-19	5:52 AM	23-Oct-19	5:53 AM	0.5	None.
23	Administration # 20	South Wall - Filing Cabinet	2707269	21-Oct-19	5:53 AM	23-Oct-19	5:54 AM	0.2	None.
24	Administration # 21	East Wall - Desk	2708111	21-Oct-19	5:55 AM	23-Oct-19	5:56 AM	0.6	None.
25	Administration # 22	East Wall - Desk	2708623	21-Oct-19	5:57 AM	23-Oct-19	5:57 AM	1.6	None.
26	Administration # 23	East Wall - Bookcase	2704191	21-Oct-19	5:58 AM	23-Oct-19	5:58 AM	0.4	None.
27	Administration # 24	South Desk	2707376	6-Nov-19	4:23 AM	8-Nov-19	5:06 AM	0.7	RTCA never received the initial test (2708606).
28	Administration # 25	North Wall - Desk	2704185	21-Oct-19	6:00 AM	23-Oct-19	6:00 AM	0.5	None.
29	Administration # 25 - Duplicate	North Wall - Desk	2708932	21-Oct-19	6:00 AM	23-Oct-19	6:00 AM	0.3	None.
30	Administration # 26	North Wall - Bookcase	2708600	21-Oct-19	6:04 AM	23-Oct-19	6:07 AM	0.5	None.
31	Student Management	South Wall - Bookcase	2708548	21-Oct-19	6:05 AM	23-Oct-19	6:09 AM	0.3	None.
32	Administration # 27	West Wall - Desk	2708627	21-Oct-19	6:06 AM	23-Oct-19	6:10 AM	0.4	None.
33	Administration # 28	North Wall - Bookcase	2708641	21-Oct-19	6:27 AM	23-Oct-19	6:30 AM	0.2	None.
34	Administration # 29	East Wall - Bookcase	2704230	21-Oct-19	6:29 AM	23-Oct-19	6:31 AM	0.2	None.
35	Administration # 29 - Blank	East Wall - Bookcase	2704143	21-Oct-19	6:29 AM	21-Oct-19	6:29 AM	0.3	None.
36	Administration # 30	Southeast Wall - Desk	2710030	21-Oct-19	6:31 AM	23-Oct-19	6:33 AM	0.1	None.
37	Administration # 31	South Wall - Bookcase	2710056	21-Oct-19	6:34 AM	23-Oct-19	6:35 AM	0.6	None.
38	Administration # 32	Desk	2707317	21-Oct-19	6:34 AM	23-Oct-19	6:36 AM	1.0	None.
39	Staff Work Room	East Wall - Bookcase	2709990	6-Nov-19	4:26 AM	8-Nov-19	5:09 AM	0.7	RTCA never received the initial test (2708577).
40	Staff Break Room	South Wall - Bookcase	2708646	21-Oct-19	6:39 AM	23-Oct-19	6:39 AM	0.2	None.
41	Staff Break Room - Duplicate	South Wall - Bookcase	2707273	21-Oct-19	6:39 AM	23-Oct-19	6:39 AM	0.4	None.
42	A-1	West Wall - Desk	2708516	21-Oct-19	6:43 AM	23-Oct-19	6:43 AM	0.1	None.

Cafeteria (C)

#	Location/Type	Placement Description	Serial #	Dated Opened	Time Opened	Date Closed	Time Closed	Radon Test Results	Remarks
1	Cafeteria # 1	West Wall - 5'	2708629	21-Oct-19	5:23 AM	23-Oct-19	5:25 AM	0.3	None.
2	Cafeteria # 2	Southeast Wall - Corner	2704484	21-Oct-19	5:23 AM	23-Oct-19	5:25 AM	0.1	None.
3	Cafeteria # 3	North Wall	2708663	21-Oct-19	5:23 AM	23-Oct-19	5:25 AM	0.1	None.
4	Cafeteria # 4	Southeast Wall	2704541	6-Nov-19	5:00 AM	8-Nov-19	5:22 AM	0.3	RTCA never received the initial test (2708117).
5	Classroom C-1	East Wall - By Sink	2708517	21-Oct-19	5:30 AM	23-Oct-19	5:32 AM	0.3	None.
6	Classroom C-1 - Duplicate	East Wall - By Sink Counter	2708551	21-Oct-19	5:30 AM	23-Oct-19	5:32 AM	0.1	None.
7	Office A	Left Wall - Shelf	2708624	21-Oct-19	5:34 AM	23-Oct-19	5:35 AM	0.6	None.
8	Office B	Right Shelf	2707254	21-Oct-19	5:33 AM	23-Oct-19	5:35 AM	0.3	None.
9	Office B - Blank	Right Shelf	2704520	21-Oct-19	5:34 AM	21-Oct-19	5:35 AM	0.2	None.

Health and Culinary Art (HC) and Child Care Center

#	Location/Type	Placement Description	Serial #	Dated Opened	Time Opened	Date Closed	Time Closed	Radon Test Results	Remarks
1	HC-1	Southwest Wall - Filing Cabinet	2708537	21-Oct-19	6:06 AM	23-Oct-19	6:07 AM	0.4	None.
2	HC-1 - Duplicate	Southwest Wall - Filing Cabinet	2708536	21-Oct-19	6:04 AM	23-Oct-19	6:05 AM	0.4	None.
3	HC-1 - Office A	Filing Cabinet	2708107	21-Oct-19	6:02 AM	23-Oct-19	6:03 AM	0.6	None.
4	HC-1 - Office B	North Wall	2708542	21-Oct-19	6:00 AM	23-Oct-19	6:01 AM	0.1	None.
5	HC-2	South Wall - Desk	2708115	21-Oct-19	5:56 AM	23-Oct-19	5:58 AM	0.2	None.
6	HC-3	Northwest Wall	8707309	21-Oct-19	5:54 AM	23-Oct-19	5:55 AM	0.4	None.
7	HC-4	Desktop	2704485	21-Oct-19	5:52 AM	23-Oct-19	5:53 AM	0.1	None.
8	HC-5	East Wall - Middle Counter	2710055	21-Oct-19	5:48 AM	23-Oct-19	5:49 AM	1.1	None.
9	HC-5 - Blank	East Wall - Middle Counter	2708532	21-Oct-19	5:48 AM	21-Oct-19	5:49 AM	0.1	None.
10	HC-8	Behind Screen	2707283	21-Oct-19	5:45 AM	23-Oct-19	5:46 AM	0.6	None.
11	CDC - Pre-School Room	North Wall - Middle	2708605	21-Oct-19	6:22 AM	23-Oct-19	6:23 AM	0.1	None.
12	CDC - Office C	Northeast Bbookshelf	2704181	6-Nov-19	4:49 AM	8-Nov-19	5:15 AM	0.7	RTCA never received the initial test (2708956).

13	CDC Office C - Duplicate	Northeast Wall - Bookshelf	2708515	21-Oct-19	6:19 AM	23-Oct-19	6:21 AM	0.1	None.
14	CDC - Infant Room	Northwest Wall	2708518	21-Oct-19	6:14 AM	23-Oct-19	6:17 AM	0.5	None.
15	CDC - Office D	Southwest Wall - Desk	2708100	21-Oct-19	6:11 AM	23-Oct-19	6:12 AM	0.6	None.
16	CDC - Office D - Blank	South Wall - Desk	2708576	21-Oct-19	6:11 AM	21-Oct-19	6:11 AM	0.1	None.
17	CDC - Infant Room - E	Southwest Wall - Bookcase	2708632	21-Oct-19	6:16 AM	23-Oct-19	6:17 AM	0.5	None.
Fine Arts (FA)									
#	Location/Type	Placement Description	Serial #	Dated Opened	Time Opened	Date Closed	Time Closed	Radon Test Results	Remarks
1	Auditorium # 1	Southwest Wall	2708116	21-Oct-19	5:15 AM	23-Oct-19	5:19 AM	0.3	None.
2	Auditorium # 2	Southeast Wall	2708104	21-Oct-19	5:18 AM	23-Oct-19	5:21 AM	0.3	None.
3	Auditorium # 3	Northeast Wall	2708120	21-Oct-19	5:20 AM	23-Oct-19	5:22 AM	0.3	None.
4	Auditorium # 4	Northwest Wall	2708930	21-Oct-19	5:24 AM	23-Oct-19	5:25 AM	0.3	None.
5	Stage	Microphone Stand	2708602	21-Oct-19	5:28 AM	23-Oct-19	5:28 AM	0.3	None.
6	Stage # 2	Storage Box	2708553	21-Oct-19	5:29 AM	23-Oct-19	5:30 AM	0.4	None.
7	Stage - Duplicate	Microphone Stand	2708954	21-Oct-19	5:28 AM	23-Oct-19	5:28 AM	0.2	None.
8	FA - 8	North Wall - Cart	2708938	21-Oct-19	5:34 AM	23-Oct-19	5:35 AM	0.1	None.
9	FA - 7	Southwest - Bookshelf	2708659	21-Oct-19	5:32 AM	23-Oct-19	5:37 AM	0.2	None.
10	FA - 6	West Wall - Countertop	2708951	21-Oct-19	5:39 AM	23-Oct-19	5:42 AM	0.1	None.
11	FA - 6 - Blank	West Wall - Countertop	2708929	21-Oct-19	5:39 AM	21-Oct-19	5:39 AM	0.1	None.
12	FA - 5	Southwest Wall - Corner Counter	2739795	21-Oct-19	5:45 AM	23-Oct-19	5:45 AM	0.7	None.
13	FA - 4 # 1	Northwest Wall - Counter	2708122	21-Oct-19	5:48 AM	23-Oct-19	5:52 AM	0.4	None.
14	FA - 4 # 2	Southeast - Table	2708944	21-Oct-19	5:48 AM	23-Oct-19	5:52 AM	0.3	None.
15	Office A	Southwest Wall - Counter	2708945	21-Oct-19	5:53 AM	23-Oct-19	5:55 AM	0.6	None.
16	Office B	West Wall	2708530	21-Oct-19	5:55 AM	23-Oct-19	5:45 AM	0.1	None.
17	Office C	Filing Cabinet	2710022	21-Oct-19	5:57 AM	23-Oct-19	5:58 AM	0.9	None.
18	FA - 3	North Wall	2708647	21-Oct-19	5:58 AM	23-Oct-19	5:59 AM	0.5	None.
19	FA - 3 - Duplicate	North Wall	2708642	21-Oct-19	5:58 AM	23-Oct-19	5:59 AM	0.3	None.
20	FA - 1	East Wall	2708618	21-Oct-19	6:02 AM	23-Oct-19	6:03 AM	0.3	None.
21	FA - 2	West Wall	2708621	21-Oct-19	6:06 AM	23-Oct-19	6:07 AM	0.4	None.
Humanities (H)									
#	Location/Type	Placement Description	Serial #	Dated Opened	Time Opened	Date Closed	Time Closed	Radon Test Results	Remarks
1	H-1	Southwest - Corner	2739796	21-Oct-19	5:14 AM	23-Oct-19	5:17 AM	1.0	None.
2	Student Store	South - Wall Shelf	2708943	21-Oct-19	5:15 AM	23-Oct-19	5:18 AM	0.1	None.
3	H-1 Office	Southeast Wall - Filing Cabinet	2708113	21-Oct-19	5:16 AM	23-Oct-19	5:20 AM	0.5	None.
4	H-2	South Wall - Computer Cart	2708620	21-Oct-19	5:21 AM	23-Oct-19	5:22 AM	0.1	None.
5	H-2 - Duplicate	South Wall - Computer Cart	2708609	21-Oct-19	5:21 AM	23-Oct-19	5:22 AM	0.2	None.
6	H-3	West Wall - Filing Cabinet	2708950	21-Oct-19	5:25 AM	23-Oct-19	5:28 AM	0.4	None.
7	Office Outside H-3	North Wall - Bookshelf	2708103	21-Oct-19	5:28 AM	23-Oct-19	5:30 AM	0.3	None.
8	H-4	Northeast - Corner Filing Cabinet	2710051	21-Oct-19	5:31 AM	23-Oct-19	5:32 AM	0.2	None.
9	H-5	Northeast Wall - Filing Cabinet	2707271	21-Oct-19	5:33 AM	23-Oct-19	5:35 AM	0.7	None.
10	H-6	Northwest Wall - Shelf	2708105	21-Oct-19	5:35 AM	23-Oct-19	5:37 AM	0.3	None.
11	H-7	Southwest - Bookshelf	2708108	21-Oct-19	5:38 AM	23-Oct-19	5:39 AM	0.1	None.
12	H-8	Northeast Wall - Filing Cabinet	2708934	21-Oct-19	5:40 AM	23-Oct-19	5:42 AM	0.2	None.
13	H-9	Southeast Wall - Filing Cabinet	2710018	21-Oct-19	5:43 AM	23-Oct-19	5:46 AM	0.2	None.
14	H-9 - Duplicate	Southeast Wall - Filing Cabinet	2708625	21-Oct-19	5:43 AM	23-Oct-19	5:46 AM	0.1	None.
15	H-10 A	Northeast Bookshelf	2710024	6-Nov-19	4:44 AM	8-Nov-19	5:12 AM	0.6	RTCA never received the initial test (2739794).
16	H-10 B	Desk By Phone	2708099	21-Oct-19	5:49 AM	23-Oct-19	5:49 AM	0.3	None.
17	H-10 C	Southeast Corner	2708631	21-Oct-19	5:51 AM	23-Oct-19	5:51 AM	0.2	None.
18	H-10 - D	Northeast - Bookshelf	2710025	21-Oct-19	5:53 AM	23-Oct-19	5:53 AM	0.2	None.
19	H-11	West Wall - Top Shelf Cabinet	2708614	21-Oct-19	5:55 AM	23-Oct-19	5:55 AM	0.2	None.
20	H-12	Northeast Wall - Bookshelf	2708098	21-Oct-19	5:58 AM	23-Oct-19	5:58 AM	0.3	None.
21	H-12 - Duplicate	Northeast Wall - Bookshelf	2708564	21-Oct-19	5:58 AM	23-Oct-19	5:58 AM	0.1	None.
22	H-13	West Wall - Green Counter	2708615	21-Oct-19	6:01 AM	23-Oct-19	6:01 AM	0.4	None.
23	H-14	South Wall - Cabinet	2708636	21-Oct-19	6:03 AM	23-Oct-19	6:03 AM	0.3	None.
24	H-15	Southwest Wall - Corner Desk	2704483	21-Oct-19	6:06 AM	23-Oct-19	6:06 AM	0.1	None.
25	H-17	West Wall - Shelf	2708639	21-Oct-19	6:09 AM	23-Oct-19	6:12 AM	0.1	None.
26	H-17 Blank	West Wall - Shelf	2704127	21-Oct-19	6:09 AM	21-Oct-19	6:09 AM	0.4	None.
27	H-18	East Wall - Middle Counter	2708525	21-Oct-19	6:11 AM	23-Oct-19	6:14 AM	0.3	None.
28	H-19	East Wall - Bookshelf	27010017	21-Oct-19	6:13 AM	23-Oct-19	6:15 AM	0.5	None.
29	H-20	Southwest Wall - Filing Cabinet	2710009	21-Oct-19	6:16 AM	23-Oct-19	6:17 AM	0.5	None.
30	H-21	West Wall - TA desk	2708552	21-Oct-19	6:19 AM	23-Oct-19	6:19 AM	0.1	None.
31	H-21 - Duplicate	West Wall - TA desk	2708638	21-Oct-19	6:19 AM	23-Oct-19	6:19 AM	0.4	None.
32	H-22	South Wall - Filing Cabinet	2708622	21-Oct-19	6:21 AM	23-Oct-19	6:21 AM	0.2	None.
33	H-41	Filing Cabinet	2710007	21-Oct-19	6:24 AM	23-Oct-19	6:27 AM	0.6	None.
34	H-42	Filing Cabinet	2710023	21-Oct-19	6:26 AM	23-Oct-19	6:28 AM	0.4	None.
35	H-43	Top of Bookcase	2708664	21-Oct-19	6:28 AM	23-Oct-19	6:29 AM	0.2	None.
36	H-44	Corner Table	2708521	21-Oct-19	6:30 AM	23-Oct-19	6:30 AM	0.4	None.
37	H-25	West Wall - Table	2708519	21-Oct-19	6:37 AM	23-Oct-19	6:37 AM	0.6	None.
38	H-23	North Wall - Middle Counter	2708119	21-Oct-19	6:40 AM	23-Oct-19	6:40 AM	0.2	None.
39	H-26	Southeast Wall - Bookshelf	2710031	21-Oct-19	6:42 AM	23-Oct-19	6:42 AM	0.7	None.
40	H-27	East Wall - Center Cabinet	2708601	21-Oct-19	6:44 AM	23-Oct-19	6:44 AM	0.2	None.
41	H-24	South Wall - Filing Cabinet	2708613	21-Oct-19	6:46 AM	23-Oct-19	6:46 AM	0.5	None.
42	H-24 - Blank	South Wall - Filing Cabinet	2708626	21-Oct-19	6:46 AM	21-Oct-19	6:46 AM	0.2	None.

43	H-28	Northwest - Corner	2708522	21-Oct-19	6:49 AM	23-Oct-19	6:51 AM	0.2	None.
44	H-31	Northwest Corner - Filing Cabinet	2708563	21-Oct-19	6:51 AM	23-Oct-19	6:53 AM	0.4	None.
45	H-31 - Duplicate	Northwest Corner - Filing Cabinet	2708927	21-Oct-19	6:51 AM	23-Oct-19	6:53 AM	0.1	None.
46	H-29	Northwest - Bookshelf	2710001	21-Oct-19	6:53 AM	23-Oct-19	6:55 AM	0.8	None.
47	H-30	Northwest - Filing Cabinet	2708649	21-Oct-19	6:56 AM	23-Oct-19	6:56 AM	0.3	None.
48	H-32	South Wall - Bookshelf	2708661	21-Oct-19	6:58 AM	23-Oct-19	6:58 AM	0.4	None.
49	H-33	Southwest - Corner	2708603	21-Oct-19	6:26 AM	23-Oct-19	6:26 AM	0.3	None.
50	H-34	West Wall - Desk	2707306	21-Oct-19	6:28 AM	23-Oct-19	6:28 AM	0.2	None.
51	H-34 - Blank	West Wall - Desk	2708665	21-Oct-19	6:28 AM	21-Oct-19	6:28 AM	0.1	None.
52	H-38	Filing Cabinet	2704499	21-Oct-19	6:31 AM	23-Oct-19	6:31 AM	0.3	None.
53	H-39	Bookshelf	2710054	21-Oct-19	6:33 AM	23-Oct-19	6:33 AM	0.2	None.
54	H-40	West Wall - Counter	2704487	21-Oct-19	6:35 AM	23-Oct-19	6:35 AM	0.4	None.
55	H-35	Southeast Wall - Filing Cabinet	2707262	21-Oct-19	6:37 AM	23-Oct-19	6:38 AM	0.4	None.
56	H-37	Desk	2708598	21-Oct-19	6:38 AM	23-Oct-19	6:39 AM	0.2	None.
57	H-36	Northwest Wall - Bookshelf	2708635	21-Oct-19	6:40 AM	23-Oct-19	6:41 AM	0.3	None.

Media Center (M) and Commons

#	Location/Type	Placement Description	Serial #	Dated Opened	Time Opened	Date Closed	Time Closed	Radon Test Results	Remarks
1	Media Center # 1	South Wall - Bookcase	2708604	21-Oct-19	7:00 AM	23-Oct-19	7:04 AM	0.5	None.
2	Media Center # 2	South Wall - Center - Bookcase	2704239	21-Oct-19	7:02 AM	23-Oct-19	7:05 AM	0.5	None.
3	Media Center # 3	Northeast Wall - Bookcase	27010016	21-Oct-19	7:03 AM	23-Oct-19	7:08 AM	0.5	None.
4	Media Center # 4	North Wall - Bookcase	2704140	21-Oct-19	7:06 AM	23-Oct-19	7:09 AM	0.4	None.
5	Media Center Computer Room	Southeast - Corner	2708633	21-Oct-19	7:10 AM	23-Oct-19	7:12 AM	0.5	None.
6	Commons # 1	Northeast - Pillar	2704211	21-Oct-19	7:14 AM	23-Oct-19	7:15 AM	0.1	None.
7	Commons # 2	Southwest Wall	2710012	6-Nov-19	4:33 AM	8-Nov-19	5:25 AM	1.0	The initial test canister (2708667) was moved.
8	Commons # 3	Southeast - Pillar	2708939	21-Oct-19	7:18 AM	23-Oct-19	7:18 AM	0.8	None.
9	Commons # 4	Southeast Counter	2708923	6-Nov-19	4:37 AM	8-Nov-19	5:27 AM	0.6	The initial test canister (2708101) was moved.
10	M-3	Northeast Wall - Desk	2704234	21-Oct-19	7:34 AM	23-Oct-19	7:35 AM	0.2	None.
11	M-3 - Duplicate	Northeast Wall - Desk	2710011	21-Oct-19	7:34 AM	23-Oct-19	7:35 AM	0.4	None.
12	M-2	West Wall - Center Counter	2704132	21-Oct-19	7:26 AM	23-Oct-19	7:28 AM	0.4	None.
13	M-2 Blank	West Wall - Center Counter	2708094	21-Oct-19	7:28 AM	21-Oct-19	7:28 AM	0.1	None.
14	M-1	East Wall - Center Desk	2808617	21-Oct-19	7:23 AM	23-Oct-19	7:26 AM	0.4	None.
15	M-1 - Duplicate	East Wall - Center Desk	2710013	21-Oct-19	7:24 AM	23-Oct-19	7:27 AM	0.4	None.

Gym (G)

#	Location/Type	Placement Description	Serial #	Dated Opened	Time Opened	Date Closed	Time Closed	Radon Test Results	Remarks
1	Gymnasium # 1	Southwest Corner of Gym	2704217	21-Oct-19	5:24 AM	23-Oct-19	5:34 AM	0.2	None.
2	Gymnasium # 2	Southeast Corner On AED	2707392	6-Nov-19	4:55 AM	8-Nov-19	5:20 AM	0.4	RTCA never received the initial test (2704227).
3	Gymnasium # 3	Southeast Corner of Gym - On Face of Equipment Room	2704116	21-Oct-19	5:29 AM	23-Oct-19	5:38 AM	0.1	None.
4	Gymnasium # 4	Northeast Corner of Gym on Equipment Room	2704123	21-Oct-19	5:31 AM	23-Oct-19	5:39 AM	0.1	None.
5	Gymnasium # 5	Northwest Corner of Gym - By Bleachers	2707323	21-Oct-19	5:37 AM	23-Oct-19	5:42 AM	0.1	None.
6	Gymnasium # 6	West Wall - 8' From North End	2704235	21-Oct-19	5:40 AM	23-Oct-19	5:44 AM	0.3	None.
7	Gymnasium # 7	West Wall - Center of Gym	2708928	21-Oct-19	5:42 AM	23-Oct-19	5:45 AM	0.5	None.
8	Gymnasium # 8	West Wall - 8' From South Door	2704190	21-Oct-19	5:45 AM	23-Oct-19	5:47 AM	0.4	None.
9	Gymnasium - Duplicate	West Wall - 8' From South Door	2710015	21-Oct-19	5:45 AM	23-Oct-19	5:48 AM	0.7	None.
10	Gymnasium - Blank	Northeast Corner of Gym - On Equipment Room By Bleachers	2708595	21-Oct-19	5:47 AM	21-Oct-19	5:47 AM	0.1	None.

Science (S)

#	Location/Type	Placement Description	Serial #	Dated Opened	Time Opened	Date Closed	Time Closed	Radon Test Results	Remarks
1	Planetarium	Southeast Corner - On Desk	2708630	21-Oct-19	6:00 AM	23-Oct-19	6:06 AM	0.3	None.
2	Planetarium - Office	Southeast Wall - Filing Cabinet	2739790	21-Oct-19	6:04 AM	23-Oct-19	6:09 AM	0.4	None.
3	S-7	Northeast Wall - Center Filing Cabinet	708612	21-Oct-19	6:09 AM	23-Oct-19	6:12 AM	0.1	None.
4	S-7 - Duplicate	Northeast Wall - Center On Filing Cabinet	2704117	21-Oct-19	6:09 AM	23-Oct-19	6:12 AM	0.2	None.
5	S-9	North Wall	2681596	21-Oct-19	6:12 AM	23-Oct-19	6:15 AM	0.3	None.
6	S-8	South Wall - Center Desk	2708550	21-Oct-19	6:15 AM	23-Oct-19	6:18 AM	0.1	None.
7	S-6	West Wall - Center Desk	2739793	21-Oct-19	6:19 AM	23-Oct-19	6:21 AM	0.3	None.
8	S-4	West Wall - Center Desk	2710020	21-Oct-19	6:21 AM	23-Oct-19	6:26 AM	0.3	None.
9	S-3	West Wall - Corner File Cabinet	2708524	21-Oct-19	6:24 AM	23-Oct-19	6:28 AM	0.1	None.
10	S-3 - Blank	West Wall - Corner File Cabinet	2708561	21-Oct-19	6:25 AM	21-Oct-19	6:25 AM	0.1	None.
11	S-2	East Wall - Center Desk	2708095	21-Oct-19	6:28 AM	23-Oct-19	6:32 AM	0.6	None.
12	S-5	North Wall - Desk	2708541	21-Oct-19	6:34 AM	23-Oct-19	6:34 AM	0.2	None.
13	S-1	East Wall - Desk	2704250	21-Oct-19	6:35 AM	23-Oct-19	6:36 AM	0.3	None.

Tech Arts (TA)

#	Location/Type	Placement Description	Serial #	Dated Opened	Time Opened	Date Closed	Time Closed	Radon Test Results	Remarks
1	TA-11	East Wall - Bookshelf	2707307	21-Oct-19	6:50 AM	23-Oct-19	6:51 AM	0.4	None.
2	TA-11 - Blank	East Wall - Bookshelf	2707255	21-Oct-19	6:50 AM	21-Oct-19	6:50 AM	0.3	None.
3	TA - 12	Southeast Wall - Corner Counter	2707310	21-Oct-19	6:48 AM	23-Oct-19	6:48 AM	0.3	None.
4	TA - 12 - Duplicate	Southeast Wall - Corner Counter	2710042	21-Oct-19	6:48 AM	23-Oct-19	6:48 AM	0.4	None.
5	Custodial Office	West Wall - Upper Shelf	2708660	21-Oct-19	6:54 AM	23-Oct-19	6:54 AM	0.3	None.
6	Wood Shop # 1	North Wall - Filing Cabinet	2707275	21-Oct-19	5:50 AM	23-Oct-19	5:58 AM	0.6	None.
7	Wood Shop # 2	East Wall - Filing Cabinet	2708557	21-Oct-19	5:53 AM	23-Oct-19	5:59 AM	0.3	None.
8	Wood Shop # 3	West Wall - Behind White Board	2707256	21-Oct-19	5:55 AM	23-Oct-19	6:01 AM	0.3	None.
9	Wood Shop - Office	West Wall	2704497	21-Oct-19	5:57 AM	23-Oct-19	6:01 AM	0.5	None.
10	Auto Shop # 1	Bookshelf By Door	2708528	21-Oct-19	6:01 AM	23-Oct-19	6:04 AM	0.4	Canister Dented

11	Auto Shop # 2	East Wall - Yellow Cabinet	2704492	21-Oct-19	6:05 AM	23-Oct-19	6:05 AM	0.1	None.
12	Auto Shop - Office	Filing Cabinet - Left of Desk	2708593	21-Oct-19	6:08 AM	23-Oct-19	6:08 AM	0.2	None.
13	Auto Shop - Classroom	West Wall - Cabinet	2707284	21-Oct-19	6:12 AM	23-Oct-19	6:13 AM	0.4	None.
14	Auto Shop Classroom - Blank	West Wall - Cabinet	2707305	21-Oct-19	6:12 AM	21-Oct-19	6:12 AM	0.1	None.
15	CTE - Shop	East Wall - Wire Tool Cabinet	2704491	21-Oct-19	6:18 AM	23-Oct-19	6:23 AM	0.8	None.
16	TA - 8	CNC Machine	2707308	21-Oct-19	6:21 AM	23-Oct-19	6:27 AM	0.4	None.
17	TA- 7	North Wall Behind Computer	2708114	21-Oct-19	6:24 AM	23-Oct-19	6:28 AM	0.2	None.
18	TA - 1	Southeast Wall - Shelf	2707272	21-Oct-19	6:31 AM	23-Oct-19	6:33 AM	0.5	None.
19	TA - 1 - Duplicate	Southeast Wall - Shelf	2707286	21-Oct-19	6:31 AM	23-Oct-19	6:33 AM	0.6	None.
20	TA - 2	East Wall - Shelf	2704518	21-Oct-19	6:28 AM	23-Oct-19	6:30 AM	0.1	None.
21	TA - 3	Northeast Wall - Cabinet	2707265	21-Oct-19	6:34 AM	23-Oct-19	6:36 AM	0.2	None.
22	TA - 4	Northwest Wall - Corner Bookshelf	2708531	21-Oct-19	6:35 AM	23-Oct-19	6:39 AM	0.2	None.
23	TA - 6	East Wall - Filing Cabinet	2707279	21-Oct-19	6:41 AM	23-Oct-19	6:44 AM	0.4	None.
24	TA - 6 Duplicate	East Wall - Wall Filing Cabinet	2708555	21-Oct-19	6:41 AM	23-Oct-19	6:44 AM	0.4	None.
25	TA-5	South Wall - By Paper Towel	2704528	21-Oct-19	6:38 AM	23-Oct-19	6:42 AM	0.2	None.

#	Type	Description	Serial #	Dated Opened	Time Opened	Date Closed	Time Closed	Radon Test Results	Remarks
1	CRM-1	Admin-Custodial Office E - Book Case	N/A	18-Oct-19	12:39 PM	23-Oct-19	4:39 AM	1.5	Continuous Radon Monitor - District Control Measure
2	CRM-2	Admin-Main Office E Table By Copier	N/A	21-Oct-19	5:08 AM	23-Oct-19	5:08 AM	0.8	Continuous Radon Monitor - District Control Measure
3	CRM-3	Admin-Conference Room A - West Table	N/A	21-Oct-19	5:04 AM	23-Oct-19	5:04 AM	1.0	Continuous Radon Monitor - District Control Measure

#	Type	Description	Serial #	Dated Opened	Time Opened	Date Closed	Time Closed	Radon Test Results	Remarks
1	Spike # 1 (Room 421)	KSU Radon Chamber Spiked This To 19.0 pCi/L	2708634	21-Oct-19	11:50 AM	23-Oct-19	11:50 AM	14.7	None.
2	Spike # 2 (Room 422)	KSU Radon Chamber Spiked This To 19.0 pCi/L	2704505	21-Oct-19	11:50 AM	23-Oct-19	11:50 AM	17.9	None.
3	Spike # 3 (Room 423)	KSU Radon Chamber Spiked This To 19.0 pCi/L	2708529	21-Oct-19	11:50 AM	23-Oct-19	11:50 AM	13.8	None.
4	Spike # 4 (Room 424)	KSU Radon Chamber Spiked This To 19.0 pCi/L	2708644	21-Oct-19	11:50 AM	23-Oct-19	11:50 AM	13.2	None.
5	Spike # 5 (Room 425)	KSU Radon Chamber Spiked This To 19.0 pCi/L	2704511	21-Oct-19	11:50 AM	23-Oct-19	11:50 AM	19.2	None.

*The E.P.A.'s recommended action level for radon is 4.0 pCi/L.

*This is not a health based number.

*Outdoor radon levels across the country average 0.4 pCi/L.

*If an RPD test result over 4.0 pCi/L differs by 28% or more, the data quality should be questioned.

*A trend in RPE values that are more than ± 30% should be investigated