

Site Radon Inspection Report

Date : 10/29/2018

Mr. Bryan Hogan
MEDFORD SCHOOL DISTRICT
815 South Oakdale Avenue
Medford, OR 97501-

Client: South Medford H.S.
Test Location: 1551 Cunningham Avenue
Medford, OR 97501-

Individual Canister Results

Canister ID# : 2612009 Test Start : 10/23/2018 @ 06:22
Canister Type : Charcoal Canister 3 inch Test Stop : 10/25/2018 @ 06:32
Location : 1st FL=C-109 DP Received: 10/29/2018 @ 12:53
Radon Level : 1.1 pCi/L Analyzed: 10/31/2018 @ 16:09
Error for Measurement is: ± 0.5 pCi/L

Canister ID# : 2612010 Test Start : 10/23/2018 @ 05:45
Canister Type : Charcoal Canister 3 inch Test Stop : 10/25/2018 @ 05:47
Location : 1st FL=A-148 Received: 10/29/2018 @ 12:53
Radon Level : 1.2 pCi/L Analyzed: 11/01/2018 @ 12:05
Error for Measurement is: ± 0.7 pCi/L

Canister ID# : 2612011 Test Start : 10/23/2018 @ 05:30
Canister Type : Charcoal Canister 3 inch Test Stop : 10/25/2018 @ 05:33
Location : 1st FL=Main Off.#2 Received: 10/29/2018 @ 12:53
Radon Level : 0.8 pCi/L Analyzed: 11/01/2018 @ 11:23
Error for Measurement is: ± 0.6 pCi/L

Canister ID# : 2612012 Test Start : 10/23/2018 @ 06:12
Canister Type : Charcoal Canister 3 inch Test Stop : 10/25/2018 @ 06:12
Location : 1st FL=Media Ctr #2 Received: 10/29/2018 @ 12:53
Radon Level : 1.0 pCi/L Analyzed: 11/01/2018 @ 11:23
Error for Measurement is: ± 0.7 pCi/L

Canister ID# : 2612013 Test Start : 10/23/2018 @ 06:18
Canister Type : Charcoal Canister 3 inch Test Stop : 10/25/2018 @ 06:20
Location : 1st FL=E-108 #2 Band Received: 10/29/2018 @ 12:53
Radon Level : 0.6 pCi/L Analyzed: 11/01/2018 @ 10:30
Error for Measurement is: ± 0.7 pCi/L

Canister ID# : 2612015 Test Start : 10/23/2018 @ 06:15
Canister Type : Charcoal Canister 3 inch Test Stop : 10/25/2018 @ 06:15
Location : 1st FL=Media Ctr #3 Received: 10/29/2018 @ 12:53
Radon Level : 0.6 pCi/L Analyzed: 11/01/2018 @ 11:40
Error for Measurement is: ± 0.8 pCi/L



Andreas C. George

Andreas C. George
Radon Measurement Specialist
NJ MES 11089

Dante Galan

Dante Galan
Laboratory Director

NRSB ARL0001
NYS ELAP ID: 10806
PADEP ID: 0346
NJDEP ID: NY933
NJ MEB 90036
FL DOH RB1609
IL RNL2000201

Site Radon Inspection Report

Date : 10/29/2018

Mr. Bryan Hogan
MEDFORD SCHOOL DISTRICT
815 South Oakdale Avenue
Medford, OR 97501-

Client: South Medford H.S.
Test Location: 1551 Cunningham Avenue
Medford, OR 97501-

Individual Canister Results

Canister ID# : 2612016 Test Start : 10/23/2018 @ 06:05
Canister Type : Charcoal Canister 3 inch Test Stop : 10/25/2018 @ 06:05
Location : 1st FL=Media Ctr NTS DP Received: 10/29/2018 @ 12:53
Radon Level : 0.4 pCi/L Analyzed: 10/31/2018 @ 11:13
Error for Measurement is: ± 0.6 pCi/L

Canister ID# : 2612018 Test Start : 10/23/2018 @ 06:07
Canister Type : Charcoal Canister 3 inch Test Stop : 10/25/2018 @ 06:07
Location : 1st FL=Main Off. 1A-119 Received: 10/29/2018 @ 12:53
Radon Level : 0.6 pCi/L Analyzed: 11/01/2018 @ 12:08
Error for Measurement is: ± 0.6 pCi/L

Canister ID# : 2612022 Test Start : 10/23/2018 @ 06:07
Canister Type : Charcoal Canister 3 inch Test Stop : 10/25/2018 @ 06:20
Location : 1st FL=C-105 Received: 10/29/2018 @ 12:53
Radon Level : 1.1 pCi/L Analyzed: 11/01/2018 @ 11:40
Error for Measurement is: ± 0.7 pCi/L

Canister ID# : 2612023 Test Start : 10/23/2018 @ 06:53
Canister Type : Charcoal Canister 3 inch Test Stop : 10/25/2018 @ 06:53
Location : 1st FL=Cafeteria #4 Received: 10/29/2018 @ 12:53
Radon Level : 0.1 pCi/L Analyzed: 11/01/2018 @ 11:40
Error for Measurement is: ± 0.8 pCi/L

Canister ID# : 2612024 Test Start : 10/23/2018 @ 06:10
Canister Type : Charcoal Canister 3 inch Test Stop : 10/25/2018 @ 06:12
Location : 1st FL=C-117 Received: 10/29/2018 @ 12:53
Radon Level : 0.3 pCi/L Analyzed: 10/31/2018 @ 16:07
Error for Measurement is: ± 0.6 pCi/L

Canister ID# : 2612026 Test Start : 10/23/2018 @ 05:50
Canister Type : Charcoal Canister 3 inch Test Stop : 10/25/2018 @ 06:08
Location : 1st FL=C-101 Received: 10/29/2018 @ 12:53
Radon Level : 0.7 pCi/L Analyzed: 10/31/2018 @ 16:40
Error for Measurement is: ± 0.6 pCi/L



Andreas C. George

Dante Galan

Andreas C. George
Radon Measurement Specialist
NJ MES 11089

Dante Galan
Laboratory Director

NRSB ARL0001
NYS ELAP ID: 10806
PADEP ID: 0346
NJDEP ID: NY933
NJ MEB 90036
FL DOH RB1609
IL RNL2000201

Site Radon Inspection Report

Date : 10/29/2018

Mr. Bryan Hogan
MEDFORD SCHOOL DISTRICT
815 South Oakdale Avenue
Medford, OR 97501-

Client: South Medford H.S.
Test Location: 1551 Cunningham Avenue
Medford, OR 97501-

Individual Canister Results

Canister ID# : 2612028 Test Start : 10/23/2018 @ 07:25
Canister Type : Charcoal Canister 3 inch Test Stop : 10/25/2018 @ 07:25
Location : 1st FL=Gym Off. E Received: 10/29/2018 @ 12:53
Radon Level : 0.6 pCi/L Analyzed: 10/31/2018 @ 16:26
Error for Measurement is: \pm 0.5 pCi/L

Canister ID# : 2612032 Test Start : 10/23/2018 @ 06:31
Canister Type : Charcoal Canister 3 inch Test Stop : 10/25/2018 @ 06:31
Location : 1st FL=Main Off. T A-112 Received: 10/29/2018 @ 12:53
Radon Level : 0.1 pCi/L Analyzed: 11/01/2018 @ 11:02
Error for Measurement is: \pm 0.7 pCi/L

Canister ID# : 2612033 Test Start : 10/23/2018 @ 06:54
Canister Type : Charcoal Canister 3 inch Test Stop : 10/25/2018 @ 06:56
Location : 1st FL=Gym #2 Received: 10/29/2018 @ 12:53
Radon Level : 0.3 pCi/L Analyzed: 10/31/2018 @ 16:43
Error for Measurement is: \pm 0.5 pCi/L

Canister ID# : 2612034 Test Start : 10/23/2018 @ 06:19
Canister Type : Charcoal Canister 3 inch Test Stop : 10/25/2018 @ 06:21
Location : 1st FL=C-118 Received: 10/29/2018 @ 12:53
Radon Level : 0.7 pCi/L Analyzed: 10/31/2018 @ 16:40
Error for Measurement is: \pm 0.6 pCi/L

Canister ID# : 2612035 Test Start : 10/23/2018 @ 05:42
Canister Type : Charcoal Canister 3 inch Test Stop : 10/25/2018 @ 05:42
Location : 1st FL=Main Off. B A-105 Received: 10/29/2018 @ 12:53
Radon Level : 0.9 pCi/L Analyzed: 11/01/2018 @ 11:42
Error for Measurement is: \pm 0.6 pCi/L

Canister ID# : 2612037 Test Start : 10/23/2018 @ 06:34
Canister Type : Charcoal Canister 3 inch Test Stop : 10/25/2018 @ 06:40
Location : 1st FL=C-112 Received: 10/29/2018 @ 12:53
Radon Level : 0.6 pCi/L Analyzed: 11/01/2018 @ 11:02
Error for Measurement is: \pm 0.8 pCi/L



Andreas C. George

Andreas C. George
Radon Measurement Specialist
NJ MES 11089

Dante Galan

Dante Galan
Laboratory Director

NRSB ARL0001
NYS ELAP ID: 10806
PADEP ID: 0346
NJDEP ID: NY933
NJ MEB 90036
FL DOH RB1609
IL RNL2000201

Site Radon Inspection Report

Date : 10/29/2018

Mr. Bryan Hogan
MEDFORD SCHOOL DISTRICT
815 South Oakdale Avenue
Medford, OR 97501-

Client: South Medford H.S.
Test Location: 1551 Cunningham Avenue
Medford, OR 97501-

Individual Canister Results

Canister ID# : 2612038 Test Start : 10/23/2018 @ 06:11
Canister Type : Charcoal Canister 3 inch Test Stop : 10/25/2018 @ 06:14
Location : 1st FL=E-105 Music Received: 10/29/2018 @ 12:53
Radon Level : 0.7 pCi/L Analyzed: 11/01/2018 @ 10:49
Error for Measurement is: \pm 0.6 pCi/L

Canister ID# : 2612039 Test Start : 10/23/2018 @ 06:39
Canister Type : Charcoal Canister 3 inch Test Stop : 10/25/2018 @ 06:40
Location : 1st FL=Cafeteria #1 Received: 10/29/2018 @ 12:53
Radon Level : 0.7 pCi/L Analyzed: 11/01/2018 @ 10:32
Error for Measurement is: \pm 0.6 pCi/L

Canister ID# : 2612041 Test Start : 10/23/2018 @ 06:30
Canister Type : Charcoal Canister 3 inch Test Stop : 10/25/2018 @ 06:32
Location : 1st FL=C-119 Received: 10/29/2018 @ 12:53
Radon Level : 0.7 pCi/L Analyzed: 11/01/2018 @ 11:04
Error for Measurement is: \pm 0.6 pCi/L

Canister ID# : 2612047 Test Start : 10/23/2018 @ 06:54
Canister Type : Charcoal Canister 3 inch Test Stop : 10/25/2018 @ 06:55
Location : 1st FL=A-145 Received: 10/29/2018 @ 12:53
Radon Level : 0.1 pCi/L Analyzed: 11/01/2018 @ 11:40
Error for Measurement is: \pm 0.9 pCi/L

Canister ID# : 2612051 Test Start : 10/23/2018 @ 07:20
Canister Type : Charcoal Canister 3 inch Test Stop : 10/25/2018 @ 07:21
Location : 1st FL=Gym Off. B Received: 10/29/2018 @ 12:53
Radon Level : 0.4 pCi/L Analyzed: 11/01/2018 @ 10:49
Error for Measurement is: \pm 0.5 pCi/L

Canister ID# : 2612056 Test Start : 10/23/2018 @ 06:25
Canister Type : Charcoal Canister 3 inch Test Stop : 10/25/2018 @ 06:25
Location : 1st FL=E-111 #2 Metals Received: 10/29/2018 @ 12:53
Radon Level : 0.7 pCi/L Analyzed: 10/31/2018 @ 16:26
Error for Measurement is: \pm 0.5 pCi/L



Andreas C. George

Andreas C. George
Radon Measurement Specialist
NJ MES 11089

Dante Galan

Dante Galan
Laboratory Director

NRSB ARL0001
NYS ELAP ID: 10806
PADEP ID: 0346
NJDEP ID: NY933
NJ MEB 90036
FL DOH RB1609
IL RNL2000201

Site Radon Inspection Report

Date : 10/29/2018

Mr. Bryan Hogan
MEDFORD SCHOOL DISTRICT
815 South Oakdale Avenue
Medford, OR 97501-

Client: South Medford H.S.
Test Location: 1551 Cunningham Avenue
Medford, OR 97501-

Individual Canister Results

Canister ID# : 2612058 Test Start : 10/23/2018 @ 06:23
Canister Type : Charcoal Canister 3 inch Test Stop : 10/25/2018 @ 06:24
Location : 1st FL=A-156 DP Received: 10/29/2018 @ 12:53
Radon Level : 1.5 pCi/L Analyzed: 11/01/2018 @ 11:02
Error for Measurement is: \pm 0.7 pCi/L

Canister ID# : 2612059 Test Start : 10/23/2018 @ 05:51
Canister Type : Charcoal Canister 3 inch Test Stop : 10/25/2018 @ 05:52
Location : 1st FL=D-109 DP Received: 10/29/2018 @ 12:53
Radon Level : 0.3 pCi/L Analyzed: 11/01/2018 @ 10:47
Error for Measurement is: \pm 0.8 pCi/L

Canister ID# : 2612060 Test Start : 10/23/2018 @ 06:52
Canister Type : Charcoal Canister 3 inch Test Stop : 10/25/2018 @ 06:54
Location : 1st FL=Gym #1 Received: 10/29/2018 @ 12:53
Radon Level : 0.2 pCi/L Analyzed: 10/31/2018 @ 16:24
Error for Measurement is: \pm 0.7 pCi/L

Canister ID# : 2612062 Test Start : 10/23/2018 @ 05:57
Canister Type : Charcoal Canister 3 inch Test Stop : 10/25/2018 @ 05:57
Location : 1st FL=Main Off. F A-113 Received: 10/29/2018 @ 12:53
Radon Level : 0.2 pCi/L Analyzed: 10/31/2018 @ 16:07
Error for Measurement is: \pm 0.7 pCi/L

Canister ID# : 2612065 Test Start : 10/23/2018 @ 06:05
Canister Type : Charcoal Canister 3 inch Test Stop : 10/25/2018 @ 06:05
Location : 1st FL=E-103 Received: 10/29/2018 @ 12:53
Radon Level : 0.7 pCi/L Analyzed: 11/01/2018 @ 10:30
Error for Measurement is: \pm 0.7 pCi/L

Canister ID# : 2612071 Test Start : 10/23/2018 @ 07:13
Canister Type : Charcoal Canister 3 inch Test Stop : 10/25/2018 @ 07:13
Location : 1st FL=Custodial Off. Received: 10/29/2018 @ 12:53
Radon Level : 0.3 pCi/L Analyzed: 10/31/2018 @ 16:40
Error for Measurement is: \pm 0.6 pCi/L



Andreas C. George

Andreas C. George
Radon Measurement Specialist
NJ MES 11089

Dante Galan

Dante Galan
Laboratory Director

NRSB ARL0001
NYS ELAP ID: 10806
PADEP ID: 0346
NJDEP ID: NY933
NJ MEB 90036
FL DOH RB1609
IL RNL2000201

Site Radon Inspection Report

Date : 10/29/2018

Mr. Bryan Hogan
MEDFORD SCHOOL DISTRICT
815 South Oakdale Avenue
Medford, OR 97501-

Client: South Medford H.S.
Test Location: 1551 Cunningham Avenue
Medford, OR 97501-

Individual Canister Results

Canister ID# : 2612075 Test Start : 10/23/2018 @ 06:03
Canister Type : Charcoal Canister 3 inch Test Stop : 10/25/2018 @ 06:17
Location : 1st FL=C-104 Received: 10/29/2018 @ 12:53
Radon Level : 0.3 pCi/L Analyzed: 10/31/2018 @ 16:09
Error for Measurement is: ± 0.5 pCi/L

Canister ID# : 2612076 Test Start : 10/23/2018 @ 06:17
Canister Type : Charcoal Canister 3 inch Test Stop : 10/25/2018 @ 06:18
Location : 1st FL=E-108 #1 Band Received: 10/29/2018 @ 12:53
Radon Level : 0.6 pCi/L Analyzed: 10/31/2018 @ 16:26
Error for Measurement is: ± 0.5 pCi/L

Canister ID# : 2612083 Test Start : 10/23/2018 @ 07:14
Canister Type : Charcoal Canister 3 inch Test Stop : 10/25/2018 @ 07:14
Location : 1st FL=Custodial DP Received: 10/29/2018 @ 12:53
Radon Level : 0.8 pCi/L Analyzed: 10/31/2018 @ 16:40
Error for Measurement is: ± 0.6 pCi/L

Canister ID# : 2612092 Test Start : 10/23/2018 @ 06:42
Canister Type : Charcoal Canister 3 inch Test Stop : 10/25/2018 @ 06:44
Location : 1st FL=A-143 Received: 10/29/2018 @ 12:53
Radon Level : 1.1 pCi/L Analyzed: 11/01/2018 @ 10:49
Error for Measurement is: ± 0.7 pCi/L

Canister ID# : 2612093 Test Start : 10/23/2018 @ 06:20
Canister Type : Charcoal Canister 3 inch Test Stop : 10/25/2018 @ 06:20
Location : 1st FL=Main Off. P Health Received: 10/29/2018 @ 12:53
Radon Level : 0.6 pCi/L Analyzed: 11/01/2018 @ 11:42
Error for Measurement is: ± 0.5 pCi/L

Canister ID# : 2612094 Test Start : 10/23/2018 @ 05:58
Canister Type : Charcoal Canister 3 inch Test Stop : 10/25/2018 @ 06:00
Location : 1st FL=C-115 Received: 10/29/2018 @ 12:53
Radon Level : 0.2 pCi/L Analyzed: 10/31/2018 @ 16:24
Error for Measurement is: ± 0.5 pCi/L



Andreas C. George

Andreas C. George
Radon Measurement Specialist
NJ MES 11089

Dante Galan

Dante Galan
Laboratory Director

NRSB ARL0001
NYS ELAP ID: 10806
PADEP ID: 0346
NJDEP ID: NY933
NJ MEB 90036
FL DOH RB1609
IL RNL2000201

Site Radon Inspection Report

Date : 10/29/2018

Mr. Bryan Hogan
MEDFORD SCHOOL DISTRICT
815 South Oakdale Avenue
Medford, OR 97501-

Client: South Medford H.S.
Test Location: 1551 Cunningham Avenue
Medford, OR 97501-

Individual Canister Results

Canister ID# : 2612095 Test Start : 10/23/2018 @ 06:05
Canister Type : Charcoal Canister 3 inch Test Stop : 10/25/2018 @ 06:05
Location : 1st FL=Main Off. H New Off. Received: 10/29/2018 @ 12:53
Radon Level : 0.7 pCi/L Analyzed: 10/31/2018 @ 16:42
Error for Measurement is: \pm 0.6 pCi/L

Canister ID# : 2612096 Test Start : 10/23/2018 @ 05:54
Canister Type : Charcoal Canister 3 inch Test Stop : 10/25/2018 @ 06:12
Location : 1st FL=C-102 Received: 10/29/2018 @ 12:53
Radon Level : 0.9 pCi/L Analyzed: 10/31/2018 @ 16:24
Error for Measurement is: \pm 0.6 pCi/L

Canister ID# : 2612098 Test Start : 10/23/2018 @ 06:10
Canister Type : Charcoal Canister 3 inch Test Stop : 10/25/2018 @ 06:22
Location : 1st FL=C-106 Received: 10/29/2018 @ 12:53
Radon Level : 1.3 pCi/L Analyzed: 11/01/2018 @ 11:42
Error for Measurement is: \pm 0.7 pCi/L

Canister ID# : 2612099 Test Start : 10/23/2018 @ 05:41
Canister Type : Charcoal Canister 3 inch Test Stop : 10/25/2018 @ 05:45
Location : 1st FL=A-147 Received: 10/29/2018 @ 12:53
Radon Level : 0.8 pCi/L Analyzed: 11/01/2018 @ 11:42
Error for Measurement is: \pm 0.6 pCi/L

Canister ID# : 2612100 Test Start : 10/23/2018 @ 07:21
Canister Type : Charcoal Canister 3 inch Test Stop : 10/25/2018 @ 07:23
Location : 1st FL=Gym Off. D Received: 10/29/2018 @ 12:53
Radon Level : 0.5 pCi/L Analyzed: 11/01/2018 @ 11:02
Error for Measurement is: \pm 0.8 pCi/L

Canister ID# : 2612101 Test Start : 10/23/2018 @ 09:50
Canister Type : Charcoal Canister 3 inch Test Stop : 10/25/2018 @ 09:50
Location : 1st FL=Gym Off. H Received: 10/29/2018 @ 12:53
Radon Level : 16.6 pCi/L Analyzed: 11/01/2018 @ 10:49
Error for Measurement is: \pm 0.9 pCi/L



Andreas C. George

Andreas C. George
Radon Measurement Specialist
NJ MES 11089

Dante Galan

Dante Galan
Laboratory Director

NRSB ARL0001
NYS ELAP ID: 10806
PADEP ID: 0346
NJDEP ID: NY933
NJ MEB 90036
FL DOH RB1609
IL RNL2000201

Site Radon Inspection Report

Date : 10/29/2018

Mr. Bryan Hogan
MEDFORD SCHOOL DISTRICT
815 South Oakdale Avenue
Medford, OR 97501-

Client: South Medford H.S.
Test Location: 1551 Cunningham Avenue
Medford, OR 97501-

Individual Canister Results

Canister ID# : 2612104 Test Start : 10/23/2018 @ 06:26
Canister Type : Charcoal Canister 3 inch Test Stop : 10/25/2018 @ 06:26
Location : 1st FL=Main Off. R A-108 Received: 10/29/2018 @ 12:53
Radon Level : 0.4 pCi/L Analyzed: 11/01/2018 @ 11:02
Error for Measurement is: \pm 0.6 pCi/L

Canister ID# : 2612108 Test Start : 10/23/2018 @ 06:19
Canister Type : Charcoal Canister 3 inch Test Stop : 10/25/2018 @ 06:19
Location : 1st FL=Main Off. O A-135 Received: 10/29/2018 @ 12:53
Radon Level : 0.7 pCi/L Analyzed: 11/01/2018 @ 10:30
Error for Measurement is: \pm 0.7 pCi/L

Canister ID# : 2612110 Test Start : 10/23/2018 @ 06:03
Canister Type : Charcoal Canister 3 inch Test Stop : 10/25/2018 @ 06:05
Location : 1st FL=C-116 Received: 10/29/2018 @ 12:53
Radon Level : 1.6 pCi/L Analyzed: 11/01/2018 @ 11:42
Error for Measurement is: \pm 0.6 pCi/L

Canister ID# : 2612111 Test Start : 10/23/2018 @ 05:57
Canister Type : Charcoal Canister 3 inch Test Stop : 10/25/2018 @ 05:58
Location : 1st FL=A-151 Received: 10/29/2018 @ 12:53
Radon Level : 0.1 pCi/L Analyzed: 10/31/2018 @ 16:40
Error for Measurement is: \pm 0.6 pCi/L

Canister ID# : 2612114 Test Start : 10/23/2018 @ 06:48
Canister Type : Charcoal Canister 3 inch Test Stop : 10/25/2018 @ 06:48
Location : 1st FL=Cafeteria #3 Received: 10/29/2018 @ 12:53
Radon Level : 1.0 pCi/L Analyzed: 11/01/2018 @ 10:46
Error for Measurement is: \pm 0.7 pCi/L

Canister ID# : 2612115 Test Start : 10/23/2018 @ 06:56
Canister Type : Charcoal Canister 3 inch Test Stop : 10/25/2018 @ 06:56
Location : 1st FL=Theater #1 Received: 10/29/2018 @ 12:53
Radon Level : 0.4 pCi/L Analyzed: 11/01/2018 @ 10:49
Error for Measurement is: \pm 0.7 pCi/L



Andreas C. George

Andreas C. George
Radon Measurement Specialist
NJ MES 11089

Dante Galan

Dante Galan
Laboratory Director

NRSB ARL0001
NYS ELAP ID: 10806
PADEP ID: 0346
NJDEP ID: NY933
NJ MEB 90036
FL DOH RB1609
IL RNL2000201

Site Radon Inspection Report

Date : 10/29/2018

Mr. Bryan Hogan
MEDFORD SCHOOL DISTRICT
815 South Oakdale Avenue
Medford, OR 97501-

Client: South Medford H.S.
Test Location: 1551 Cunningham Avenue
Medford, OR 97501-

Individual Canister Results

Canister ID# : 2612116 Test Start : 10/23/2018 @ 06:25
Canister Type : Charcoal Canister 3 inch Test Stop : 10/25/2018 @ 06:25
Location : 1st FL=Media Ctr #5 NW Received: 10/29/2018 @ 12:53
Radon Level : 0.8 pCi/L Analyzed: 11/01/2018 @ 11:40
Error for Measurement is: \pm 0.7 pCi/L

Canister ID# : 2612117 Test Start : 10/23/2018 @ 06:31
Canister Type : Charcoal Canister 3 inch Test Stop : 10/25/2018 @ 06:32
Location : 1st FL=E-112 #2 Auto Received: 10/29/2018 @ 12:53
Radon Level : 0.5 pCi/L Analyzed: 10/31/2018 @ 16:43
Error for Measurement is: \pm 0.6 pCi/L

Canister ID# : 2612119 Test Start : 10/23/2018 @ 05:59
Canister Type : Charcoal Canister 3 inch Test Stop : 10/25/2018 @ 06:08
Location : 1st FL=Main Off. W A-118 Received: 10/29/2018 @ 12:53
Radon Level : 0.9 pCi/L Analyzed: 10/31/2018 @ 16:24
Error for Measurement is: \pm 0.6 pCi/L

Canister ID# : 2612121 Test Start : 10/23/2018 @ 05:48
Canister Type : Charcoal Canister 3 inch Test Stop : 10/25/2018 @ 05:49
Location : 1st FL=A-149 Received: 10/29/2018 @ 12:53
Radon Level : 0.4 pCi/L Analyzed: 11/01/2018 @ 11:21
Error for Measurement is: \pm 0.8 pCi/L

Canister ID# : 2612122 Test Start : 10/23/2018 @ 06:43
Canister Type : Charcoal Canister 3 inch Test Stop : 10/25/2018 @ 06:43
Location : 1st FL=Cafeteria #2 Received: 10/29/2018 @ 12:53
Radon Level : 1.0 pCi/L Analyzed: 11/01/2018 @ 11:05
Error for Measurement is: \pm 0.6 pCi/L

Canister ID# : 2612126 Test Start : 10/23/2018 @ 06:28
Canister Type : Charcoal Canister 3 inch Test Stop : 10/25/2018 @ 06:29
Location : 1st FL=A-126 Received: 10/29/2018 @ 12:53
Radon Level : 0.7 pCi/L Analyzed: 11/01/2018 @ 10:32
Error for Measurement is: \pm 0.6 pCi/L



Andreas C. George

Andreas C. George
Radon Measurement Specialist
NJ MES 11089

Dante Galan

Dante Galan
Laboratory Director

NRSB ARL0001
NYS ELAP ID: 10806
PADEP ID: 0346
NJDEP ID: NY933
NJ MEB 90036
FL DOH RB1609
IL RNL2000201

Site Radon Inspection Report

Date : 10/29/2018

Mr. Bryan Hogan
MEDFORD SCHOOL DISTRICT
815 South Oakdale Avenue
Medford, OR 97501-

Client: South Medford H.S.
Test Location: 1551 Cunningham Avenue
Medford, OR 97501-

Individual Canister Results

Canister ID# : 2612128 Test Start : 10/23/2018 @ 06:25
Canister Type : Charcoal Canister 3 inch Test Stop : 10/25/2018 @ 06:35
Location : 1st FL=C-110 Received: 10/29/2018 @ 12:53
Radon Level : 1.0 pCi/L Analyzed: 11/01/2018 @ 10:32
Error for Measurement is: \pm 0.6 pCi/L

Canister ID# : 2612129 Test Start : 10/23/2018 @ 06:05
Canister Type : Charcoal Canister 3 inch Test Stop : 10/25/2018 @ 06:05
Location : 1st FL=Media Ctr NTS Received: 10/29/2018 @ 12:53
Radon Level : 0.6 pCi/L Analyzed: 11/01/2018 @ 10:32
Error for Measurement is: \pm 0.6 pCi/L

Canister ID# : 2612130 Test Start : 10/23/2018 @ 05:55
Canister Type : Charcoal Canister 3 inch Test Stop : 10/25/2018 @ 05:55
Location : 1st FL=Main Off. E A-111 Received: 10/29/2018 @ 12:53
Radon Level : 0.5 pCi/L Analyzed: 11/01/2018 @ 11:05
Error for Measurement is: \pm 0.7 pCi/L

Canister ID# : 2612132 Test Start : 10/23/2018 @ 06:33
Canister Type : Charcoal Canister 3 inch Test Stop : 10/25/2018 @ 06:33
Location : 1st FL=Main Off. U A-114 Received: 10/29/2018 @ 12:53
Radon Level : 0.8 pCi/L Analyzed: 11/01/2018 @ 11:23
Error for Measurement is: \pm 0.6 pCi/L

Canister ID# : 2612134 Test Start : 10/23/2018 @ 06:25
Canister Type : Charcoal Canister 3 inch Test Stop : 10/25/2018 @ 06:25
Location : 1st FL=Media Ctr BL Received: 10/29/2018 @ 12:53
Radon Level : 0.1 pCi/L Analyzed: 10/31/2018 @ 16:24
Error for Measurement is: \pm 0.5 pCi/L

Canister ID# : 2612136 Test Start : 10/23/2018 @ 05:55
Canister Type : Charcoal Canister 3 inch Test Stop : 10/25/2018 @ 05:55
Location : 1st FL=E-101 Received: 10/29/2018 @ 12:53
Radon Level : 0.7 pCi/L Analyzed: 10/31/2018 @ 16:40
Error for Measurement is: \pm 0.7 pCi/L



Andreas C. George

Andreas C. George
Radon Measurement Specialist
NJ MES 11089

Dante Galan

Dante Galan
Laboratory Director

NRSB ARL0001
NYS ELAP ID: 10806
PADEP ID: 0346
NJDEP ID: NY933
NJ MEB 90036
FL DOH RB1609
IL RNL2000201

Site Radon Inspection Report

Date : 10/29/2018

Mr. Bryan Hogan
MEDFORD SCHOOL DISTRICT
815 South Oakdale Avenue
Medford, OR 97501-

Client: South Medford H.S.
Test Location: 1551 Cunningham Avenue
Medford, OR 97501-

Individual Canister Results

Canister ID# : 2612141 Test Start : 10/23/2018 @ 06:37
Canister Type : Charcoal Canister 3 inch Test Stop : 10/25/2018 @ 06:38
Location : 1st FL=A-141 Received: 10/29/2018 @ 12:53
Radon Level : 0.6 pCi/L Analyzed: 11/01/2018 @ 11:40
Error for Measurement is: \pm 0.7 pCi/L

Canister ID# : 2612142 Test Start : 10/23/2018 @ 06:56
Canister Type : Charcoal Canister 3 inch Test Stop : 10/25/2018 @ 06:58
Location : 1st FL=Gym #3 Received: 10/29/2018 @ 12:53
Radon Level : 0.8 pCi/L Analyzed: 11/01/2018 @ 10:46
Error for Measurement is: \pm 0.7 pCi/L

Canister ID# : 2612143 Test Start : 10/23/2018 @ 06:29
Canister Type : Charcoal Canister 3 inch Test Stop : 10/25/2018 @ 06:38
Location : 1st FL=C-111 Received: 10/29/2018 @ 12:53
Radon Level : 1.2 pCi/L Analyzed: 11/01/2018 @ 10:32
Error for Measurement is: \pm 0.6 pCi/L

Canister ID# : 2612145 Test Start : 10/23/2018 @ 07:05
Canister Type : Charcoal Canister 3 inch Test Stop : 10/25/2018 @ 07:07
Location : 1st FL=Gym #6 Received: 10/29/2018 @ 12:53
Radon Level : 0.1 pCi/L Analyzed: 10/31/2018 @ 16:24
Error for Measurement is: \pm 0.5 pCi/L

Canister ID# : 2612146 Test Start : 10/23/2018 @ 07:18
Canister Type : Charcoal Canister 3 inch Test Stop : 10/25/2018 @ 07:19
Location : 1st FL=Gym Off. A Training Received: 10/29/2018 @ 12:53
Radon Level : 0.5 pCi/L Analyzed: 11/01/2018 @ 10:32
Error for Measurement is: \pm 0.6 pCi/L

Canister ID# : 2612149 Test Start : 10/23/2018 @ 06:22
Canister Type : Charcoal Canister 3 inch Test Stop : 10/25/2018 @ 06:32
Location : 1st FL=C-109 Received: 10/29/2018 @ 12:53
Radon Level : 1.8 pCi/L Analyzed: 11/01/2018 @ 11:02
Error for Measurement is: \pm 0.7 pCi/L



Andreas C. George

Andreas C. George
Radon Measurement Specialist
NJ MES 11089

Dante Galan

Dante Galan
Laboratory Director

NRSB ARL0001
NYS ELAP ID: 10806
PADEP ID: 0346
NJDEP ID: NY933
NJ MEB 90036
FL DOH RB1609
IL RNL2000201

Site Radon Inspection Report

Date : 10/29/2018

Mr. Bryan Hogan
MEDFORD SCHOOL DISTRICT
815 South Oakdale Avenue
Medford, OR 97501-

Client: South Medford H.S.
Test Location: 1551 Cunningham Avenue
Medford, OR 97501-

Individual Canister Results

Canister ID# : 2612474 Test Start : 10/23/2018 @ 06:35
Canister Type : Charcoal Canister 3 inch Test Stop : 10/25/2018 @ 06:37
Location : 1st FL=C-120 Received: 10/29/2018 @ 12:53
Radon Level : 0.8 pCi/L Analyzed: 10/31/2018 @ 16:26
Error for Measurement is: \pm 0.6 pCi/L

Canister ID# : 2612475 Test Start : 10/23/2018 @ 06:46
Canister Type : Charcoal Canister 3 inch Test Stop : 10/25/2018 @ 06:47
Location : 1st FL=A-144 Received: 10/29/2018 @ 12:53
Radon Level : 0.8 pCi/L Analyzed: 11/01/2018 @ 11:23
Error for Measurement is: \pm 0.6 pCi/L

Canister ID# : 2612476 Test Start : 10/23/2018 @ 09:50
Canister Type : Charcoal Canister 3 inch Test Stop : 10/25/2018 @ 09:50
Location : 1st FL=Gym Off. F Received: 10/29/2018 @ 12:53
Radon Level : 16.1 pCi/L Analyzed: 10/31/2018 @ 16:40
Error for Measurement is: \pm 0.9 pCi/L

Canister ID# : 2612479 Test Start : 10/23/2018 @ 06:59
Canister Type : Charcoal Canister 3 inch Test Stop : 10/25/2018 @ 07:01
Location : 1st FL=Gym #4 Received: 10/29/2018 @ 12:53
Radon Level : 1.0 pCi/L Analyzed: 11/01/2018 @ 11:04
Error for Measurement is: \pm 0.7 pCi/L

Canister ID# : 2612490 Test Start : 10/23/2018 @ 05:59
Canister Type : Charcoal Canister 3 inch Test Stop : 10/25/2018 @ 06:15
Location : 1st FL=C-103 Received: 10/29/2018 @ 12:53
Radon Level : 1.4 pCi/L Analyzed: 11/01/2018 @ 10:46
Error for Measurement is: \pm 0.7 pCi/L

Canister ID# : 2612556 Test Start : 10/23/2018 @ 05:52
Canister Type : Charcoal Canister 3 inch Test Stop : 10/25/2018 @ 05:52
Location : 1st FL=Main Off. C A-107 Received: 10/29/2018 @ 12:53
Radon Level : 0.5 pCi/L Analyzed: 11/01/2018 @ 11:04
Error for Measurement is: \pm 0.6 pCi/L



Andreas C. George

Andreas C. George
Radon Measurement Specialist
NJ MES 11089

Dante Galan

Dante Galan
Laboratory Director

NRSB ARL0001
NYS ELAP ID: 10806
PADEP ID: 0346
NJDEP ID: NY933
NJ MEB 90036
FL DOH RB1609
IL RNL2000201

Site Radon Inspection Report

Date : 10/29/2018

Mr. Bryan Hogan
MEDFORD SCHOOL DISTRICT
815 South Oakdale Avenue
Medford, OR 97501-

Client: South Medford H.S.
Test Location: 1551 Cunningham Avenue
Medford, OR 97501-

Individual Canister Results

Canister ID# : 2612568 Test Start : 10/23/2018 @ 05:33
Canister Type : Charcoal Canister 3 inch Test Stop : 10/25/2018 @ 05:35
Location : 1st FL=Main Off.A A-103 Received: 10/29/2018 @ 12:53
Radon Level : 0.4 pCi/L Analyzed: 11/01/2018 @ 11:21
Error for Measurement is: \pm 0.9 pCi/L

Canister ID# : 2612569 Test Start : 10/23/2018 @ 05:53
Canister Type : Charcoal Canister 3 inch Test Stop : 10/25/2018 @ 05:56
Location : 1st FL=A-150 Received: 10/29/2018 @ 12:53
Radon Level : 1.7 pCi/L Analyzed: 11/01/2018 @ 10:49
Error for Measurement is: \pm 0.6 pCi/L

Canister ID# : 2612571 Test Start : 10/23/2018 @ 05:54
Canister Type : Charcoal Canister 3 inch Test Stop : 10/25/2018 @ 05:54
Location : 1st FL=Main Off. D A-109 Received: 10/29/2018 @ 12:53
Radon Level : 0.4 pCi/L Analyzed: 11/01/2018 @ 11:42
Error for Measurement is: \pm 0.5 pCi/L

Canister ID# : 2619245 Test Start : 10/23/2018 @ 06:19
Canister Type : Charcoal Canister 3 inch Test Stop : 10/25/2018 @ 06:19
Location : 1st FL=Media Ctr #4 Received: 10/29/2018 @ 12:53
Radon Level : 0.5 pCi/L Analyzed: 11/01/2018 @ 11:40
Error for Measurement is: \pm 0.8 pCi/L

Canister ID# : 2619255 Test Start : 10/23/2018 @ 09:50
Canister Type : Charcoal Canister 3 inch Test Stop : 10/25/2018 @ 09:50
Location : 1st FL=Gym Off. G Received: 10/29/2018 @ 12:53
Radon Level : 13.0 pCi/L Analyzed: 11/01/2018 @ 11:02
Error for Measurement is: \pm 0.9 pCi/L

Canister ID# : 2619294 Test Start : 10/23/2018 @ 07:18
Canister Type : Charcoal Canister 3 inch Test Stop : 10/25/2018 @ 07:19
Location : 1st FL=Gym Off. A BL Received: 10/29/2018 @ 12:53
Radon Level : 0.2 pCi/L Analyzed: 11/01/2018 @ 11:40
Error for Measurement is: \pm 0.7 pCi/L



Andreas C. George

Andreas C. George
Radon Measurement Specialist
NJ MES 11089

Dante Galan

Dante Galan
Laboratory Director

NRSB ARL0001
NYS ELAP ID: 10806
PADEP ID: 0346
NJDEP ID: NY933
NJ MEB 90036
FL DOH RB1609
IL RNL2000201

Site Radon Inspection Report

Date : 10/29/2018

Mr. Bryan Hogan
MEDFORD SCHOOL DISTRICT
815 South Oakdale Avenue
Medford, OR 97501-

Client: South Medford H.S.
Test Location: 1551 Cunningham Avenue
Medford, OR 97501-

Individual Canister Results

Canister ID# : 2619297 Test Start : 10/23/2018 @ 05:28
Canister Type : Charcoal Canister 3 inch Test Stop : 10/25/2018 @ 05:32
Location : 1st FL=Main Off.#1 DP Received: 10/29/2018 @ 12:53
Radon Level : 0.8 pCi/L Analyzed: 11/01/2018 @ 11:23
Error for Measurement is: \pm 0.6 pCi/L

Canister ID# : 2619332 Test Start : 10/23/2018 @ 07:22
Canister Type : Charcoal Canister 3 inch Test Stop : 10/25/2018 @ 07:22
Location : 1st FL=Gym Off. C Received: 10/29/2018 @ 12:53
Radon Level : 0.2 pCi/L Analyzed: 11/01/2018 @ 10:32
Error for Measurement is: \pm 0.6 pCi/L

Canister ID# : 2619345 Test Start : 10/23/2018 @ 06:24
Canister Type : Charcoal Canister 3 inch Test Stop : 10/25/2018 @ 06:25
Location : 1st FL=E-111 #1 Metals Received: 10/29/2018 @ 12:53
Radon Level : 0.6 pCi/L Analyzed: 11/01/2018 @ 10:47
Error for Measurement is: \pm 0.7 pCi/L

Canister ID# : 2619349 Test Start : 10/23/2018 @ 07:07
Canister Type : Charcoal Canister 3 inch Test Stop : 10/25/2018 @ 07:08
Location : 1st FL=Gym #7 Received: 10/29/2018 @ 12:53
Radon Level : 0.6 pCi/L Analyzed: 10/31/2018 @ 16:09
Error for Measurement is: \pm 0.5 pCi/L

Canister ID# : 2619351 Test Start : 10/23/2018 @ 05:55
Canister Type : Charcoal Canister 3 inch Test Stop : 10/25/2018 @ 05:56
Location : 1st FL=C-114 BL Received: 10/29/2018 @ 12:53
Radon Level : 0.1 pCi/L Analyzed: 10/31/2018 @ 16:09
Error for Measurement is: \pm 0.4 pCi/L

Canister ID# : 2619352 Test Start : 10/23/2018 @ 06:12
Canister Type : Charcoal Canister 3 inch Test Stop : 10/25/2018 @ 06:13
Location : 1st FL=C-117 DP Received: 10/29/2018 @ 12:53
Radon Level : 0.4 pCi/L Analyzed: 10/31/2018 @ 16:40
Error for Measurement is: \pm 0.7 pCi/L



Andreas C. George

Andreas C. George
Radon Measurement Specialist
NJ MES 11089

Dante Galan

Dante Galan
Laboratory Director

NRSB ARL0001
NYS ELAP ID: 10806
PADEP ID: 0346
NJDEP ID: NY933
NJ MEB 90036
FL DOH RB1609
IL RNL2000201

Site Radon Inspection Report

Date : 10/29/2018

Mr. Bryan Hogan
MEDFORD SCHOOL DISTRICT
815 South Oakdale Avenue
Medford, OR 97501-

Client: South Medford H.S.
Test Location: 1551 Cunningham Avenue
Medford, OR 97501-

Individual Canister Results

Canister ID# : 2619356 Test Start : 10/23/2018 @ 06:19
Canister Type : Charcoal Canister 3 inch Test Stop : 10/25/2018 @ 06:29
Location : 1st FL=C-108 Received: 10/29/2018 @ 12:53
Radon Level : 1.3 pCi/L Analyzed: 11/01/2018 @ 10:32
Error for Measurement is: \pm 0.7 pCi/L

Canister ID# : 2619399 Test Start : 10/23/2018 @ 06:16
Canister Type : Charcoal Canister 3 inch Test Stop : 10/25/2018 @ 06:16
Location : 1st FL=A-124 Panther Ctr Received: 10/29/2018 @ 12:53
Radon Level : 0.1 pCi/L Analyzed: 11/01/2018 @ 10:30
Error for Measurement is: \pm 0.5 pCi/L

Canister ID# : 2619400 Test Start : 10/23/2018 @ 06:15
Canister Type : Charcoal Canister 3 inch Test Stop : 10/25/2018 @ 06:15
Location : 1st FL=Main Off. L A-127 Received: 10/29/2018 @ 12:53
Radon Level : 0.1 pCi/L Analyzed: 10/31/2018 @ 16:07
Error for Measurement is: \pm 0.2 pCi/L

Canister ID# : 2619407 Test Start : 10/23/2018 @ 05:28
Canister Type : Charcoal Canister 3 inch Test Stop : 10/25/2018 @ 05:32
Location : 1st FL=Main Off.#1 Received: 10/29/2018 @ 12:53
Radon Level : 0.5 pCi/L Analyzed: 11/01/2018 @ 11:05
Error for Measurement is: \pm 0.6 pCi/L

Canister ID# : 2619410 Test Start : 10/23/2018 @ 06:15
Canister Type : Charcoal Canister 3 inch Test Stop : 10/25/2018 @ 06:17
Location : 1st FL=A-155 Received: 10/29/2018 @ 12:53
Radon Level : 0.8 pCi/L Analyzed: 11/01/2018 @ 11:04
Error for Measurement is: \pm 0.6 pCi/L

Canister ID# : 2619415 Test Start : 10/23/2018 @ 06:17
Canister Type : Charcoal Canister 3 inch Test Stop : 10/25/2018 @ 06:17
Location : 1st FL=A-155 BL Received: 10/29/2018 @ 12:53
Radon Level : 0.1 pCi/L Analyzed: 11/01/2018 @ 10:46
Error for Measurement is: \pm 0.4 pCi/L



Andreas C. George

Andreas C. George
Radon Measurement Specialist
NJ MES 11089

Dante Galan

Dante Galan
Laboratory Director

NRSB ARL0001
NYS ELAP ID: 10806
PADEP ID: 0346
NJDEP ID: NY933
NJ MEB 90036
FL DOH RB1609
IL RNL2000201

Site Radon Inspection Report

Date : 10/29/2018

Mr. Bryan Hogan
MEDFORD SCHOOL DISTRICT
815 South Oakdale Avenue
Medford, OR 97501-

Client: South Medford H.S.
Test Location: 1551 Cunningham Avenue
Medford, OR 97501-

Individual Canister Results

Canister ID# : 2619421 Test Start : 10/23/2018 @ 06:06
Canister Type : Charcoal Canister 3 inch Test Stop : 10/25/2018 @ 06:05
Location : 1st FL=E-103 DP Received: 10/29/2018 @ 12:53
Radon Level : 0.5 pCi/L Analyzed: 11/01/2018 @ 10:47
Error for Measurement is: \pm 0.8 pCi/L

Canister ID# : 2619423 Test Start : 10/23/2018 @ 06:00
Canister Type : Charcoal Canister 3 inch Test Stop : 10/25/2018 @ 06:00
Location : 1st FL=Main Off. G A-115 Received: 10/29/2018 @ 12:53
Radon Level : 0.6 pCi/L Analyzed: 10/31/2018 @ 16:26
Error for Measurement is: \pm 0.5 pCi/L

Canister ID# : 2619425 Test Start : 10/23/2018 @ 05:50
Canister Type : Charcoal Canister 3 inch Test Stop : 10/25/2018 @ 05:55
Location : 1st FL=C-114 Received: 10/29/2018 @ 12:53
Radon Level : 1.5 pCi/L Analyzed: 11/01/2018 @ 11:42
Error for Measurement is: \pm 0.6 pCi/L

Canister ID# : 2619426 Test Start : 10/23/2018 @ 05:50
Canister Type : Charcoal Canister 3 inch Test Stop : 10/25/2018 @ 05:52
Location : 1st FL=D-109 CTE Received: 10/29/2018 @ 12:53
Radon Level : 0.4 pCi/L Analyzed: 11/01/2018 @ 10:30
Error for Measurement is: \pm 0.6 pCi/L

Canister ID# : 2619427 Test Start : 10/23/2018 @ 05:56
Canister Type : Charcoal Canister 3 inch Test Stop : 10/25/2018 @ 05:56
Location : 1st FL=Media Ctr #1 Received: 10/29/2018 @ 12:53
Radon Level : 0.7 pCi/L Analyzed: 10/31/2018 @ 16:26
Error for Measurement is: \pm 0.6 pCi/L

Canister ID# : 2619443 Test Start : 10/23/2018 @ 06:15
Canister Type : Charcoal Canister 3 inch Test Stop : 10/25/2018 @ 06:24
Location : 1st FL=C-107 Received: 10/29/2018 @ 12:53
Radon Level : 0.5 pCi/L Analyzed: 10/31/2018 @ 16:24
Error for Measurement is: \pm 0.7 pCi/L



Andreas C. George

Andreas C. George
Radon Measurement Specialist
NJ MES 11089

Dante Galan

Dante Galan
Laboratory Director

NRSB ARL0001
NYS ELAP ID: 10806
PADEP ID: 0346
NJDEP ID: NY933
NJ MEB 90036
FL DOH RB1609
IL RNL2000201

Site Radon Inspection Report

Date : 10/29/2018

Mr. Bryan Hogan
MEDFORD SCHOOL DISTRICT
815 South Oakdale Avenue
Medford, OR 97501-

Client: South Medford H.S.
Test Location: 1551 Cunningham Avenue
Medford, OR 97501-

Individual Canister Results

Canister ID# : 2619445 Test Start : 10/23/2018 @ 06:58
Canister Type : Charcoal Canister 3 inch Test Stop : 10/25/2018 @ 07:00
Location : 1st FL=A-146 Received: 10/29/2018 @ 12:53
Radon Level : 1.3 pCi/L Analyzed: 11/01/2018 @ 10:30
Error for Measurement is: ± 0.8 pCi/L

Canister ID# : 2619446 Test Start : 10/23/2018 @ 06:58
Canister Type : Charcoal Canister 3 inch Test Stop : 10/25/2018 @ 06:58
Location : 1st FL=Theater #2 Received: 10/29/2018 @ 12:53
Radon Level : 0.1 pCi/L Analyzed: 11/01/2018 @ 11:02
Error for Measurement is: ± 0.8 pCi/L

Canister ID# : 2619461 Test Start : 10/23/2018 @ 06:00
Canister Type : Charcoal Canister 3 inch Test Stop : 10/25/2018 @ 06:00
Location : 1st FL=E-102 BL Received: 10/29/2018 @ 12:53
Radon Level : 0.1 pCi/L Analyzed: 10/31/2018 @ 16:24
Error for Measurement is: ± 0.2 pCi/L

Canister ID# : 2619463 Test Start : 10/23/2018 @ 05:59
Canister Type : Charcoal Canister 3 inch Test Stop : 10/25/2018 @ 05:59
Location : 1st FL=E-102 Received: 10/29/2018 @ 12:53
Radon Level : 0.2 pCi/L Analyzed: 10/31/2018 @ 16:42
Error for Measurement is: ± 0.5 pCi/L

Canister ID# : 2619466 Test Start : 10/23/2018 @ 05:45
Canister Type : Charcoal Canister 3 inch Test Stop : 10/25/2018 @ 05:50
Location : 1st FL=D-108 Culinary Received: 10/29/2018 @ 12:53
Radon Level : 0.4 pCi/L Analyzed: 11/01/2018 @ 10:47
Error for Measurement is: ± 0.7 pCi/L

Canister ID# : 2679158 Test Start : 10/23/2018 @ 05:54
Canister Type : Charcoal Canister 3 inch Test Stop : 10/25/2018 @ 06:06
Location : 1st FL=Main Off. V A-116 Received: 10/29/2018 @ 12:53
Radon Level : 0.6 pCi/L Analyzed: 11/01/2018 @ 10:49
Error for Measurement is: ± 0.5 pCi/L



Andreas C. George

Andreas C. George
Radon Measurement Specialist
NJ MES 11089

Dante Galan

Dante Galan
Laboratory Director

NRSB ARL0001
NYS ELAP ID: 10806
PADEP ID: 0346
NJDEP ID: NY933
NJ MEB 90036
FL DOH RB1609
IL RNL2000201

Site Radon Inspection Report

Date : 10/29/2018

Mr. Bryan Hogan
MEDFORD SCHOOL DISTRICT
815 South Oakdale Avenue
Medford, OR 97501-

Client: South Medford H.S.
Test Location: 1551 Cunningham Avenue
Medford, OR 97501-

Individual Canister Results

Canister ID# : 2679240 Test Start : 10/23/2018 @ 06:07
Canister Type : Charcoal Canister 3 inch Test Stop : 10/25/2018 @ 06:12
Location : 1st FL=A-153 Received: 10/29/2018 @ 12:53
Radon Level : 0.9 pCi/L Analyzed: 11/01/2018 @ 10:30
Error for Measurement is: ± 0.6 pCi/L

Canister ID# : 2679248 Test Start : 10/23/2018 @ 06:02
Canister Type : Charcoal Canister 3 inch Test Stop : 10/25/2018 @ 06:09
Location : 1st FL=A-152 Received: 10/29/2018 @ 12:53
Radon Level : 0.4 pCi/L Analyzed: 10/31/2018 @ 16:26
Error for Measurement is: ± 0.5 pCi/L

Canister ID# : 2679297 Test Start : 10/23/2018 @ 06:03
Canister Type : Charcoal Canister 3 inch Test Stop : 10/25/2018 @ 06:10
Location : 1st FL=Main Off. X A-120 Received: 10/29/2018 @ 12:53
Radon Level : 0.3 pCi/L Analyzed: 11/01/2018 @ 10:30
Error for Measurement is: ± 0.6 pCi/L

Canister ID# : 2681503 Test Start : 10/23/2018 @ 06:29
Canister Type : Charcoal Canister 3 inch Test Stop : 10/25/2018 @ 06:29
Location : 1st FL=Main Off. S A-110 Received: 10/29/2018 @ 12:53
Radon Level : 0.4 pCi/L Analyzed: 11/01/2018 @ 11:23
Error for Measurement is: ± 0.6 pCi/L

Canister ID# : 2681514 Test Start : 10/23/2018 @ 06:16
Canister Type : Charcoal Canister 3 inch Test Stop : 10/25/2018 @ 06:16
Location : 1st FL=Main Off. M A-129 Received: 10/29/2018 @ 12:53
Radon Level : 1.1 pCi/L Analyzed: 11/01/2018 @ 11:42
Error for Measurement is: ± 0.7 pCi/L

Canister ID# : 2681592 Test Start : 10/23/2018 @ 06:13
Canister Type : Charcoal Canister 3 inch Test Stop : 10/25/2018 @ 06:14
Location : 1st FL=Main Off. K A-128 Received: 10/29/2018 @ 12:53
Radon Level : 0.2 pCi/L Analyzed: 11/01/2018 @ 11:21
Error for Measurement is: ± 0.6 pCi/L



Andreas C. George

Andreas C. George
Radon Measurement Specialist
NJ MES 11089

Dante Galan

Dante Galan
Laboratory Director

NRSB ARL0001
NYS ELAP ID: 10806
PADEP ID: 0346
NJDEP ID: NY933
NJ MEB 90036
FL DOH RB1609
IL RNL2000201

Site Radon Inspection Report

Date : 10/29/2018

Mr. Bryan Hogan
MEDFORD SCHOOL DISTRICT
815 South Oakdale Avenue
Medford, OR 97501-

Client: South Medford H.S.
Test Location: 1551 Cunningham Avenue
Medford, OR 97501-

Individual Canister Results

Canister ID# : 2681593 Test Start : 10/23/2018 @ 06:09
Canister Type : Charcoal Canister 3 inch Test Stop : 10/25/2018 @ 06:09
Location : 1st FL=Main Off. J A-121 Received: 10/29/2018 @ 12:53
Radon Level : 0.8 pCi/L Analyzed: 11/01/2018 @ 10:49
Error for Measurement is: \pm 0.6 pCi/L

Canister ID# : 2681599 Test Start : 10/23/2018 @ 06:17
Canister Type : Charcoal Canister 3 inch Test Stop : 10/25/2018 @ 06:17
Location : 1st FL=Main Off. N A-133 Received: 10/29/2018 @ 12:53
Radon Level : 0.1 pCi/L Analyzed: 10/31/2018 @ 16:26
Error for Measurement is: \pm 0.4 pCi/L

Canister ID# : 2681616 Test Start : 10/23/2018 @ 06:25
Canister Type : Charcoal Canister 3 inch Test Stop : 10/25/2018 @ 06:25
Location : 1st FL=Main Off. Q Activites Received: 10/29/2018 @ 12:53
Radon Level : 0.5 pCi/L Analyzed: 11/01/2018 @ 11:05
Error for Measurement is: \pm 0.6 pCi/L

Canister ID# : 2681621 Test Start : 10/23/2018 @ 06:21
Canister Type : Charcoal Canister 3 inch Test Stop : 10/25/2018 @ 06:22
Location : 1st FL=A-156 Received: 10/29/2018 @ 12:53
Radon Level : 0.8 pCi/L Analyzed: 11/01/2018 @ 11:21
Error for Measurement is: \pm 0.8 pCi/L

Canister ID# : 2681683 Test Start : 10/23/2018 @ 06:11
Canister Type : Charcoal Canister 3 inch Test Stop : 10/25/2018 @ 06:13
Location : 1st FL=A-154 Received: 10/29/2018 @ 12:53
Radon Level : 0.1 pCi/L Analyzed: 10/31/2018 @ 16:07
Error for Measurement is: \pm 0.8 pCi/L



Andreas C. George

Andreas C. George
Radon Measurement Specialist
NJ MES 11089

Dante Galan

Dante Galan
Laboratory Director

NRSB ARL0001
NYS ELAP ID: 10806
PADEP ID: 0346
NJDEP ID: NY933
NJ MEB 90036
FL DOH RB1609
IL RNL2000201

Site Radon Inspection Report

Date : 10/29/2018

Mr. Bryan Hogan
MEDFORD SCHOOL DISTRICT
815 South Oakdale Avenue
Medford, OR 97501-

Client: South Medford H.S.
Test Location: 1551 Cunningham Avenue
Medford, OR 97501-

Individual Canister Results

The results indicate that at least one testing device registered at or above the United States Environmental Protection Agency (EPA) action level of 4.0 picoCuries per liter of air (pCi/L). The EPA recommends mitigation if the average of two short-term tests taken in the lowest level of the building suitable for occupancy show radon levels that are equal to or greater than 4.0 pCi/L.

For information on how to reduce radon levels in your home, please review the EPA booklet: Consumer's Guide to Radon Reduction (www.epa.gov/radon/pdfs/consguid.pdf) and contact your state health department. The EPA maintains a radon information website, including copies of its publications, at www.epa.gov/iaq/radon.

For New Jersey clients: Please see the attached guidance document entitled Radon Testing and Mitigation: The Basics for further information.

For New York clients: If the radon level of one or more testing devices is equal to or exceeds 20 pCi/L please contact the New York State Department of Health, Bureau of Environmental Radiation Protection, for technical advice and assistance at 518-402-7556 or toll free 1-800-458-1158.

PLEDGE OF ASSURED QUALITY

All procedures used for generating this report are in complete accordance with the current EPA protocols for the analysis of radon in air (EPA 402-R-92-004). The analytical results relate only to the samples tested, in the condition received by the lab, and that calculations were based upon the information supplied by client. RTCA and its personnel do not assume responsibility or liability, collectively and individually, for analysis results when detectors have been improperly handled or placed by the consumer, nor does RTCA and its personnel accept responsibility for any financial or health consequences of subsequent action or lack of action, taken by the customer or its consultants based on RTCA-provided results.



Andreas C. George
Radon Measurement Specialist
NJ MES 11089

Dante Galan
Laboratory Director

NRSB ARL0001
NYS ELAP ID: 10806
PADEP ID: 0346
NJDEP ID: NY933
NJ MEB 90036
FL DOH RB1609
IL RNL2000201